

Hagspiel, Simeon; Knaut, Andreas; Peter, Jakob

Working Paper

Reliability in multi-regional power systems: Capacity adequacy and the role of interconnectors

EWI Working Paper, No. 17/07

Provided in Cooperation with:

Institute of Energy Economics at the University of Cologne (EWI)

Suggested Citation: Hagspiel, Simeon; Knaut, Andreas; Peter, Jakob (2017) : Reliability in multi-regional power systems: Capacity adequacy and the role of interconnectors, EWI Working Paper, No. 17/07, Institute of Energy Economics at the University of Cologne (EWI), Köln

This Version is available at:

<https://hdl.handle.net/10419/172837>

Standard-Nutzungsbedingungen:

Die Dokumente auf EconStor dürfen zu eigenen wissenschaftlichen Zwecken und zum Privatgebrauch gespeichert und kopiert werden.

Sie dürfen die Dokumente nicht für öffentliche oder kommerzielle Zwecke vervielfältigen, öffentlich ausstellen, öffentlich zugänglich machen, vertreiben oder anderweitig nutzen.

Sofern die Verfasser die Dokumente unter Open-Content-Lizenzen (insbesondere CC-Lizenzen) zur Verfügung gestellt haben sollten, gelten abweichend von diesen Nutzungsbedingungen die in der dort genannten Lizenz gewährten Nutzungsrechte.

Terms of use:

Documents in EconStor may be saved and copied for your personal and scholarly purposes.

You are not to copy documents for public or commercial purposes, to exhibit the documents publicly, to make them publicly available on the internet, or to distribute or otherwise use the documents in public.

If the documents have been made available under an Open Content Licence (especially Creative Commons Licences), you may exercise further usage rights as specified in the indicated licence.

Reliability in multi-regional power systems - Capacity adequacy and the role of interconnectors

AUTHORS

Simeon Hagspiel

Andreas Knaut

Jakob Peter

EWI Working Paper, No 17/07

August 2017

**Institute of Energy Economics
at the University of Cologne (EWI)**

Alte Wagenfabrik
Vogelsanger Str. 321a
50827 Köln
Germany

Tel.: +49 (0)221 277 29-100
Fax: +49 (0)221 277 29-400
www.ewi.uni-koeln.de

CORRESPONDING AUTHOR

Jakob Peter
Institute of Energy Economics at the University of Cologne (EWI)
jakob.peter@ewi.uni-koeln.de

ISSN: 1862-3808

The responsibility for working papers lies solely with the authors. Any views expressed are those of the authors and do not necessarily represent those of the EWI.

Reliability in multi-regional power systems – Capacity adequacy and the role of interconnectors

Simeon Hagspiel^a, Andreas Knaut^b, Jakob Peter^{b,*}

^a*University of Cologne, Department of Economics, Universitätsstrasse 22a, 50937 Cologne, Germany*

^b*University of Cologne, Institute of Energy Economics (EWI), Vogelsanger Strasse 321a, 50827 Cologne, Germany*

Abstract

Based upon probabilistic reliability metrics, we develop an optimization model to determine the efficient amount and location of firm generation capacity to achieve reliability targets in multi-regional electricity systems. A particular focus lies on the representation and contribution of transmission capacities as well as variable renewable resources. Calibrating our model with a comprehensive dataset for Europe, we find that there are substantial benefits from regional cooperation. The amount of firm generation capacity to meet a perfectly reliable system could be reduced by 32.4 GW (i.e., 6.1 %) compared to an isolated regional approach, which translates to savings of 12.9 Bn Euro when being valued with typical investment costs of an open-cycle gas turbine. Interconnectors contribute in both directions, with capacity values up to their technical maximum of close to 200 %, while wind power contributions are in the range of 3.8-29.5 %. Furthermore, we find that specific reliability targets heavily impact the efficient amount and distribution of reliable capacity as well as the contribution of individual technologies, and should therefore be chosen with care.

Keywords: Reliability of supply, Capacity adequacy, Multi-regional power system, Interconnector, Variable renewable energy

JEL classification: C61, C63, D47, L50, Q42, Q48

1. Introduction

Due to its high economic value, reliability of supply has always been a major concern in electricity systems. The topic has been subject to extensive scientific research effort, both from a technical as well as an economic perspective (see, e.g., Billinton (1970) or Telson (1975) for early contributions in the two fields). However, new challenges are currently arising due to the large-scale deployment of renewable energies to avoid greenhouse gas emissions and combat climate change.

The authors want to thank Felix Hoeffler and Marc Oliver Bettzuege for their helpful comments, Marius Overath for his support, and the participants of the workshops "15. Wind Integration Workshop" (Vienna, 2016) and „Transition to power systems with weather-dependent generation“ (Cologne, 2016) for valuable discussions. The work was carried out within the UoC Emerging Group on "Energy Transition and Climate Change (ET-CC)" as well as within the UoC Forum "Market design and regulation for stochastic electricity supply chains". Funding by the DFG Zukunftskonzept (ZUK 81/1) is gratefully acknowledged.

*Email: jakob.peter@ewi.uni-koeln.de

The reason lies in the variable nature of many renewable energy resources, such as wind and solar, and the possible risk of recurring unavailability during times of stress (e.g., Cramton et al. (2013)).

In order to foster reliability of supply in power systems, interconnections with neighboring regions have proven an effective means. As such, balancing effects in supply and demand may be lifted, and better overall reliability levels be reached (e.g., Cepeda et al. (2009) or Hagspiel (2017)). In fact, enhanced reliability of supply was the main reason to create large interconnected electricity systems, such as the European or the North-American one. In the context of renewable energy integration, large-scale systems gain further importance due to the fact that renewable energy resources are typically more diverse on a wide geographical scope. Hence, cooperative actions with respect to reliability gain further importance to account for balancing effects (both in load and generation) and to reach envisaged reliability levels at lower costs compared to an isolated approach.

From a political perspective, however, reliability of supply is often considered an issue of national interest. As a consequence, assessments and measures to ensure reliability often have a narrow spatial scope, e.g., bounded by national borders. For instance, capacity mechanisms have been put into place in many power systems worldwide, with the aim to reach a certain level of reliability within national borders (e.g., Joskow (2008)). In this context, interconnectors with neighboring countries are often included in a very simplified manner, or even excluded explicitly. This inevitably results in market distortions and economic inefficiencies (e.g. Newbery (2015)). As a countermeasure, the European Union has recently required member states to account for cross-border trade within capacity mechanisms (EU Commission, 2016). Benefits shall thus be lifted by means of cooperative considerations and actions. However, it so far lacks stringent approaches to investigate reliability in multi-regional power systems with capacity-constrained interconnectors to ensure security of supply in highly meshed and interdependent electricity systems (Newbery (2015)). At the same time – as we will show in this paper – cross-regional effects and interconnectors have a major impact on reliability assessments. Especially, they largely drive the overall amount and distribution of generation capacity needed to ensure reliability. Therefore, misspecifications may entail substantial economic inefficiencies and distributive effects.

As a simple intuitive example, consider two systems A and B : In an isolated system-state, A and B both require 5 units of reliable capacity to achieve a certain reliability target. It is clear that the overall amount of reliable capacity might be decreased to less than 10 units when these systems interconnect, for instance due to statistical balancing in load. However, determining the optimal overall amount of reliable capacity Z and its best locational shares Z_A, Z_B for reliable capacities requires a consistent analysis of the entire system, including the joint probability distribution of load and generation as well as limited interconnection capacities. Naturally, the extension to $N > 2$ interconnected systems further complicates the problem and constitutes a complex multivariate probabilistic optimization problem.

Against this background, this paper provides a comprehensive framework to investigate reli-

ability in power systems consisting of multiple technologies and multiple interconnected regions. We first review well-known probabilistic metrics to determine the level of reliability in isolated one-regional power systems as well as the contribution of individual generators (known as capacity value¹). Subsequently, we extend this literature which typically neglects capacity-constrained transmission infrastructure. In contrast to (stochastic) simulation techniques, we propose a novel approach based on a comprehensive optimization model that flexibly accounts for multi-regional settings and multiple generation technologies, including dispatchable power plants and variable renewable energies, as well as capacity-constrained transmission lines. The main innovative strength of this model lies in its ability to quantify the economically efficient amount and distribution of reliable capacity in each region within a consistent optimization framework. Furthermore, it may also be used to determine the capacity value of individual technologies in a system context.

After a general description of our methodology, we introduce the comprehensive numerical dataset used to calibrate our model for different European case studies. The focus of the data lies on system properties incorporating large-scale variations – such as infeed from wind and solar power – to replicate the (joint) probability of various possible system outcomes. As direct observations are missing (due to a rapid system development with respect to the deployment of variable renewable energies), we build our optimization on a synthetic dataset created from 20 years of hourly reanalysis data with a high level of spatial resolution.

In a first step, we illustrate our approach based on two two-regional systems (namely France - Germany and France - Great Britain). Specifically, we depict how an interconnector can contribute to reliability, dependent on its size as well as the joint probability of load levels and capacity availability. Second, we apply the model to the entire European electricity system in order to quantify the efficient amount and location of firm generation capacity to achieve reliability targets as well as the contribution of wind power and interconnectors in a realistic case study. Compared to an isolated country-by-country approach, cooperation by means of an efficient usage of interconnectors would allow to reduce the overall necessary amount of reliable generation capacity by 32.4 GW (i.e., 6.1%) on a European level to ensure perfect reliability, also impacting the distribution of capacities. In this cooperative solution, several interconnectors contribute in both directions, with up to their technical maximum of close to 200% of their nominal capacity.² In contrast, due to its variability, the contribution of wind power is only in the range of 3.8-29.5%. These results provide empirical evidence that a consistent analysis of multi-regional systems with restricted interconnector capacities is crucial for reliability of supply analyses. In practice, our approach could thus be used for the improved design of capacity mechanisms by providing an approach to consider interdependencies with physically connected neighbors. Moreover, the large differences

¹Capacity value is also often referred to as capacity credit. Throughout this paper we will, however, stick to the term capacity value.

²In our calibration, we will assume a directional transmission efficiency <100%, such that the capacity value is slightly reduced.

between the first-best and isolated results provide strong arguments to achieve reliability targets efficiently in a cooperative manner, e.g., by means of joint capacity mechanisms.

As an additional insight, we find that specific reliability targets heavily impact the efficient amount and distribution of reliable capacity as well as the contribution of individual technologies. In practice, policymakers and system engineers should therefore choose reliability targets for power systems with care to avoid inefficiencies from excessively high (or low) capacity levels.

The rest of this paper is structured as follows: In Section 2, we introduce our methodology. The data are discussed in Section 3, while our results are comprised in Section 4. Section 5 concludes.

2. Methodology

Different methodologies have been proposed to determine generation adequacy and the capacity value of individual technologies in settings with one region only (i.e., without considering grid restrictions). The Loss-of-Load-Expectation (LOLE) and the Expected-Energy-Unserved (EEU) are two well established measures to depict the ability of a system to cover expected load levels (e.g., Billinton and Allan (1996)). After having determined the total system's adequacy, one may derive the contribution of individual technologies – typically referred to as capacity value or capacity credit (e.g., Keane et al. (2011), Madaeni et al. (2013)). Different approaches exist, but the equivalent firm capacity (EFC) is often recommended due to its ability to provide consistent results (Amelin (2009)).

In the following, we will first revise the well-known LOLE, EEU and EFC measures, valid for a one-region one-technology setting. We will then present an alternative formulation based on an optimization problem, before we extend our analysis to generation adequacy and the capacity value in a multi-region multi-technology context.

2.1. Notation

We will use the notation as listed in Table 1. Unless noted differently, we will use capital letters for random variables, bold capital letters for sets, and lower case letters for parameters, and bold lower case letters for nominal optimization variables.

2.2. Reliability metrics for one region only

In a self-contained system without transmission constraints, we follow Billinton and Allan (1996) and define the loss-of-load probability at a specific instant in time t as

$$LOLP_t = P(X_t^e < L_t), \quad (1)$$

i.e., as the probability that the available existing capacity X^e is smaller than load L_t . X_t^e will typically represent the availability of multiple power generators in the system, each characterized by its nominal capacity \bar{x}_i^e and its capacity availability $X_{i,t}^e \in [0, 1]$, such that $X_t^e = \sum_{i \in \mathbf{I}} \bar{x}_i^e X_{i,t}^e$.

Sets	
$i \in \mathbf{I}$	Existing generators
$m, n \in \mathbf{M}$	Regions
$t \in \mathbf{T}$	Time slices
Random variables	
L	Load
X^e	Availability of existing capacity
Y	Availability of extra capacity
K	Availability of import capacity
Parameters	
$LOLP$	Loss of load probability
$LOLE$	Loss of load expectation
EEU	Expected energy unserved
\bar{x}^e	Nominal capacity of existing generator
x^e	Availability of existing generator
\bar{y}	Nominal capacity of extra generator
v	Capacity value of extra capacity \bar{y}
l	Load
\bar{k}	Transmission capacity
η	Transmission efficiency
Optimization variables	
\mathbf{z}	Overall equivalent firm capacity needed
\mathbf{z}^y	Equivalent firm capacity of extra capacity \bar{y}
\mathbf{u}	Load curtailment
\mathbf{k}	Capacity exchange

Table 1: Model sets, parameters and variables

Note that in the above equation, we implicitly assume that load is inelastic with no adjustment when capacity is scarce, e.g., due to the lack of real time pricing. Consequently, in a market environment, there may be situations where all capacities are running at maximum availability without being able to serve the level of load, i.e., market clearing cannot be guaranteed even if there are high price levels.

Summing up probabilities over some time-period T yields the well-known reliability level measure Loss-of-Load-Expectation

$$LOLE = \sum_{t \in \mathbf{T}} LOLP_t. \quad (2)$$

A straightforward extension of the LOLE is the reliability measure EEU, weighting the LOLPs with the expected load level that cannot be served (therefore indicating the severity of these situations):

$$EEU = \sum_{t \in \mathbf{T}} E(L_t - X_t^e) * LOLP_t. \quad (3)$$

To determine the contribution of individual technologies, we determine their equivalent firm capacity (EFC). I.e., we derive the amount of equivalent firm capacity \mathbf{z}^y by which X_t^e can be reduced when installing some new capacity \bar{y} with availability $Y_t \in [0, 1]$ whose capacity value shall

be determined, such that the initial (target) reliability level EEU is achieved. To this end, the modified equation that needs to be solved for \mathbf{z}^y writes as

$$EEU = \sum_{t \in \mathbf{T}} E(L_t - (X_t^e + \bar{y}Y_t - \mathbf{z}^y)) * P(X_t^e + \bar{y}Y_t - \mathbf{z}^y < L_t). \quad (4)$$

Due to the fact that $\bar{y} > 0$ and $0 \leq Y_t \leq 1$, it must hold that $\mathbf{z}^y \geq 0$. The capacity value of a technology with capacity \bar{y} is then defined as

$$v = \frac{\mathbf{z}^y}{\bar{y}}, \quad (5)$$

with $0 \leq v \leq 1$.

Note that the above equations for the capacity value are typically solved by means of numerical iteration. Loosely speaking, after \bar{y} has been to the system, in each step \mathbf{z}^y is increased by some small amount until the target EEU is reached. Due to the convexity of the problem, this approach is guaranteed to yield the desired result.

2.3. The effect of interconnections

In contrast to the self-contained system considered before (say, system m), let us now study the effect of system interconnections. For illustration, assume m is interconnected with system n by means of a line with maximum transfer capacity \bar{k} . In this case, the $LOLP$ of m needs to be extended by several terms:³

$$LOLP_{m \leftarrow n} = P(X_m < L_m \text{ and} \quad (6a)$$

$$[X_n < L_n \text{ or} \quad (6b)$$

$$(X_n > L_n \text{ and } L_m - X_m > X_n - L_n) \text{ or} \quad (6c)$$

$$(X_n > L_n \text{ and } L_m - X_m < X_n - L_n \text{ and } L_m - X_m > \bar{k})]. \quad (6d)$$

The above equations state that a capacity shortage $X_m < L_m$ in system m may be relieved by means of an interconnection with system n . However, this does not hold if there is no spare capacity in n (Equation (6b)), if the spare capacity is not large enough to cover the shortage in m (Equation (6c)), or if the transfer capacity is not sufficient to cover the shortage in m (Equation (6d)). We will illustrate the meaning of these four terms for a numerical example in Section 4.

Note that comparing Equation (6) with Equation (1) reveals that it must hold that $LOLP^{m \leftarrow n} \leq LOLP^m$, i.e., that an interconnected system m is at least as reliable as if it was isolated. Con-

³For better readability, we skip the subscript t and superscript e here.

sequently, interconnections will have a neutral or a lowering effect on the level of equivalent firm capacity needed to serve load at some predefined level of reliability in the respective systems.

This beneficial effect may also be seen in an alternative formulation for the LOLP of m being interconnected with n , where capacity imports are contained in a lump-sum variable $K_{m\leftarrow n}$:

$$LOLP_{m\leftarrow n} = P(X_m + K_{m\leftarrow n} < L_m) \quad (7)$$

Due to the fact that only imports are considered, K is positive. From above, K is bounded by the import capacity \bar{k} , such that the support of $K_{m\leftarrow n}$ is $[0, \bar{k}]$. Of course – as stated above – if K is positive, it must be that $LOLP_{m\leftarrow n} \leq LOLP^m$. Or, conversely, that the amount of equivalent firm capacity needed may be smaller in an interconnected system to reach a fixed target reliability.

Unfortunately, beyond the statement that interconnections must yield positive effects, this theoretical analysis does not allow to derive further details regarding the size of the effect. This is due to the fact that the specific system’s *LOLP* (and thus, its *LOLE*, too) depends on the specific statistical characteristics of the random variables involved, i.e., their joint distributions. In fact, even if assuming independent variables in the above equations, the joint distributions and inequalities can – if at all – analytically only be tackled by means of upper and lower bounds (e.g., by applying Hoeffding’s or Bennett’s inequality). The case is further complicated when considering dependent variables which naturally occur in our area of application, such as load and wind profiles in neighboring countries.

Because of these inherent analytical complexities, we will continue our analysis by presenting a framework to endogenously determine the level of equivalent firm capacity which we can calibrate with numerical data to derive further insights into the generation adequacy of multi-regional interconnected systems.

2.4. A framework for endogenous equivalent firm capacity

The above introduced reliability metrics typically build upon *exogenous* systems, characterized by the availability of existing capacities X_t^e and (expected future) demand levels L_t . In contrast, we suggest an approach to *endogenize* the level of equivalent firm capacity. Similar to the concept of equivalent firm capacity described in Equation (4), we strive for a probabilistic optimization program minimizing the equivalent firm capacity \mathbf{z} that needs to be added to (or removed from) the system to achieve the target reliability level *EEU*. For notational simplicity, let us drop the capacity additions \bar{y} and aggregate all capacities exogenously given to the system by their nominal capacities \bar{x}_i^e and their capacity availabilities $X_{i,t}^e$. The program to solve for one region can be

written as follows (8):

$$\begin{aligned} & \min \mathbf{z} && (8a) \\ \text{s.t.} \quad & \sum_{t \in \mathbf{T}} E(L_t - (\sum_{i \in \mathbf{I}} \bar{x}_i^e X_{i,t}^e + \mathbf{z})) * P(\sum_{i \in \mathbf{I}} \bar{x}_i^e X_{i,t}^e + \mathbf{z} < L_t) \leq EEU && (8b) \end{aligned}$$

Due to the fact that the above probabilistic problem is hardly solvable for the general case, we formulate its deterministic equivalent which is a linear program. The idea is to replace probabilities and random variables by their deterministic counterpart, which may then be calibrated based on data covering a large range of possible outcomes. The validity and consistency of the result obtained may then be justified by the central limit theorem (Zachary and Dent (2011)).

For one single region (or market), the objective function (9a) minimizes the equivalent firm capacity \mathbf{z} in this region subject to two constraints: First, the adequacy constraint (9b) states that the equivalent firm capacity should be greater or equal to the region-specific and time-varying demand l_t minus the load curtailment variable \mathbf{u}_t minus the sum of the exogenously given technologies' available capacity at every instant in time t . And second, the reliability constraint (9c) requires the sum of load curtailment activities \mathbf{u}_t not to exceed a certain reliability target, specified as expected energy unserved EEU within the considered period of time T .⁴

$$\begin{aligned} & \min \mathbf{z} && (9a) \\ \text{s.t.} \quad & \mathbf{z} \geq l_t - \mathbf{u}_t - \sum_{i \in \mathbf{I}} \bar{x}_i^e x_{i,t}^e \quad \forall t && (9b) \\ & \sum_{t \in \mathbf{T}} \mathbf{u}_t \leq EEU && (9c) \end{aligned}$$

Note that the load curtailment variable \mathbf{u}_t allows for a relaxation of the load serving requirement in Equation (9b). If EEU is set to zero, only one of the hourly constraints (9b) is binding, namely the hour of peak residual demand (given that all residual demand levels are distinct).⁵ With EEU increasing, the peaks are increasingly shaved off.

⁴Note that it is straightforward to reformulate the problem when reliability targets are based on the *LOLE* measure. Specifically, equations (9b) and (9c) need to be modified using \mathbf{s}_t as the load shedding (binary) variable:

$$\begin{aligned} & \mathbf{z} \geq l_t \mathbf{s}_t - \sum_i \bar{x}_i^e x_{i,t}^e \quad \forall t \\ & \sum_t (1 - \mathbf{s}_t) \leq LOLE \end{aligned}$$

Note that for the case of *LOLE*, the problem becomes a mixed integer optimization.

⁵Residual demand = $l_t - \sum_i \bar{x}_i^e x_{i,t}^e$.

Solving problem (9) yields \mathbf{z}^* , i.e., the equivalent firm capacity required to obtain the requested level of reliability in one region. In order to determine the capacity value of technology $i = i'$, we simply need to set $\bar{x}_{i'}$ to zero and resolve the model, thus yielding \mathbf{z}^+ . Equivalent to the difference in equivalent firm capacity depicted in Equation (5), the technology and region-specific capacity value can then be calculated by Equation (10).

$$v = \frac{\mathbf{z}^+ - \mathbf{z}^*}{\bar{x}_{i'}} \quad (10)$$

2.5. Extension to interconnected regions

Extending problem (9) to multiple interconnected regions while assuming cooperation with respect to reliability, the planning problem becomes an integrated optimization. The objective function (11a) aims at minimizing the sum of required equivalent firm capacity \mathbf{z}_m over all regions, subject to five constraints: First, the adequacy constraint (11b) states that the required equivalent firm capacity should be greater or equal to the region-specific and time-varying load $l_{m,t}$ minus the load curtailment variable $\mathbf{u}_{m,t}$, minus the sum of the additional technologies' available capacity, and plus electricity exchanges $\mathbf{k}_{m,n,t}$ from region m to region n at every instant in time t . We charge electricity imports with an efficiency loss $\eta_{m,n}$ in order to account for transmission losses. The reliability constraint (11c) remains unchanged compared to the one-region optimization above. Note that by Equation (11c), a specific target reliability shall be reached within each region. Additionally, however, we now need an electricity exchange constraint (11d) limiting $\mathbf{k}_{m,n,t}$ to the installed transmission capacity $\bar{k}_{m,n}$.⁶

$$\min \sum_{m \in \mathbf{M}} \mathbf{z}_m \quad (11a)$$

$$\text{s.t.} \quad \mathbf{z}_m \geq l_{m,t} - \mathbf{u}_{m,t} - \sum_{i \in \mathbf{I}} \bar{x}_{i,m}^e x_{i,m,t}^e + \mathbf{k}_{m,n,t} - \eta_{m,n} \mathbf{k}_{n,m,t} \quad \forall m, n, t, m \neq n \quad (11b)$$

$$\sum_{t \in \mathbf{T}} \mathbf{u}_{m,t} \leq EEU_m \quad \forall m \quad (11c)$$

$$\mathbf{k}_{m,n,t} \leq \bar{k}_{m,n} \quad \forall m, n, t, m \neq n \quad (11d)$$

Solving problem (11) yields \mathbf{z}_m^* . In order to determine the capacity value of technology $i = i'$ in region $m = m'$ with respect to the entire system, we set the corresponding capacity $\bar{x}_{i',m'}^e$ to zero and resolve the model, which yields \mathbf{z}_m^+ . Based on the result we can calculate $v_{m',i'} = \frac{\sum_{m \in \mathbf{M}} \mathbf{z}_m^+ - \mathbf{z}_m^*}{\bar{x}_{i',m'}^e}$. In contrast, if we aim at the capacity value of technology $i = i'$ in region $m = m'$ with respect to its

⁶Again, reformulation to represent the *LOLE* measure is straightforward.

own isolated region m' , we solve the problem for isolated systems and calculate $v_{m',i'} = \frac{\mathbf{z}_{m'}^+ - \mathbf{z}_{m'}^*}{\bar{x}_{i',m'}^e}$. Analogously, we can determine the capacity value of a specific transmission capacity $\bar{k}_{m',n'}$ between region $m = m'$ and $n = n'$ by setting the capacity to zero and solving for capacity levels \mathbf{z}_m^+ .

3. Data

The data required to calibrate our model can be classified into three areas: First, we need region- and time-specific load levels ($l_{m,t}$). Second, information is required for capacity availabilities of existing generators, i.e., installed nominal capacity levels $\bar{x}_{i,m}^e$ as well as their corresponding availabilities $x_{i,m,t}^e$. Third, we need data on the transmission capacities $\bar{k}_{m,n}$.

Common to all data will be the regional coverage: We aggregate data on a national level, and cover the following European states: AT, BE, BG, CH, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IT, LT, LU, LV, NL, NO, PL, PT, RO, SE, SI, SK.

Recall that load $l_{m,t}$ and generation availability $x_{i,m,t}^e$ need to be calibrated with a large amount of possible outcomes to replicate the characteristics of the corresponding random variables L_t, X_t^e . To this end, we will deploy the so called hindcast approach, i.e., we calibrate the model using a large number of historical joint observations (for details, the reader is referred to Zachary and Dent (2011) and Keane et al. (2011)). Furthermore, we combine historical observations in order to better represent the joint probability space. Specifically, we focus our attention on load and wind capacity availability, which are the system properties with the largest variation.

Load data are taken from ENTSO-E (ENTSO-E (2016a)) for the years 2011 - 2015. They depict the national vertical load, i.e., the amount of electricity consumed, on an hourly basis. It should be noticed that these historical measurements were a result of a functioning electricity system and may include some price responsiveness of consumers or load shedding. To calibrate our model, however, we need to assume that the observed load data is price inelastic. Meanwhile, historical load data is the best proxy available for the fluctuating electricity demand over time, and price responsiveness during times of scarcity was indeed found to be fairly low (Lijesen, 2007).

Our hourly wind generation profiles are based on wind speeds from reanalysis data in COSMO-REA6 provided by the Hans Ertel Centre for Weather Research (HErZ) (Bollmeyer et al., 2015). Energy output has been calculated for the existing wind parks in 2014 using data from *The Wind Power*⁷ with the methodology explained in Henckes et al. (2016). The total dataset consists of 20 years with hourly wind production levels from 1995 - 2014.

We combine each load year with each wind year available in order to get a good representation of the joint probability space. Noticeably, we implicitly assume there is no causal relationship between wind and load. This leads us to a total of 120 years with hourly load and wind data. Note

⁷www.thewindpower.net

that the amount of data used in our analysis is well beyond the requirements identified by Hasche et al. (2011), and can hence be expected to yield consistent results.

In contrast to the detailed representation of load and wind, we abstract from a full representation of other existing generators in the system. This is mainly due to three reasons: First, detailed information about installed capacities of individual generators and their capacity availabilities is difficult to obtain. Second, abstraction allows to circumvent the need to derive a probability function for the availability of capacity X , usually depicted via a Capacity Outage Probability Table (COPT) and calculated via convolution. Third, and most importantly, abstraction is in line with our objective to determine the amount of equivalent firm capacity needed to serve load at some level of reliability. Therefore, our model can be seen as a way to endogenously determine the amount of equivalent firm capacity that needs to enter the system while other system characteristics are fixed. For instance, the expansion of renewable energies is typically driven by support schemes and hence, largely exogenous.

Data on transmission capacities are based on publications by ENTSO-E in the Ten Year Network Development Plan (ENTSO-E, 2016b). We make use of Net Transfer Capacity (NTC) values to represent average transmission capacities between countries in 2016. NTC is the maximum exchange program between two areas compatible with security standards applicable in both areas and taking into account the technical uncertainties on future network conditions ETSO (2001).

4. Results

We present our results in two main steps: first, we consider the illustrative case of two-regional systems to gain insights into the general problem characteristics and model outcomes. Second, we deploy our complete dataset for the entire European continent for more comprehensive and realistic results.

4.1. Two-regional system

4.1.1. Isolated regions

For illustration, we parametrise our isolated region model (i.e., problem 9) with one year of data from France, Germany and Great Britain. Figure 1 shows scatter plots of residual load (i.e., load - wind power) for the country combinations Great Britain (GB)- France (FR) (left) and Germany (DE)- France (FR) (right).

The dashed lines represent the level of equivalent firm capacity (\mathbf{z}_m) required in the respective region when they strive for reliability in an isolated approach. We apply here a typical reliability benchmark of 3 hours per year which is often used in theory (e.g., Keane et al. (2011)) as well as in practice (e.g., in the capacity markets in Great Britain or by the ISO New England). Therefore, the scatter plots depict residual load levels exceeding the necessary level of equivalent firm capacity during 3 hours in each region. In our methodology section, this would have been depicted by an




Figure 1: Critical residual demand in the isolated two-regional systems Great Britain - France (left) and Germany - France (right) for $LOLE = 3 \text{ h/y}$

expected value of 3 in Equation (2). Naturally, tightening the reliability target shifts the required equivalent firm capacity lines outwards, up to a perfectly reliable system ($LOLE = 0$) where the dotted lines cover all residual load levels and no load shedding is allowed to occur.

Note that in the right hand side figure, there is one situation where residual load cannot be met in both regions at the same time (indicated by the dot in the rectangle in the upper right corner). In contrast, the data in the left hand side figure show no coincidental load shedding. This is crucial for benefits from cooperation, as demonstrated in Equation (6) and discussed in the subsequent section.

4.1.2. Cooperating regions

In case of cooperation, regions take into account interconnections with neighbors to reach their envisaged reliability target while solving the integrated problem (11). Therefore, they take full advantage of balancing effects on the supply as well as on the demand side.

Requirements for equivalent firm capacity. For illustration, in Figure 2 we recapture the country combinations Great Britain - France and Germany - France. Again, the thicker dashed lines depict the necessary equivalent firm capacity level per region which can now be reduced due to gains from cooperation (corresponds to term (6a) in Equation (6)). The thinner dotted lines represent the sum of equivalent firm capacity plus transmission capacity (2 GW for GB - FR and 1.2 GW for FR - DE), derated by a transfer efficiency of 0.95. Thus, all points in between the dashed and dotted lines – indicated by green triangles – can be covered by capacity exchange between the two regions.

Noticeably, interconnectors can only contribute to system adequacy if there is sufficient generation in the adjacent region to be exported. This is the case as long as the point of interest does not lie above the sloped dotted line in the top right corner which limits the interconnector's contribution to system adequacy (depicted by terms (6b)-(6d) in Equation (6)).





Figure 2: Critical residual demand in the cooperating two-regional systems Great Britain - France (left) and Germany - France (right) for $\text{LOLE} = 3 \text{ h/y}$

The capacity value of wind power. Figure 3 shows the capacity value of wind power derived from Equation (10) and the full dataset for isolated and cooperating two-regional systems. In general, our results confirm that the capacity value decreases with increasing capacity installations due to decreasing returns to scale (e.g., see numerical evidence by Hasche et al. (2011) or Keane et al. (2011), or theoretical analyses by Zachary and Dent (2011) or Hagspiel (2016)). For perfectly reliable systems ($\text{LOLE} = 0$), the problem reduces to the analysis of the hour with peak residual load. Due to the stochastic nature and at times low output of wind power, this approach yields low and rather flat capacity values in a perfectly reliable system (Figures 3a, 3b). Flat capacity values arise when peak residual load is reduced at a constant rate with increasing wind capacity. Relaxing the reliability constraint to $\text{LOLE} = 3$ (Figures 3c, 3d) and the corresponding EEU (Figures 3e, 3f) increases the capacity value of wind, due to the fact that wind is then allowed to deliver its contribution within a longer (i.e., relaxed) period.⁸ Thus we observe that setting a low reliability level EEU results in flat capacity values for wind power which in turn increases equivalent firm capacity requirements and thereby total system costs.


Figure 3 also shows how the capacity value of wind is affected by cooperation, i.e., a change in the reference system the wind may contribute to. For $\text{LOLE} = 0$, wind in Great Britain and France does not benefit from cooperation, as the interconnector is used to its full capacity during peak load, irrespective of the installed wind capacity in the two regions (Figures 3a, 3b). In contrast, the usage of German interconnectors during peak load increases with increasing wind capacity, thus reducing the equivalent firm capacity requirements of the interconnected system, and resulting in improved wind capacity values (Figure 3b).

Interestingly, at relaxed reliability levels and wind capacities $>10 \text{ GW}$ in Great Britain, the capacity value of wind for cooperating regions is (slightly) lower than for isolated regions. This at first counter-intuitive result can be explained by the observation that, in contrast to wind capacities


⁸The EEU has been derived from Equation (3) with an $\text{LOLE} = 3$ in isolated regions, thus amounting to GB 3.72 GWh, FR 6.17 GWh, and DE 2.43 GWh.




(a) Wind power in GB and FR, respectively, for two-region system GB-FR | LOLE = 0




(b) Wind power in DE and FR, respectively, for two-region system DE-FR | LOLE = 0




(c) Wind power in GB and FR, respectively, for two-region system GB-FR | LOLE = 3



(d) Wind power in DE and FR, respectively, for two-region system DE-FR | LOLE = 3



(e) Wind power in GB and FR, respectively, for two-region system GB-FR | EEU



(f) Wind power in DE and FR, respectively, for two-region system DE-FR | EEU

Figure 3: Capacity value of wind power for isolated and cooperating two-region systems GB-FR (left) and DE-FR (right) with different reliability targets (Upper graphs: LOLE=0, middle graphs: LOLE=3, lower graphs: corresponding EEU)

<10 GW, the critical residual load situations switch to hours where the interconnectors with France and Great Britain are congested, resulting in higher equivalent firm capacity requirement.

Even though the EEU reliability target is directly derived from $\text{LOLE} = 3$, capacity values are different (Figures 3e, 3f). Especially, the capacity value of wind in France for capacities < 10 GW is not constant as for $\text{LOLE} = 3$, but decreases starting from a higher value. This is due to the fact that the EEU target allows to distribute the energy unserved to an arbitrary amount instead of only a restricted amount of hours.

The capacity value of interconnectors. Figure 4 shows the capacity value of the interconnectors for cooperating two-regional systems. Noticeably, values can exceed 100% due to its utilisation in two directions. Thus, they are limited by 200% in a world without transmission losses, and by 190% when taking into account directional efficiency factors of $\eta = 0.95$.




Figure 4: Capacity value of interconnectors for cooperating two-region systems GB-FR (left) and DE-FR (right) with different reliability targets

The interconnector between Great Britain and France is found to be highly beneficial, contributing its technical maximum to both regions at low capacity levels. This implies that peak load hours are mutually exclusive. Capacity values begin to drop slightly after 4.3 GW for $\text{LOLE} = 3$, and after 2 GW for relaxed reliability targets.

Looking at the two-country system Germany-France with $\text{LOLE} = 0$, the interconnector capacity value is at its maximum up to an interconnector capacity of 1.3 GW, followed by a sharp decrease. Relaxing the reliability level to $\text{LOLE} = 3$ or EEU leads to new peak residual demand situations where the interconnector capacity is not fully utilised anymore. This results in lower values for small capacities, but also much slower decrease (such that the curves intersect with the one for $\text{LOLE} = 0$). Essentially, this is due to the shape of the residual demand curve as compared to the peak residual load.

4.2. European system

We will now investigate efficiency gains through cooperation on a European level. More specifically, we look at minimum required equivalent firm capacity in each region considering all system interactions under the assumption of cooperation, and compare it to the results in isolated regions. Moreover, we calculate the reliability contributions of individual technologies.

Requirements for equivalent firm capacity. The equivalent firm capacity aggregated over Europe as a function of the reliability target EEU for isolated regions and cooperating regions is shown in Figure 5. We observe that – as expected – relaxing the reliability target reduces the required level of equivalent firm capacity. While capacity requirements are reduced more significantly when moving away from an EEU of zero, reductions become smaller for further relaxations of the reliability target. The capacity savings induced by European cooperation (compared to isolated efforts) are significant and range from 36.1 GW for EEU = 0 % to 25.8 GW for EEU = 0.01 %. This corresponds to a relative reduction of 6.4, %-5.1,%. When valuing the reduced capacity needs with 400 EUR/kW (i.e., typical investment costs of an open-cycle gas turbine which can be regarded as safe back-up capacity), the gains from cooperation amount to 10.3- 14.5 Bn. EUR.




Figure 5: Capacity requirements as a function of EEU with the respective gains from cooperation (marked in black).

Even though capacity requirements are generally decreased with relaxed targets, country-specific gains from cooperation are more diverse (Figure 6). For instance, in Denmark (DK), at a reliability level of EEU = 0.001 % of annual load, the reduction in equivalent firm capacity is lower than for EEU = 0.01 %. Therefore, cooperation not only affects efficiency (i.e., the overall amount of capacity needed), but also entails distributive effects. The country-specific capacity savings for EEU = 0.001 %, which corresponds roughly to LOLE = 3, range from 82 to 6430 MW. Comparing to the market size in the respective countries, we find relative capacity savings of 1.6 % - 30.7 % with respect to the country-specific peak load.

The capacity value of wind power. Figure 7 shows the country-specific capacity value of wind power in 2015 with respect to two different system boundaries. It ranges broadly from 3.2, % to 25.5, % in isolated, and from 3.8, % to 29.5, % in cooperating regions (i.e., on a European level).⁹ Noticeably, changing the system boundaries from isolated to cooperating entails increasing capacity values for some of the regions (e.g., for wind in Germany), but also adverse effects (e.g., for wind in France).

⁹Note that SK is not shown in this figure due to missing wind power data for that region.




Figure 6: Gains from cooperation: Reduction in equivalent firm capacity with cooperation

This is due to the fact that the load profile wind power needs to match is changed, while it is unclear a priori whether this is facilitating or complicating the task.




Figure 7: Country-specific capacity value of wind power with respect to total system for isolated and cooperating regions

The influence of the reliability level on the capacity value of wind power (in case of cooperation on an EU level) is shown in Figure 8. We observe that in tendency, lower reliability levels have an increasing effect on the capacity value of wind. For perfectly reliable systems ($EEU = 0\%$), the analysis is limited to the peak residual demand hour, and thus very sensitive. Therefore, the capacity values vary considerably depending on the respective generation level in that particular hour.

Besides the optimized values, our modeling framework also allows to determine marginal capacity values of technologies. This is done by substituting the nominal capacity parameters with variables and adding additional constraints fixing the variables to the nominal capacity parameters. This seemingly cumbersome formulation helps us to derive the marginal capacity value via the Lagrange multiplier. We find that for wind power, marginal values are smaller but close to the actual values, due to decreasing returns to scale. Thus, marginal values differ most for regions




Figure 8: Country-specific capacity value of wind power with respect to total system for different reliability levels EEU

with large amounts of wind power being installed, such as Germany or Denmark, for instance. The detailed results can be found in the Appendix.

The capacity value of interconnectors. Figure 9 shows the capacity values of the existing interconnector capacities in 2015 with respect to the total system for different reliability levels EEU. Results are driven by the difference in demand and generation profiles, as well as their correlation. Some less embedded regions take particular advantage when being interconnected, i.e., Great Britain, Italy, and Romania. The interconnector from/to the Iberian Peninsula (FR-ES) is also highly beneficial to ensure reliability of supply in an efficient way. Marginal values are again shown in the Appendix.




Figure 9: Capacity values of interconnectors between two regions with respect to total system (EU)

5. Conclusion

Reliability of supply is of key importance in any power system. In order to achieve reliability targets efficiently, balancing effects and gains from cooperation may be deployed by means of large-scale interconnected systems. In practice, however, reliability is often considered on a narrow spatial

scale (e.g., national). Furthermore, it lacks consistent approaches to consider interdependencies with other regions along with scarce transmission capacities.

In this paper, we have therefore developed a comprehensive computational framework to determine the efficient amount and location of firm generation capacity needed to achieve reliability targets in multi-regional systems with constrained transmission capacities. In addition, the model allows to value the contribution of individual technologies to reliability, such as wind power in a particular country or specific interconnectors.

Calibrated with a detailed dataset for Europe, our calculations show that there are indeed large benefits from cooperation: compared to an isolated country-by-country approach, the amount of firm capacity to meet a perfectly reliable system may be reduced by 32.4 GW (i.e., 6.1 %) when considering reliability in a cooperative manner, which translates to 12.9 Bn. Euro when valued with typical investment costs of an open-cycle gas turbine. Individual countries could reduce their amounts by up to 31.8%. In this cooperative solution, some interconnectors contribute substantially – in both directions – with up to their technical maximum. Especially valuable are the interconnectors from/to Great Britain, Italy, and Romania, as well as the interconnector between France and Spain. Capacity expansions at those borders would therefore help most to further reduce the need for firm generation capacity. Despite its fluctuations, wind power in European countries would in the cooperative solution be able to contribute with 3.7-29.5 % of its nominal capacity to the reduction of necessary firm generation capacity, compared to a capacity value of 3.1-25.5 % when considering reliability in isolated countries.

As an additional key insight, we find that the amount and distribution of reliable capacity as well as the contribution of individual technologies strongly depend on the specific reliability target required from the system. For instance, pushing the target from an Expected Energy Unserved of 0.01 % to perfect reliability requires 29.1 GW of additional firm capacity in a coordinated European solution, and 33.0 GW for isolated target fulfillment. Therefore, targets should be carefully revisited and chosen to avoid substantial economic inefficiencies.

Our paper could be extended in several directions: The network infrastructure could be represented in more detail, e.g., by means of full-fledged load flow equations in our optimization framework. Strategic interactions between regions could be considered to investigate (and eventually, facilitate) the process of cooperative actions. The model could also be extended to tackle the problem of optimal reliability targets by a more detailed and endogenous representation of the supply, transmission and demand side including their cost structures.

References

- Amelin, M., 2009. Comparison of capacity credit calculation methods for conventional power plants and wind power. *IEEE Transactions on Power Systems* 24 (2), 685–691.
- Billinton, R., 1970. *Power system reliability evaluation*. Taylor & Francis.
- Billinton, R., Allan, R. N., 1996. *Reliability evaluation of power systems*, 2nd ed. New York: Plenum Publishing Corporation.
- Bollmeyer, C., Keller, J., Ohlwein, C., Wahl, S., Crewell, S., Friederichs, P., Hense, A., Keune, J., Kneifel, S., Pscheidt, I., et al., 2015. Towards a high-resolution regional reanalysis for the european cordex domain. *Quarterly Journal of the Royal Meteorological Society* 141 (686), 1–15.
- Cepeda, M., Saguan, M., Finon, D., Pignon, V., 2009. Generation adequacy and transmission interconnection in regional electricity markets. *Energy Policy* 37 (12), 5612–5622.
- Cramton, P., Ockenfels, A., Stoft, S., 2013. Capacity market fundamentals. *Economics of Energy & Environmental Policy* 2 (2), 27–46.
- ENTSO-E, 2016a. Hourly load levels for european countries.
URL <https://www.entsoe.eu/data/data-portal/consumption/Pages/default.aspx>
- ENTSO-E, 2016b. Ten-year network development plan 2016.
URL <http://tyndp.entsoe.eu/reference/#downloads>
- ETSO, 2001. *Definitions of transfer capacities in liberalised electricity markets - final report*.
- EU Commission, Nov. 2016. Regulation of the european parliament and of the council on the internal market for electricity com(2016)861.
URL http://ec.europa.eu/energy/sites/ener/files/documents/1_en_act_part1_v9.pdf
- Hagspiel, S., 2016. Supply chain reliability and the role of individual suppliers. *EWI Working Paper* 16/05.
- Hagspiel, S., 2017. Reliability through spatial integration and cooperation. *EWI Working Paper* forthcoming.
- Hasche, B., Keane, A., O'Malley, M., 2011. Capacity value of wind power, calculation, and data requirements: the irish power system case. *IEEE Transactions on Power Systems* 26 (1), 420–430.
- Henckes, P., Knaut, A., Obermüller, F., 2016. Twenty years of european wind power production - balancing effects in europe with a focus on germany. In: *15th Annual Int. Workshop on Large-Scale Integration of Wind Power into Power Systems as Well as on Transmission Networks for Offshore Wind Power Plants*, Vienna, Austria.
- Joskow, P. L., 2008. Lessons learned from electricity market liberalization. *The Energy Journal* 29 (Special Issue# 2).
- Keane, A., Milligan, M., Dent, C., Hasche, B., D'Annunzio, C., Dragoon, K., Holttinen, H., Samaan, N., Soder, L., O'Malley, M., 2011. Capacity value of wind power. *IEEE Transactions on Power Systems* 26 (2), 564–572.
- Lijesen, M. G., 2007. The real-time price elasticity of electricity. *Energy economics* 29 (2), 249–258.
- Madaeni, S., Sioshansi, R., Denholm, P., 2013. Comparing capacity value estimation techniques for photovoltaic solar power. *IEEE Journal of Photovoltaics* 13 (1), 407–415.
- Newbery, D., 2015. *Security of supply, capacity auctions and interconnectors*. Energy Policy Research Group, University of Cambridge. Retrieved from <http://www.eprg.group.cam.ac.uk/wpcontent/uploads/2015/03/EPRG-WP-15081.pdf>.
- Telson, M. L., 1975. The economics of alternative levels of reliability for electric power generation systems. *The Bell Journal of Economics*, 679–694.
- Zachary, S., Dent, C. J., 2011. Probability theory of capacity value of additional generation. *Proceedings of the Institution of Mechanical Engineers, Part O: Journal of Risk and Reliability* 226 (1), 33–43.

6. Appendix

The marginal capacity value of wind power in case of cooperation is shown in Figure 10 for different reliability targets EEU. One can observe that a higher reliability level has no clear directional influence on the capacity value of wind power.




Figure 10: Country-specific marginal capacity value of wind power with respect to total system for different reliability levels EEU

Figure 11 shows the marginal capacity values of interconnectors. As expected, in line with the capacity values derived in Figure 9, the marginal capacity values of the interconnectors of little interconnected regions are highest. This points to the insight that an expansion of these interconnectors would be most beneficial with respect to system reliability in case of cooperation.




Figure 11: Marginal capacity values of interconnectors between two regions with respect to total system (EU)