

Singh, Bindeshwar; Mishra, Deependra Kumar

Article

A survey on enhancement of power system performances by optimally placed DG in distribution networks

Energy Reports

Provided in Cooperation with:

Elsevier

Suggested Citation: Singh, Bindeshwar; Mishra, Deependra Kumar (2018) : A survey on enhancement of power system performances by optimally placed DG in distribution networks, Energy Reports, ISSN 2352-4847, Elsevier, Amsterdam, Vol. 4, pp. 129-158, <https://doi.org/10.1016/j.egyr.2018.01.004>

This Version is available at:

<https://hdl.handle.net/10419/187896>

Standard-Nutzungsbedingungen:

Die Dokumente auf EconStor dürfen zu eigenen wissenschaftlichen Zwecken und zum Privatgebrauch gespeichert und kopiert werden.

Sie dürfen die Dokumente nicht für öffentliche oder kommerzielle Zwecke vervielfältigen, öffentlich ausstellen, öffentlich zugänglich machen, vertreiben oder anderweitig nutzen.

Sofern die Verfasser die Dokumente unter Open-Content-Lizenzen (insbesondere CC-Lizenzen) zur Verfügung gestellt haben sollten, gelten abweichend von diesen Nutzungsbedingungen die in der dort genannten Lizenz gewährten Nutzungsrechte.

Terms of use:

Documents in EconStor may be saved and copied for your personal and scholarly purposes.

You are not to copy documents for public or commercial purposes, to exhibit the documents publicly, to make them publicly available on the internet, or to distribute or otherwise use the documents in public.

If the documents have been made available under an Open Content Licence (especially Creative Commons Licences), you may exercise further usage rights as specified in the indicated licence.



<https://creativecommons.org/licenses/by-nc-nd/4.0/>



Research paper

A survey on enhancement of power system performances by optimally placed DG in distribution networks

Bindeshwar Singh ^{*}, Deependra Kumar Mishra

Kamla Nehru Institute of Technology (KNIT), Sultanpur, Uttar Pradesh, India



ARTICLE INFO

Article history:

Received 21 May 2017

Received in revised form 23 January 2018

Accepted 24 January 2018

Keywords:

Artificial intelligence techniques

Distributed generation (DG)

Distribution networks (DNs)

Optimally placed distributed generation

Power system performances

ABSTRACT

This paper presents a survey on enhancement of power system performances by optimally placed distributed generations in distribution networks. The distribution power system performances such as minimization of real power loss, minimization of reactive power loss, improvement of voltage profile, short circuit current capacity, system average interruption duration index (SAIDI), customers average interruption duration index (CAIDI), power system oscillations, available power transfer capacity of system, loadability of the system, reliability and security of the system, power system stability etc. are considered in this survey paper as major issue in distribution networks. Such power system performances can be enhanced by conventional devices as well as planning of DG technologies such as fuel cell, biogas, wind turbine, photovoltaic, solar, geo-thermal, tidal and wave etc. This survey paper is very much useful for scientific persons, engineers, industrial persons and researchers regarding with enhancement of power system performances by optimally placed distributed generations in distribution networks.

© 2018 Published by Elsevier Ltd. This is an open access article under the CC BY license (<http://creativecommons.org/licenses/by/4.0/>).

1. Introduction

DG is an approach of small-scale electricity generation at a customer site, this approach is fairly new idea in the economics point of view about electricity markets, but the idea behind it is not new at all. In the starting days, DG was not used to the transmission, balancing demand and supply was partially done using local storage, i.e. batteries, which is directly coupled to the DC grid. Application of DG local storage is also coming in application, technology development, uses of AC grid allowed to electricity transmitted over a long distance and economic of generation electricity increase the power output according to demand. All this results with increased convenience and lower per unit costs a large electrical system were constructed, consisting of long distance transmission system with high capacity distribution grids and large generating plants to balancing demand and supply was done by the averaging effect.

According to Ackermann DG is defined as “Distributed generation is an electric power source connected directly to the distribution network or on the customer site of the meter”. There are some other points of view to define the DG like real power, independent operation, capacity of generation etc. the DG basically classified in two category such as renewable and non renewable. The renewable DG such as wind power plants, solar power plants, solar cell

power plants, biogas power plants, tidal power plants, wave power plant, ocean power plants, geo thermal power plants etc. and non renewable DG such as doubly fed induction generation, diesel engine, Internal combustion engine etc. the DG can be broadly classified on basis of real and reactive power delivered/absorbed as follows:

- (i) **DG Type 1:** At unity power factor, the real and reactive power delivered by DG to the system, is known as type-1 DG such as wave energy source wind power source, and tidal energy source etc.
- (ii) **DG Type 2:** At 0.8 to 0.99 leading power factors, only real power delivered by DG to the system is known as a type-2 DG such as fuel cell, photovoltaic system, and solar power plant etc.
- (iii) **DG Type 3:** At zero power factor, only reactive power support provided by DG to the system is known as type-3 DG such as synchronous motor in over excited mode, phase modifier circuit or synchronous condenser etc.
- (iv) **DG Type 4:** At 0.8 to 0.99 lagging power factor, provides real power support to the system and absorbs reactive power from the system by DG is known as a type-4 DG such as DFIG etc.

Several advantages of DG like minimization of the real power loss and reactive power loss, enhance voltage stability of the system, reduce power system oscillation, increase available power

* Corresponding author.

E-mail addresses: bindeshwar.singh2025@gmail.com, bindeshwar.singh@knit.ac.in (B. Singh).

Nomenclature

DG	Distributed generations
ODGP	Optimal distributed generations planning
DISCO	Distributed company
GA	Genetic algorithm
ANN	Artificial neural network
OPF	Optimum power flow
LPF	Load power flow
DFIG	Doubly fed induction generator
PSO	Particle swarm optimization
ABC	Ant Bee colony algorithm
ACS	Ant colony search algorithm
DLF	Decoupled load Flow
PST	Pole shifting technique
APF	Adaptive power flow
MOEA	Multi objective evolutionary algorithm
MPSO	Modified particle swarm optimization
SA	Simulated annealing
TS	tabu search
GSA	Gravitational search algorithms
HA	Heuristic algorithms
KFA	Kalman filter algorithms
HRA	Hereforced ranch algorithms
OT	optimization technique
LM	Load model
AP	Analytical approach
NLP	Non-linear programming method
MOOA	Multi objective optimization algorithm
MOF	Multi-objective function

transfer capability, reduce pollution as it uses cleaner energy resources, increase loadability of the system, increase bandwidth of operation, hence more flexible operation, more social and economic benefits etc. besides this benefits, also the some limitation of DG like small power generation, subsidiary system to the main system, mechanical maintenance required, and choice of type of DG system greatly depend upon the environmental factors etc. the view of power quality, DG is used for reduction of harmonics, prevent voltage sag and voltage swell, to reduce the transient period, minimization of voltage fluctuation and power factor improvement. This development has led to the breaking up of investments (small generating units), emergence of new generation techniques with small ratings, ecological benefits, increased profitability, combined with heat generation, saturation of existing networks and the continuous growth of the demand.

The importance of DG is now being increasingly accepted and realized by power system engineers. The planning of DG is a feasible alternative for new capacity especially in the competitive electricity market environment and has immense benefits such as: short lead time and low investment risk since it is built-in modules, small-capacity modules that can track load variation more closely, small physical size that can be installed at load centers, and the existence of a fast range of DG technologies. Different schemes have been proposed in this paper, distribution network capacity expansion considering the options of adding new substations and connecting feeders. The drawbacks of DG are as follows: fuel problems in non renewable DG, and DG can be always using only at load center.

This paper organized as follows: Section 2 presented the mathematical modeling of DG for optimal placement. Section 3 presented the taxonomical reviews on DG planning from power system performances point of view. Section 4 presented the summary of paper. Section 5 presented the conclusion and the future scope of work.

2. Mathematical modeling of DG for optimal placement

2.1. Mathematical modeling of static loads

The planning of different types of DG, for different load scenario i.e. summer day, summer night, winter day, and winter night loads, a IEEE-38 bus distribution system is adopted (Singh et al., 2007a, b). In this paper, the line impedances, load data and the line power limits are expressed in p.u. At the base voltage of 12.66 kV and base MVA of 10 MVA (Singh et al., 2007a, b). In conventional load flow analysis, the active and reactive power loads are assumed as constant power load whereas, in practice, the loads may be voltage dependent i.e. industrial, residential, and commercial loads which may be represented by models as described in (IEEE Task Force, 1993). The voltage dependent load model is a static load model that represents the power relationship to voltage as an exponential equation, and represented in following Eqs. (1)–(2) form.

$$P_{i_bus} = P_{0i_bus} \left(\frac{|V_{i_bus}|}{|V_{0i_bus}|} \right)^{\alpha\text{pha}}$$
 (1)

$$Q_{i_bus} = Q_{0i_bus} \left(\frac{|V_{i_bus}|}{|V_{0i_bus}|} \right)^{\beta\text{eta}}$$
 (2)

where, P_{i_bus} , Q_{i_bus} , P_{0i_bus} , Q_{0i_bus} , V_{i_bus} , and V_{0i_bus} are in per unit. Above Eqs. (1) and (2) neglect the frequency dependence of distribution system load, due to the fact that it is phenomenon which cannot be controlled locally and remain same for whole of the system. In practice, the load on each bus may be the composition of industrial, residential, and commercial which may vary with seasonal day and night. Therefore, in this paper the seasonal mixed load model at each bus is considered as described in Qian et al. (2011) and represented in following Eqs. (3)–(4) form.

$$\begin{aligned} P_{i_bus} = & w_{i_bus_pi} P_{0i_bus} \left(\frac{|V_{i_bus}|}{|V_{0i_bus}|} \right)^{\alpha\text{pha}_{i_bus}} \\ & + w_{r_bus_pi} P_{0i_bus} \left(\frac{|V_{i_bus}|}{|V_{0i_bus}|} \right)^{\alpha\text{pha}_{r_bus}} \\ & + w_{c_bus_pi} P_{0i_bus} \left(\frac{|V_{i_bus}|}{|V_{0i_bus}|} \right)^{\alpha\text{pha}_{c_bus}} \end{aligned}$$
 (3)

$$\begin{aligned} Q_{i_bus} = & w_{i_bus_qi} Q_{0i_bus} \left(\frac{|V_{i_bus}|}{|V_{0i_bus}|} \right)^{\beta\text{eta}_{i_bus}} \\ & + w_{r_bus_qi} Q_{0i_bus} \left(\frac{|V_{i_bus}|}{|V_{0i_bus}|} \right)^{\beta\text{eta}_{r_bus}} \\ & + w_{c_bus_qi} Q_{0i_bus} \left(\frac{|V_{i_bus}|}{|V_{0i_bus}|} \right)^{\beta\text{eta}_{c_bus}} \end{aligned}$$
 (4)

where, αpha_{i_bus} and βeta_{i_bus} are active and reactive exponents for industrial load model; αpha_{r_bus} and βeta_{r_bus} are active and reactive exponents for residential load model; αpha_{c_bus} and βeta_{c_bus} are active and reactive exponents for commercial load model; $w_{i_bus_pi}$, $w_{r_bus_pi}$, and $w_{c_bus_pi}$ are the relevant factors for active industrial, residential, and commercial Load models at bus i ; $w_{i_bus_qi}$, $w_{r_bus_qi}$, and $w_{c_bus_qi}$ are the relevant factors for reactive industrial, residential, and commercial Load models at bus i .

The following condition expressed in Eqs. (5)–(6) must be satisfied for all buses except buses without load (BWL) (Bus 1 is slack bus and buses 34 to 38 are not having load).

$$w_{i_bus_pi} + w_{r_bus_pi} + w_{c_bus_pi} = 1$$
 (5)

$$w_{i_bus_qi} + w_{r_bus_qi} + w_{c_bus_qi} = 1$$
 (6)

The values for exponents of voltage for active and reactive component of summer day, summer night, winter day, and winter night load models are given in Qian et al. (2011). The relevant factor of each load model at each bus is (hypothetically generated) given in Payasi et al. (2013). In this study it is assumed that $w_{i_bus_p} = w_{i_bus_q}$, $w_{r_bus_p} = w_{r_bus_q}$, and $w_{c_bus_p} = w_{c_bus_q}$. The study is performed considering the situations of load, may be, in practice as follows: (1) each bus having mix of industrial, residential, and commercial load in certain proportion; (2) Loads vary with seasonal day and night. Apart from these situations, T1, T2, T3 and T4 are considered for comparative study. A 38 bus system is assumed to be supplying power to mix of industrial, residential, and commercial load without violating bus voltage and line capacity

limits. The following test cases are developed for optimal size and location of DG for constant and seasonal mixed load models for two objectives: (1) Real power loss (P_{Loss}) minimization; and (2) Apparent power intake (S_{intake}) minimization. The types of DGs are as follows: Type 1 DG; Type 2 DG; Type 3 DG; and Type 4 DG. The parameters considered for study are as follows:

- (a) Number of voltage limit violations (NVLV);
- (b) Number of line limits violations (NLCLV);
- (c) Apparent power intake (S_{intake}), real power intake (P_{intake}), and reactive power intake (Q_{intake}) at bus 1;
- (d) Real and reactive power loss (P_{Loss} and Q_{Loss});
- (e) Apparent system power requirement (S_{system});
- (f) Power system performance indices (P_{L_index} , Q_{L_index} , VP_index , and L_{C_index} , $SAID_{index}$, $CAID_{index}$).

2.2. Mathematical modeling of DG with NRLF

The formulation of DGP problem is proposed on the basis of two objective functions:

- (1) Real power loss (P_{Loss});
- (2) Apparent power intake (S_{intake}).

2.2.1. Minimization of real power loss

The objective function is total real power loss (P_{Loss}) in the system. The P_{Loss} in the system is represented by Eq. (7).

$$P_{Loss} = \sum_{i_bus, j_bus \in N_L} \frac{P_{i_bus, j_bus}^2 + Q_{i_bus, j_bus}^2}{|V_{i_bus}|^2} r_{i_bus, j_bus} \quad (7)$$

The P_{Load} is function of all system bus voltage (V_{i_bus}), line resistances (r_{i_bus, j_bus}), α lpha, and β eta. The total losses mainly depend on voltage profile.

2.2.2. Minimization of total power intake at substation

The objective function is apparent power intake (S_{intake}) at main substation. The P_{intake} is the sum of P_{Demand} and P_{Loss} , and represented by Eq. (8).

$$P_{intake} = P_1(V, P_0, Q_0, \alpha lpha, \beta eta) = P_{Demand} + P_{Loss} \\ = \sum_{i_bus=1}^{N_B} P_{0i_bus} (|V_{i_bus}| / |V_{0i_bus}|)^{\alpha lpha} + P_{Loss} \quad (8)$$

Similarly, the Q_{intake} is the sum of Q_D and Q_L , and represented by Eq. (9).

$$Q_{intake} = Q_1(V, P_0, Q_0, \alpha lpha, \beta eta) = Q_{Demand} + Q_{Loss} \\ = \sum_{i_bus=1}^{N_B} Q_{0i_bus} (|V_{i_bus}| / |V_{0i_bus}|)^{\beta eta} + Q_{Loss} \quad (9)$$

Apparent power intake at main substation is expressed as Eq. (10):

$$S_{intake} = [(P_{intake})^2 + (Q_{intake})^2]^{1/2} \quad (10)$$

And apparent power requirement for distribution system is expressed as Eq. (11):

$$S_{system} = [(P_{intake} \pm P_{DG})^2 + (Q_{intake} \pm Q_{DG})^2]^{1/2} \quad (11)$$

where, based on terminal characteristic are as follows: $Q_{DG} = 0.0$ for Type 1 DG; $P_{DG} = 0.0$ for Type 3 DG; and $Q_{DG} = -ve$ for Type 4 DG.

It is observed that for a distribution power system as Eqs. (12)–(13).

$$\sum_{i_bus=1}^{N_B} P_{0i_bus} (|V_{i_bus}| / |V_{0i_bus}|)^{\alpha lpha} \gg P_{Loss} \quad (12)$$

$$\sum_{i_bus=1}^{N_B} Q_{0i_bus} (|V_{i_bus}| / |V_{0i_bus}|)^{\beta eta} \gg Q_{Loss} \quad (13)$$

Thus the P_{intake} and Q_{intake} in Eqs. (8) and (9) respectively are largely decided by the load exponents α (Alpha) and β (Beta) not by P_{Load} and Q_{Load} .

The above objectives are subject to the following set of power flows, voltage limits, line power capacity limit, and DG size limit are expressed in Eqs. (14)–(20) respectively.

$$P_{i_bus} = \sum_{j_bus=1}^{N_B} |V_{i_bus}| |V_{j_bus}| [G_{i_bus, j_bus} \cos(\delta_{i_bus} - \delta_{j_bus}) \\ + B_{i_bus, j_bus} \sin(\delta_{i_bus} - \delta_{j_bus})] \quad (14)$$

$$Q_{i_bus} = \sum_{j_bus=1}^{N_B} |V_{i_bus}| |V_{j_bus}| [G_{i_bus, j_bus} \sin(\delta_{i_bus} - \delta_{j_bus}) \\ - B_{i_bus, j_bus} \cos(\delta_{i_bus} - \delta_{j_bus})] \quad (15)$$

$$P_{i_bus, j_bus} = |V_{i_bus}| G_{i_bus, j_bus} \\ - |V_{i_bus}| |V_{j_bus}| [G_{i_bus, j_bus} \cos(i_busj_bus) \\ - B_{i_bus, j_bus} \sin(i_busj_bus)] \quad (16)$$

$$Q_{i_bus, j_bus} = |V_{i_bus}| B_{i_bus, j_bus} \\ - |V_{i_bus}| |V_{j_bus}| [G_{i_bus, j_bus} \sin(i_busj_bus) \\ + B_{i_bus, j_bus} \cos(i_busj_bus)] \quad (17)$$

$$V_{min} \leq V_{i_bus} \leq V_{max} \quad (18)$$

$$S_{i_bus, j_bus} \leq CS_{i_bus, j_bus}^{\max} \quad (19)$$

$$P_{DG} \leq P_{intake} \quad (20)$$

In this paper voltage limits and line power capacity limit are as follows: $V_{min} = 0.95$ p.u and $V_{max} = 1.05$ p.u. CS_{i_bus, j_bus}^{\max} , for $i_bus, j_bus \in N_L$; Power capacity limits.

2.3. Power system performance indices to quantify the benefits of DG

The indices to quantify the benefits of DG are defined as follows (Singh et al., 2007a, b).

2.3.1. Real power loss index (P_{L_index})

The real power loss index is defined as Eq. (21):

$$P_{L_index} = \left(\frac{P_{L_WDG}}{P_{L_WODG}} \right) \times 100\% \quad (21)$$

The lower values of this index indicate better benefits in terms of real power loss reduction accrued due to DG location and size.

2.3.2. Reactive power loss index (Q_{L_index})

The reactive power loss index is defined as Eq. (22):

$$Q_{L_index} = \left(\frac{Q_{L_WDG}}{Q_{L_WODG}} \right) \times 100\% \quad (22)$$

The lower values of this index indicate better benefits in terms of reactive power loss reduction accrued due to DG location and size.

2.3.3. Voltage profile index (V_{P_index})

It is related to the maximum voltage drop between each node and root node. The lower values of this index indicate better performance of network. The V_{P_index} can be defined as Eq. (23):

$$V_{P_index} = \max \left(\frac{|V_{ref}| - |V_{i_bus}|}{|V_{ref}|} \right) \times 100 \quad (23)$$

2.3.4. Line capacity index (L_{C_index})

The power flows may diminish in some sections of the network and released more capacity with the power supplied near to the load. This index provides important information about the level of power flows/currents through the network regarding maximum capacity of distribution lines. Lower values of this index indicate more capacity available. This is defined as Eq. (24):

$$L_{C_index} = \max \left(\frac{S_{i_bus,j_bus}}{CS_{i_bus,j_bus}} \right) \times 100 \quad (24)$$

2.3.5. System average interruption duration index ($SAID_{index}$)

It is commonly referred to as customer minutes of interruption or customer hours and is designed to provide information as to the average time the customers are interrupted as Eq. (25).

$$SAID_{index} = \frac{\sum U_i N_i}{\sum N_i} \quad (25)$$

Here U_i is interruption duration at i th load point and N_i is the number of customer at i th load point.

2.3.6. Customers average interruption duration index ($CAID_{index}$)

It is the average time needed to restore service to the average customer per sustained interruption as Eq. (26).

$$CAID_{index} = \frac{\sum U_i N_i}{\sum \lambda_i N_i} \quad (26)$$

Here λ_i is the annual failure rate at i th feeder.

2.4. Multiobjective function for optimal planning of DG

The multi-objective function for optimal planning of DG in distribution power system from overall power system performance point of view as Eqs. (27)–(28).

$$F = \lambda_1 P_{L_index} + \lambda_2 Q_{L_index} + \lambda_3 V_{P_index} + \lambda_4 L_{C_index} + \lambda_5 SAID_{index} + \lambda_6 CAID_{index} \quad (27)$$

where

$$\sum_{m=1}^6 \lambda_m = 1 \quad (28)$$

The values of $\lambda_1, \lambda_2, \lambda_3, \lambda_4, \lambda_5, \lambda_6$ are selected on basis of priority order of distribution power system performances such as real power loss, reactive power loss, voltage profile and line capacity indices. The above objective function can be optimized by employing artificial intelligence computational techniques such as GA, PSO, ANN, Fuzzy algorithm, ABC algorithm, ACS algorithm, SA algorithm, Hybrid algorithm etc. Such AI techniques are reviewed in taxonomical form in Section 3. The value of above weight factor such as $\lambda_1, \lambda_2, \lambda_3, \lambda_4, \lambda_5, \lambda_6$ are given in Table 2.1.

3. Taxonomical reviews on DG planning from power system performances point of view

The taxonomical survey for the details of literature survey regarding with optimally placed DG in the distribution networks from the power system performance point of view presented in Table 3.1.

Table 2.1

Weight factor and its value on basis on priority.

Weight factors	Its value on basis of priority
λ_1	0.4
λ_2	0.3
λ_3	0.2
λ_4	0.05
λ_5	0.03
λ_6	0.02

4. Summary of paper

The summaries of paper are as follows:

4.1. Conventional methods

Table 4.1, shows the summary of this article from different conventional methods viewpoint.

Table 4.1, it is concluded that the conventional methods such as Eigen values method, Modal method, Added model method, Index method, OPF, PST, Monte-carlo method, Tradeoff method, LPF, Newton–Raphson are 2.9%, 27.94%, 19.11%, 9.5%, 20.5%, 3.68%, 2.21%, 3.68%, 8.09%, 2.21% respectively reviewed.

4.2. Artificial intelligence techniques

Table 4.2, shows the summary of this article from different artificial intelligence techniques viewpoint.

Table 4.2, it is concluded that the artificial intelligence techniques such as Genetic algorithms, Artificial neural network, Fuzzy logic, Particle swarm optimization, Ant bees colony, Gravitational search algorithms, tabu search, Simulated annealing, Heuristic algorithms, Kalman filter algorithms, Two stage planning algorithms, MMR algorithms, Evolutionary algorithms, Optimal algorithms, Immune system algorithms, Hereforced algorithms, Other are 37.64, 5.05, 5.05, 8.98, 16.29, 0.56, 1.12, 2.24, 8.42, 1.68, 0.56, 0.56, 1.12, 0.56, 0.56, 1.12, 8.42 respectively reviewed.

4.3. Optimization methods

Table 4.3, shows the summary of this article from different optimization methods viewpoint.

Table 4.3, it is concluded that the optimization methods such as Dynamic programming method, Linear programming method, Non-Linear programming method, Mixed integer non-linear programming method, Dual programming method, Other programming method are 20.22%, 11.23%, 34.83%, 24.71%, 2.80%, 6.17% respectively reviewed.

4.4. Hybrid intelligence techniques

Table 4.4, shows the summary of this article from different Hybrid intelligence techniques viewpoint.

Table 4.4, it is concluded that the hybrid artificial intelligence techniques such as FZ + GA, PSO + Model, OPF + Newton method, TS + SA, PSO + FZ, GA + BFGS, GSA + TS, GA + OPF, GA + PSO, FZ + HA are 35.29%, 5.88%, 5.88%, 5.88%, 11.76%, 5.88%, 5.88%, 11.76%, 5.88%, 5.88% respectively reviewed.

4.5. Others techniques

Table 4.5, shows the summary of this article from other techniques viewpoint.

Table 4.5, it is concluded that the others techniques such as Wind generation, Industrial Planning, Switching operation are 50%, 25%, 25% respectively reviewed.

Table 3.1

Taxonomical survey for the details of literature survey regarding with optimally placed DG in the distribution networks from the power system performance point of view.

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Pregelj et al.	2006	DG-1	Reliability	GA	IEEE 9 bus system	Static	Hybrid
Kansal et al.	2011	DG-4	Real power loss	PSO	IEEE 33 bus system	Static	Hybrid
Acharya et al.	2006	DG-2	Power loss reduction	GA	IEEE 33,37 bus system	Static	Hybrid
Ackermann et al.	2001	DG-1	Power loss reduction	LM	IEEE 15 bus system	Static	Hybrid
Pavlos et al.	2013	DG-1	ODGP Problem	GA	IEEE 69 bus system	Static	Hybrid
Shereen	2012	DG-1	Power loss reduction	GA	IEEE 33 bus system	Static	Hybrid
Huddleston et al.	1990	DG-1	Real power loss	OT	IEEE 33 bus system	Static	Hybrid
Georgilakis and Hatziargyriou	2013	DG-3	ODGP Problem	GA	IEEE 15 bus system	Static	Hybrid
Kashem et al.	2000b	DG-1	Loss	HA	IEEE33 bus system	Static	Hybrid
Rau and Wan	1994	DG-1	loss reduction	AP	IEEE 33,37 bus system	Static	Hybrid
Borozan and Rajakovic	1997	DG-1	Real power loss	OT	IEEE 37 bus system	Static	Hybrid
Ackermann et al.	2000	DG-4	Cost	AP	IEEE 9,69 bus system	Static	MOF
Khator and Leung	1997	DG-1	Power loss and Voltage	OT	IEEE 33,37 bus system	Static	Hybrid
Kim et al.	1998a	DG-4	Power loss	OPF	IEEE 33,37 bus system	Static	Hybrid
Ault et al.	2003	DG-1	Power loss and Voltage	OT	IEEE 37,69 bus system	Static	Hybrid
Griffin et al.	2000a	DG-1	Power loss + location	OT	IEEE 33,37 bus system	Static	Hybrid
Willis	2000a	DG-3	location	Model	IEEE 15 bus system	Static	Hybrid
Gray	1998	DG-2	Cost	OT	IEEE 33 bus system	Static	Hybrid
Zhu et al.	2006	DG-4	Reliability + efficiency	GA	IEEE 33,37 bus system	Static	Hybrid
Hoff and Shugar	1995	DG-1	Loss	GA	IEEE 37,69 bus system	Static	Hybrid
Kim et al.	1993	DG-1	Loss	ANN	IEEE 9,69 bus system	Static	Hybrid
Dugan et al.	2001	DG-1	Power loss and Voltage	OT	IEEE 9,33 bus system	Static	Hybrid
Ochoa et al.	2008c	DG-4	Time varying generation	Multi objective index	IEEE 15 bus system	Static	Hybrid
Kotari et al.	1996	DG-1	Location	PST	IEEE 37,69 bus system	Static	Hybrid
Wang and Singh	2008	DG-1	Reliability	Algorithm	IEEE 33,37 bus system	Static	Hybrid
Friedman	1998	DG-2	Cost	OT	IEEE 37 bus system	Static	Hybrid
Pavlos et al.	2013	DG-1	Power loss	OT	IEEE 33,37 bus system	Static	Hybrid
Porkar et al.	2011	DG-1	Loss+reliability	NLP	IEEE 69 bus system	Static	Hybrid
Brown and Freeman	2001	DG-3	Cost+location	OT	IEEE 9 bus system	Static	Hybrid
Khalesi et al.	2011	DG-3	Loss+reliability	Dynamic programming	IEEE 69 bus system	Static	Hybrid
Taleski and Rajicic	1997	DG-1	Real power loss	OT	IEEE 15 bus system	Static	Hybrid
Jabr and Pal	2009b	DG-1	Location+sizing	Ordinal optimization	IEEE 33,37 bus system	Static	Hybrid
Shirmohammadi and Hong	1989	DG-1	Real power loss	AP	IEEE 9,37 bus system	Static	Hybrid
Ramakumar	2001	DG-1	Cost+location	OT	IEEE 37,69 bus system	Static	MOF
Baran and Wu	1989b	DG-1	Loss	GA	IEEE 33 bus system	Static	Hybrid
Hegazy et al.	2003	DG-4	Voltage	Monte carlo method	IEEE 69 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Barker	2000	DG-4	Loss+capacity	OT	IEEE 37 bus system	Static	Hybrid
Ding and Gergis	2001	DG-1	Load+Loss	OT	IEEE 37 bus system	Static	Hybrid
Zhou et al.	1997	DG-1	Cost	ANN	IEEE 33,37 bus system	Static	Hybrid
Chiradeja and Ramakumar	2004	DG-1	Size+cost	Quantification method	IEEE 69 bus system	Static	Hybrid
Singh and Goswami	2009	DG-1	Siting+sizing	radial and networked	IEEE 15 bus system	Static	Hybrid
Broadwater et al.	1993	DG-1	Real power loss	AP	IEEE 37 bus system	Static	Hybrid
Peponis et al.	1995	DG-4	Real power loss	OT	IEEE 69 bus system	Static	Hybrid
Yokoyama et al.	1998	DG-2	Power loss+location	Probability security criteria	IEEE 9,37 bus system	Static	MOF
Harrison and Wallace	2005	DG-2	Size+loss	OPF	IEEE 69 bus system	Static	Hybrid
Civanlar et al.	1988	DG-1	Real power loss	GA	IEEE 33 bus system	Static	Hybrid
Tuba Gözel et al.	2009	DG-1	Sizing+sitting	radial systems	IEEE 15 bus system	Static	Hybrid
Ochoa et al.	2010	DG-1	capacity assessment	active networks	IEEE 33,37 bus system	Static	Hybrid
Goswami and Basu	1992	DG-1	Real power loss	AP	IEEE 37 bus system	Static	Hybrid
Kumaranand and Gao	2010	DG-1	Location	NLP	IEEE 69 bus system	Static	Hybrid
Kashem et al.	1998	DG-1	Power loss	OT	IEEE 37 bus system	Static	Hybrid
Khodr et al.	2010	DG-1	Location	OT	IEEE 69 bus system	Static	Hybrid
Brown et al.	2001	DG-1	Power loss and Voltage	AP	IEEE 37 bus system	Static	Hybrid
Hadjisaid et al.	1999a	DG-4	Loss	OT	IEEE 33 bus system	Static	Hybrid
Ault et al.	2002	DG-1	Power loss and Voltage	AP	IEEE 37,69 bus system	Static	Hybrid
Lasseter	1998	DG-3	Power loss	OT	IEEE 33,37 bus system	Static	Hybrid
Jabri and Pal	2009b	DG-1	Sizing	Ordinal optimization	IEEE 69 bus system	Static	Hybrid
Edwards et al.	2000	DG-1	Power loss,voltage	OT	IEEE 37 bus system	Static	Hybrid
Singh and Goswami	2010	DG-1	loss	Optimum allocation	IEEE 69 bus system	Static	Hybrid
Chao et al.	1999	DG-3	Capacity	GA	IEEE 9,33 bus system	Static	Hybrid
Lee and Park	2009	DG-1	optimal location+size	Kalman filter algorithm	IEEE 9 bus system	Static	Hybrid
Quintana et al.	1993	DG-1	Power loss and Voltage	Two stage-planning algorithm	IEEE 69 bus system	Static	Dynamic
Gonen and Ramírez-Rosado	1986	DG-1	Power loss+location	OT	IEEE 9 bus system	Static	Hybrid
Kim et al.	2002	DG-4	Location	Fuzzy+GA	IEEE 37,9 bus system	Static	Time varying load
Khan and Choudhry	2010a	DG-1	Feeder	Algorithm	IEEE 69 bus system	Static	Hybrid
Ault and McDonald	2000	DG-1	Location+capacity	TS	IEEE 37 bus system	Static	Hybrid
Rau and Wan	1994	DG-3	Location	OT	IEEE 37 bus system	Static	Hybrid
Willis	2000b	DG-1	Location+power loss	AP	IEEE 9,33 bus system	Static	MOF
Khan and Choudhry	2010b	DG-2	Feeder+load	Algorithm	IEEE 15 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Willis	1997	DG-1	Location	ANN	IEEE 69,9 bus system	Static	Hybrid
Thirault et al.	2002	DG-1	Cost	OT	IEEE 9 bus system	Static	MOF
Keane and O'Malley	2005	DG-1	Location	ABC	IEEE 69,37 bus system	Static	Hybrid
Raiassi et al.	1997	DG-1	Power loss	AP	IEEE 9,69 bus system	Static	Hybrid
Lopez-Lezama et al.	2012	DG-4	Location+contract pricing	GA	IEEE 33,37 bus system	Static	Hybrid
Khattamet et al.	2004	DG-1	Cost+size	HA	IEEE 69,37 bus system	Static	Hybrid
Kellogg et al.	1998	DG-3	Cost+capacity	OT	IEEE 33 bus system	Static	MOF
Ochoa et al.	2008c	DG-2	Location	Multi objective index	IEEE 15 bus system	Static	Hybrid
Hadjsaid et al.	1999b	DG-4	Cost	OT	IEEE 33 bus system	Static	Hybrid
Rashid et al.	2010	DG-1	Size+Location	Intelligent Techniques	IEEE 69 bus system	Static	Hybrid
Nehrir et al.	2003	DG-1	Power loss+cost	OT	IEEE 9,37 bus system	Dynamic	Hybrid
Akorede et al.	2010	DG-1	Strategies	Optimal Placement	IEEE 15 bus system	Static	Hybrid
Kim et al.	1998	DG-1	Location	HRA	IEEE 69 bus system	Static	Hybrid
Lalitha et al.	2011	DG-1	Siting and Sizing	RCCA	IEEE 9,69 bus system	Static	Hybrid
Dugan and Price	2002	DG-4	Location+size	OT	IEEE 37,69 bus system	Static	Hybrid
Wang and Hsshem	2004	DG-1	Location	AP	IEEE 37,69 bus system	Static	Hybrid
Chiradeja and Ramakumar	1998	DG-4	Capacity+location	OT	IEEE 9,37,69 bus system	Static	MOF
Dugan and Mcdermont	2002	DG-1	Cost+size	OT	IEEE 37,69 bus system	Static	Hybrid
Scott	1998	DG-1	Power loss+location	OT	IEEE 933 bus system	Static	Hybrid
Sharma and Vittal	2010	DG-4	Allocation	HA	IEEE 9,69 bus system	Static	Hybrid
Rahman	2001	DG-1	Power loss+cost	AP	IEEE 9,37 bus system	Static	Hybrid
Kotb et al.	2010	DG-1	Siting+Sizing	GA	IEEE 69 bus system	Static	Hybrid
Price	2002	DG-1	Location + Size	OT	IEEE 69 bus system	Static	Hybrid
Singh et al.	2009a	DG-1	Load Models	Radial Distribution	IEEE 15 bus system	Static	Dynamic
Del Monaco	2000	DG-1	Location+cost+size	OT	IEEE 969 bus system	Static	Hybrid
Kuerasuk and Ongsakul	2006	DG-1	Optimal Placement	PSO	IEEE9,33 bus system	Static	Hybrid
Nara et al.	1992	DG-1	Loss	GA	IEEE 37,69 bus system	Static	Hybrid
Hien et al.	2013	DG-4	Location +loss +cost	OT	IEEE 9 bus system	Static	Hybrid
Rodrigo et al.	2005	DG-1	Size	OT	IEEE 69 bus system	Static	Hybrid
Zhu	2002	DG-1	Location	GA	IEEE 9,33 bus system	Static	Hybrid
Jabr and Pal	2009b	DG-4	Location +size	OT	IEEE 69 bus system	Static	Hybrid
Biswas and Goswami	2010	DG-1	Loss+voltage	GA	IEEE 37,69 bus system	Static	Hybrid
Ochoa et al.	2008a	DG-1	Load + Cost	OT	IEEE 9 bus system	Static	Hybrid
Kamel and Kermanshahi	2009	DG-1	Size+location+loss	OT	IEEE 37,69 bus system	Static	Hybrid
Silvestri et al.	1999	DG-1	Location	GA	IEEE 37 bus system	Static	Hybrid
Kashem et al.	2006	DG-1	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Jain et al.	2010	DG-1	Siting+Sizing	PSO	IEEE 69 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Bernardon et al.	2005	DG-4	Loss+cost	GA	IEEE 15 bus system	Static	Hybrid
Hajizadeh and Hajizadeh	2008	DG-1	Planning	PSO	IEEE 9,33 bus system	Static	Hybrid
Dale	2002	DG-1	Location	OT	IEEE 37 bus system	Static	Hybrid
Amanifar and Golshan	2011	DG-1	Loss + voltage	PSO+Sensitivity Analysis	IEEE 9bus system	Static	Hybrid
Lopez et al.	2004	DG-4	Capacity	OT	IEEE 69 bus system	Static	Hybrid
Milligan and Graham	1996	DG-1	Location+cost	Probability simulation technique	IEEE 9,69 bus system	Static	Hybrid
Greene et al.	1997	DG-1	Voltage	Contingency analysis	IEEE 9,33 bus system	Static	Dynamic
Su	2010	DG-1	Voltage+location	OT	IEEE 9 bus system	Static	Hybrid
Ochoa et al.	2010	DG-1	Capacity	Analytical method	IEEE 69 bus system	Static	Hybrid
Caire et al.	2002	DG-4	Loss+ cost	GA	IEEE 37,69 bus system	Static	Hybrid
Ramakumar and Chiradeja	2002	DG-4	Location	OT	IEEE 9 bus system	Static	Hybrid
Yassami et al.	2011	DG-4	Reliability +loss	MOOA	IEEE 9,33 bus system	Static	Hybrid
Chiradeja and Ramakumar	2001	DG-3	Voltage+loss	Probabilistic approach	IEEE 37,69 bus system	Static	Hybrid
Rezaei and Vakilian	2010	DG-3	Location+loss	MPSO	IEEE 69 bus system	Static	Hybrid
Su and Lee	2003	DG-3	Location +loss +cost	Mixed integer programming	IEEE 9 bus system	Static	Hybrid
Kumar and Kumar	2011	DG-1	Voltage +loss	PSO	IEEE 30 bus system	Static	Hybrid
Merlin and Back	1975	DG-1	Loss	Spanning tree	IEEE 15 bus system	Static	Hybrid
Shirmohammadi and Hong	1989	DG-1	Loss	GA	IEEE 37 bus system	Static	Hybrid
Ramos et al.	2005	DG-3	Loss	Path based technique	IEEE 9,33 bus system	Static	Hybrid
Augugliaro et al.	2004	DG-3	Voltage+loss	OT	IEEE 69 bus system	Static	Hybrid
Mohammad and Nasab	2011	DG-3	Reliability +loss	GA	IEEE 9 bus system	Static	Hybrid
Glamocanin	1990	DG-2	Loss	OT	IEEE 33 bus system	Static	Hybrid
Taylor and Lubkeman	1990	DG-2	Loss+location	HA	IEEE 69 bus system	Static	Hybrid
Roytelman et al.	1996	DG-2	Location+loss+size	OT	IEEE 37 bus system	Static	Hybrid
Lalitha et al.	2010	DG-1	Loss	Algorithm	IEEE 9,33 bus system	Static	MOF
Das	2006	DG-1	Location+loss	FZ	IEEE 69 bus system	Static	Hybrid
Gil and Joos	2006	DG-1	Cost	Quantification	IEEE 37,69 bus system	Static	Hybrid
Conejo et al.	2002	DG-1	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Gareth et al.	2007	DG-4	Cost	Trade off method	IEEE 9 bus system	Static	Hybrid
Paliwal and Patidar	2010	DG-4	Loss	Model	IEEE 69 bus system	Static	Hybrid
Chiang and Jean-Jumeau	1990b	DG-1	Loss+location	OT	IEEE 69,9 bus system	Static	Hybrid
Rezazadeh and Alavian	2009	DG-1	Sizing+Sitting	GA	IEEE 9,33 bus system	Static	Hybrid
Borges and Falcao	2003	DG-1	Location+size+voltage+loss	OT	IEEE 9,33 bus system	Static	Hybrid
Dent et al.	2005	DG-1	Capacity+voltage	OPF	IEEE 15 bus system	Static	Hybrid
Dent et al.	2010	DG-1	Capacity	ACOPF	IEEE 9,33 bus system	Static	Hybrid
Choi	2007	DG-1	Reliability	GA	IEEE 69,9 bus system	Static	MOF
Borazan et al.	1997	DG-4	Loss	FZ	IEEE 69 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Tong and Miu	2005	DG-4	Voltage	LPF	IEEE 9 bus system	Static	Hybrid
Carvalho et al.	2008	DG-1	Voltage	LPF	IEEE 69,9 bus system	Static	Hybrid
Ullah et al.	2009	DG-1	Cost+loss	OT	IEEE 9,33 bus system	Static	Hybrid
Fahim et al.	2001	DG-1	Impact	GA	IEEE 69,9 bus system	Static	Hybrid
Borozan et al.	1995	DG-1	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Sarfi et al.	1994	DG-1	Loss	Analytical method	IEEE 9,33 bus system	Static	MOF
Peponis et al.	1996	DG-1	Cost+Size	OT	IEEE 69,9 bus system	Static	Hybrid
Sarfi et al.	1996	DG-1	Loss	GA	IEEE 69 bus system	Static	Dynamic
Harrison and Wallace	2005	DG-1	Location	OPF	IEEE 9 bus system	Static	Hybrid
Kuri et al.	2004	DG-4	Size+location	OT	IEEE 9,33 bus system	Static	Hybrid
Vovos et al.	2007	DG-1	Voltage	OT	IEEE 9,33 bus system	Static	Hybrid
McDermott et al.	1999	DG-3	Location+loss	HA	IEEE 69,9 bus system	Static	Hybrid
Murthy and Kumar	2013	DG-2	Allocation	Radial distribution	IEEE 9,33 bus system	Static	Hybrid
Lopez et al.	2002	DG-4	Loss	Dynamic programming	IEEE 9,33 bus system	Static	Hybrid
Wagner et al.	1991	DG-1	Loss	ANN	IEEE 69,37 bus system	Static	Hybrid
Alrashidi and El-Hawary	2009	DG-1	Loss	PSO	IEEE 9,33 bus system	Static	Hybrid
Del Valle et al.	2008	DG-1	Loss+voltage	PSO	IEEE 33 bus system	Static	Hybrid
Broadwater et al.	1993	DG-1	Loss+location	OT	IEEE 33,9 bus system	Static	Hybrid
Chiou et al.	2005	DG-1	Location +loss	Hybrid differential evolution	IEEE 9 bus system	Static	Hybrid
Su et al.	2005	DG-1	Loss	ABC	IEEE 9,33 bus system	Static	Hybrid
Reza and Hussain Shareef	2012	DG-1		Algorithm	IEEE 9,33 bus system	Static	Hybrid
Brian and Shin	1994	DG-2	Loss+location	HA	IEEE 9 bus system	Static	Hybrid
Niketut et al.	2011	DG-3	Loss +voltage	GA	IEEE 69,9 bus system	Static	Hybrid
Shenkman	1990	DG-4	Loss	Statistical techniques	IEEE 9,33 bus system	Static	Hybrid
Enrique et al.	2004	DG-1	Location+size	PSO	IEEE 9,33,69 bus system	Static	Hybrid
Merlin and Back	1975	DG-1	Loss	Spanning tree method	IEEE 9,33 bus system	Static	MOF
Etemadi and Fotuhi	2008	DG-1	Size+loss	OT	IEEE 9 bus system	Static	Hybrid
Ponnavaikko et al.	1987	DG-1	Location	MIPA	IEEE 9,33 bus system	Static	ANN
Hossain et al.	2011	DG-1	Placement+sizing	PSO	IEEE 9 bus system	Static	Hybrid
Coles and Beck	2001	DG-1	Cost	GSA	IEEE 9,69 bus system	Static	Hybrid
Chowdhury et al.	2003	DG-1	Location+Size	AP	IEEE 9,69 bus system	Static	Hybrid
Cebrian and Kagan	2010	DG-1	Loss+cost	GA	IEEE 9 bus system	Static	Hybrid
Walid et al.	2005	DG-1	Location	GA	IEEE 33,9 bus system	Static	Hybrid
Kuri et al.	2004	DG-1	Size+location	ABC	IEEE 33,69 bus system	Static	Hybrid
Ettehadi et al.	2013	DG-1	Cost	OT	IEEE 9 bus system	Static	Hybrid
Nara and Song	2002	DG-1	Location	HA	IEEE 37,69 bus system	Static	Hybrid
El-Khaltam et al.	2004	DG-1	Cost	OT	IEEE 37,69 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
M et al.	2011	DG-1	Size+location	ANN	IEEE 15 bus system	Static	Hybrid
Rau and Wan	1994	DG-1	Location	Undistributed planning	IEEE 9 bus system	Static	MOF
Chen et al.	1993	DG-1	Location+loss	PST	IEEE 33,69 bus system	Static	Hybrid
Hariri and Malik	1986	DG-2	Location+loss	FZ	IEEE 9,37,69 bus system	Static	Hybrid
El-Metwally et al.	1996	DG-3	Location+loss	FZ	IEEE 9,69 bus system	Static	Hybrid
Naik et al.	2013	DG-3	Loss	Model	IEEE 9 bus system	Static	Hybrid
Haque	1996	DG-4	Voltage	OPF	IEEE 69 bus system	Static	Hybrid
Mok et al.	2000	DG-1	Location	OPF	IEEE 37 bus system	Static	Hybrid
Fan et al.	1996	DG-1	Loss	OT	IEEE 9 bus system	Static	Hybrid
Abur	1996	DG-1	Location+loss	Modified linear programming	IEEE 69,9 bus system	Static	Hybrid
Das et al.	1995	DG-3	Loss+location	Dynamic programming	IEEE 37 bus system	Static	MOF
Abdel-Magid et al.	1997	DG-3	Location+loss	GA	IEEE 37,9 bus system	Realistic	Hybrid
Roger	1993	DG-1	Location+loss+cost	GA	IEEE 9,69 bus system	Static	Hybrid
Fraile and Zufiria	2005	DG-4	Loss+size	GA	IEEE 9,37,69 bus system	Static	Hybrid
Tinney and Hart	1967	DG-4	Loss	OPF + Newton's method	IEEE 9 bus system	Static	Hybrid
Stott and Alsac	1974	DG-3	Loss	FDLF	IEEE 33 bus system	Static	Hybrid
Tripathy et al.	1982	DG-2	Loss	Newton like method	IEEE 37 bus system	Static	Hybrid
Iwamoto and Tamura	1981	DG-1	Loss	OPF	IEEE 9,37 bus system	Static	Hybrid
Shirmohammadi et al.	1988	DG-1	Loss	OPF	IEEE 9,37 bus system	Static	Hybrid
Luo and Semlyen	1990	DG-1	Loss	OPF	IEEE 9,69 bus system	Static	Hybrid
Gopiya et al.	2013	DG-1	Loss	Allocation	IEEE 9,33 bus system	Static	Hybrid
Baran and Wu	1989a	DG-1	Location+size	OT	IEEE 69 bus system	Static	Hybrid
Chiang	1991	DG-1	Loss+size	DLF	IEEE 69 bus system	Static	Hybrid
Renato Cespedes	1990	DG-1	Loss+Location	OT	IEEE 33 bus system	Static	Hybrid
Roy and Hossain	2013	DG-1	Voltage	Wind generation	IEEE 15 bus system	Static	Hybrid
Borges and Falcao	2006	DG-3	Loss+voltage	OT	IEEE 9 bus system	Static	MOF
Abou El-Ela et al.	(2010)	DG-1	Cost	GA	IEEE 69,9 bus system	Static	Hybrid
Jasmon and Lee	1991	DG-1	Voltage	OPF	IEEE 37 bus system	Static	Hybrid
Liang et al.	2006	DG-3	Location+loss+cost	PSO	IEEE 9,37,69 bus system	Static	Hybrid
Soroudi et al.	2011b	DG-4	Cost+location	OT	IEEE 9 bus system	Static	Hybrid
Piccolo and Siano	2009	DG-4	Cost+size	OT	IEEE 9,37,69 bus system	Static	MOF
Salama and Chikhani	1993	DG-1	Reactive loss	LFT	IEEE 33,9 bus system	Static	Hybrid
Eminoglu and Hocaoglu	2005	DG-1	Voltage	OPF	IEEE 9,69 bus system	Static	Hybrid
Nara et al.	2001	DG-1	Location	TS	IEEE 69 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Huang et al.	2013	DG-1	Load	SVC	IEEE 9 bus system	Static	Hybrid
Vovos et al.	2005	DG-1	Size	OPF	IEEE 33 bus system	Static	Hybrid
Dommel and Tinney	1968	DG-1	Loss	OPF	IEEE 37 bus system	Static	Hybrid
Eberly and Schaefer	2002	DG-1	Voltage	OPF	IEEE 9,37 bus system	Static	Hybrid
Soroudi and Ehsan	2010	DG-1	Size+voltage	OT	IEEE 15 bus system	Static	Hybrid
Siano et al.	2009	DG-1	Cost	OT	IEEE 9,37,69 bus system	Static	MOF
Zangeneh et al.	2009	DG-4	Cost	OT	IEEE 9 bus system	Static	Hybrid
Santhikumar and Raja	2008	DG-4	Loss	PSO	IEEE 33 bus system	Static	Hybrid
Wall	2001	DG-3	Loss	OT	IEEE 69 bus system	Static	Hybrid
Chin and Huang	2000	DG-3	Loss	OT	IEEE 9,37,69 bus system	Static	Hybrid
Kim et al.	1993	DG-4	Loss	ANN	IEEE 69,9 bus system	Static	Hybrid
Guimaraes et al.	2010	DG-1	Location+loss	GA	IEEE 9 bus system	Static	Hybrid
Lavorato et al.	2012	DG-1	Location +loss	OT	IEEE 9,33,69 bus system	Static	Hybrid
Goswami and Basu	1992	DG-1	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Baran and Wu	1989b	DG-4	Loss	OT	IEEE 9 bus system	Static	Hybrid
Amany	2010	DG-1	Load	PSO	IEEE 9,33 bus system	Static	Hybrid
Kashem et al.	1999	DG-1	Load	OT	IEEE 9,37,69 bus system	Static	Hybrid
Hsiao and Chen	2001	DG-4	Loss+location+voltage	OT	IEEE 9,33 bus system	Static	Hybrid
Willis and Northcote	1985	DG-4	Loss	OT	IEEE 9 bus system	Static	Hybrid
Gonen and Ramirez-Rosado	1986	DG-4	Cost+location+size	OT	IEEE 9,33 bus system	Static	Hybrid
Jeon and Kim	2000	DG-1	Location	TS+Annealing	IEEE 9,33 bus system	Static	MOF
Lin et al.	2000	DG-1	Location	GA	IEEE 15 bus system	Static	Hybrid
Ghosh and Das	1999	DG-1	Load	OT	IEEE 9 bus system	Static	Hybrid
Bakirtzis et al.	2002	DG-1	Location	GA	IEEE 69,37 bus system	Static	Hybrid
Luan et al.	2002	DG-1	Loss+load	GA	IEEE 69 bus system	Static	Hybrid
Chang and Kuo	1994	DG-1	Location	Simulated annealing	IEEE 69,9 bus system	Static	MOF
Augugliaro et al.	1995	DG-4	Loss	Greedy approach	IEEE 9,33 bus system	Static	Hybrid
Morton and Mareels	2000	DG-2	Location	Brute-force solution	IEEE 9,33 bus system	Static	Hybrid
Yun et al.	2000	DG-2	Voltage	OT	IEEE 9 bus system	Static	Hybrid
Mutale et al.	2000	DG-3	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Carpaneto et al.	2006	DG-4	Loss+location	BC decomposition method	IEEE 9,33 bus system	Static	Hybrid
Swarup and Yamashiro	2002	DG-1	Size	GA	IEEE 37 bus system	Static	Dynamic
Hong and Ho	2005	DG-1	Location+cost+size	GA	IEEE 37 bus system	Static	Hybrid
Willis et al.	1995	DG-1	Loss	OPF	IEEE 9,33 bus system	Static	Hybrid
Boardman and Meckiff	1985	DG-1	Location	Branch method	IEEE 9 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Shaaban et al.	2013	DG-1	Power loss	OT	IEEE 69,9 bus system	Static	Hybrid
Fahad and El-Hawary	2011	DG-1	Allocation+sizing	ABC	IEEE 9,33 bus system	Static	Hybrid
Nara et al.	1994	DG-3	Size	AP	IEEE 9 bus system	Static	Hybrid
Ramírez-Rosado and Gönen	1991	DG-2	Size+cost	Pseudodynamic programming	IEEE 9,37,69 bus system	Static	Hybrid
Jóos et al.	2000	DG-3	Size	OT	IEEE 69,37 bus system	Static	Hybrid
Marei et al.	2004	DG-4	Voltage	OT	IEEE 9,37,69 bus system	Static	Hybrid
Hejazi et al.	2013	DG-4	Voltage stability	OT	IEEE 9,33 bus system	Static	Hybrid
Sedighizadeh et al.	2014	DG-1	Power loss	OT	IEEE 69,9 bus system	Static	Hybrid
Ramírez-Rosado and Bernal-Agustín	1998	DG-1	Cost+size	GA	IEEE 9,69 bus system	Static	Hybrid
Gómez et al.	2004	DG-1	Cost+location	ABC	IEEE 37,69 bus system	Static	Hybrid
Usaola	2009	DG-1	Voltage+location	LPF	IEEE 69,9 bus system	Static	Hybrid
Jabr and Pal	2009a	DG-1	Location	OPF	IEEE 9 bus system	Static	Hybrid
Ganjavi	2001	DG-1	Cost+location	OT	IEEE 9,33 bus system	Static	Hybrid
Paiva et al.	2004	DG-1	Cost	MI linear programming	IEEE 9,33 bus system	Static	Hybrid
Mithulanthan et al.	2004	DG-1	Loss	GA	IEEE 9 bus system	Static	Hybrid
Yang and Guo	2008	DG-1	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
De Oliveira	2010	DG-4	Location+loss	OT	IEEE 15 bus system	Static	Dynamic
Jain et al.	2015	DG-3	Power loss	OT	IEEE 9,33 bus system	Static	Hybrid
Singh et al.	2015a	DG-3	Loss+cost	OT	IEEE 9,33 bus system	Static	Hybrid
Costa and Matos	2015	DG-2	Loss	OT	IEEE 9,37,69 bus system	Static	Hybrid
Baran and Wu	1989a	DG-1	Loss	OPF	IEEE 9,37,69 bus system	Static	Hybrid
Jenkins et al.	2000	DG-3	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Hadjisaïd et al.	1999b	DG-1	Loss	OT	IEEE 9 bus system	Static	Hybrid
Shukla et al.	2010	DG-1	Size	Radial distribution	IEEE 9,33 bus system	Static	Hybrid
Zhang and Cheng	1997	DG-1	Size	Newton method	IEEE 9,37 bus system	Static	Hybrid
Augugliaro et al.	2001	DG-1	Size	Iterative method	IEEE 9 bus system	Static	Hybrid
Viswanadha Raju and Bijwe	2008	DG-1	Location+loss	HA	IEEE 9,33 bus system	Static	Hybrid
Khodr et al.	2009	DG-1	Location+loss	OPF	IEEE 9,66 bus system	Static	Hybrid
Kim and Hwang	2001	DG-1	Size	Analytical method	IEEE 9,33 bus system	Static	Hybrid
Usta and Redfem	2001	DG-1	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
De Macêdo Braz and Alencar de Souza	2011	DG-3	Location+cost+loss	GA	IEEE 15 bus system	Static	Hybrid
Kuersuk and Ongsakul	2006	DG-2	Location	PSO	IEEE 9,33,69 bus system	Static	Hybrid
Xu and Gergis	2001	DG-1	Load	AP	IEEE 9,33 bus system	Static	Hybrid
Edwards et al.	2000	DG-1	Location	AP	IEEE 33,69 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Girgis and Brahma	2000	DG-4	Loss+fault	OT	IEEE 9 bus system	Static	Hybrid
Doyle	2002	DG-1	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Brown	2002	DG-1	Loss	OT	IEEE 9,37,69 bus system	Static	Hybrid
Barker and De Mello	2000	DG-1	Impact	Radial distribution	IEEE 9,33 bus system	Static	Hybrid
Kersting	1991	DG-4	Loss	OT	IEEE 9,33,69 bus system	Static	MOF
Ciric et al.	2003	DG-1	Loss	General approach	IEEE 9,37 bus system	Static	Hybrid
Zhu and Tomsovic	2002	DG-1	Location	AFP	IEEE 9,33 bus system	Static	MOF
Meliopoulos et al.	1990	DG-4	Loss	PPFA	IEEE 9,37,69 bus system	Static	Hybrid
Hadjisaid et al.	1999a	DG-1	Impact	Dispersed generation	IEEE 9,33 bus system	Static	Hybrid
Walid et al.	2006	DG-1	Loss	Monte carlo method	IEEE 9 bus system	Static	Hybrid
Lopes	2002	DG-1	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Celli and Pilo	2001a	DG-1	Location	GA	IEEE 69 bus system	Static	Hybrid
Kersting	2003	DG-4	Loss	OLF	IEEE 9,33 bus system	Static	Hybrid
Gupta et al.	2010	DG-4	Location+loss+cost	GA+ FZ	IEEE 9,37,69 bus system	Static	Hybrid
Chiang and Jean-Jumeau	1990a	DG-4	Location	Numerical analysis	IEEE 9,33 bus system	Static	Hybrid
Ochoa et al.	2006	DG-1	Loss+location	Index method	IEEE 69 bus system	Static	Hybrid
Brahma and Girgis	2004	DG-1	Location+fault	ANN	IEEE 37,69 bus system	Static	Hybrid
Ochoa et al.	2006	DG-1	Impact	multiobjective index	IEEE 9,33 bus system	Static	Hybrid
Abbey and Joós	2005	DG-1	Voltage	OT	IEEE 9 bus system	Static	Hybrid
Wenger et al.	1994	DG-3	Size	OT	IEEE 9,33 bus system	Static	Hybrid
Yiming and Miu	2003	DG-3	Reliability	Radial distribution	IEEE 33 bus system	Static	Hybrid
Kersting	1991	DG-3	Location+loss	Analytical method	IEEE 9,33 bus system	Static	Hybrid
Hugo and Geza	2006	DG-1	Cost	Quantification method	IEEE 9,33 bus system	Static	Hybrid
Kashem et al.	2000a	DG-1	Voltage	OT	IEEE 9,37 bus system	Static	Hybrid
Gomes et al.	2005	DG-1	Loss	HA	IEEE 9,66 bus system	Static	Hybrid
Zhu et al.	2006	DG-1	Location	OT	IEEE 9 bus system	Static	Hybrid
Warren et al.	2006	DG-1	Fault	OT	IEEE 15 bus system	Static	Hybrid
Singh et al.	2011	DG-2	Reliability	PSO + FZ	IEEE 37,69 bus system	Static	MOF
Kim et al.	2002	DG-2	Location	FZ+GA	IEEE 9,37,69 bus system	Static	Hybrid
Carpinelli et al.	2001	DG-2	Size+location	GA	IEEE 37,69 bus system	Static	Hybrid
Huang	2001	DG-1	Location+load	ABC	IEEE 9,37,69 bus system	Static	Hybrid
Salvatore et al.	2007	DG-1	Location +cost	ABC	IEEE 69 bus system	Static	Hybrid
Kotamarty et al.	2008	DG-1	Impact	Contingency analysis	IEEE 15 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Kim et al.	2002	DG-1	Location	FZ+GA	IEEE 37,69 bus system	Static	Hybrid
Wang and Nehrir	2002	DG-1	Location	AP	IEEE 9,33 bus system	Static	Hybrid
Gómez et al.	2004	DG-1	Loss	ABC	IEEE 9,37,69 bus system	Static	Hybrid
Concordia and Ihara	1982	DG-1	Stability	ABC	IEEE 9,33 bus system	Static	Hybrid
Philipson	2000	DG-1	Cost	OT	IEEE 9,39 bus system	Static	Hybrid
Carpinelli et al.	2001	DG-3	Location+size	ABC	IEEE 9,37 bus system	Static	Hybrid
Hsiao and Chien	2001	DG-2	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Vovos et al.	2007	DG-2	Voltage	Hybrid	IEEE 9,37,69 bus system	Static	Hybrid
Bala et al.	1997	DG-1	Loss	Analyzer recorder	IEEE 33,9 bus system	Static	Hybrid
Acharya et al.	2006	DG-1	Location	AP	IEEE 9,33 bus system	Static	Hybrid
Hobbs and Meier	1994	DG-4	Loss+location	OT	IEEE 9,37,69 bus system	Static	MOF
El-Hawary	1998	DG-1	Loss	FZ	IEEE 9 bus system	Static	Hybrid
Carrano et al.	2006	DG-1	Location+loss+cost	GA	IEEE 9,33 bus system	Static	Hybrid
Ramírez-Rosado and Bernal-Agustín	1998	DG-1	Location	GA	IEEE 9,33 bus system	Static	Hybrid
Teng et al.	2002	DG-1	Location	AP	IEEE 15 bus system	Static	Hybrid
Broadwater et al.	1994	DG-1	Fault	AP	IEEE 9,37,69 bus system	Static	MOF
Soroudi et al.	2011a	DG-3	Impact	GA	IEEE 9,33 bus system	Static	Hybrid
Pregelj et al.	2018	DG-1	Location	GA	IEEE 37,69 bus system	Static	Hybrid
Srinivas and Patnaik	1994	DG-4	Cost	GA	IEEE 9,69 bus system	Static	Hybrid
Wu et al.	2010	DG-1	Location +loss	OT	IEEE 9,33 bus system	Static	Hybrid
Carreno et al.	2008	DG-1	Loss	OT	IEEE 9,37,69 bus system	Static	MOF
Pregelj et al.	2006	DG-1	Location	OT	IEEE 9,33 bus system	Static	Hybrid
Parada et al.	2004	DG-3	Location	SA	IEEE 9 bus system	Static	Hybrid
Eduardo et al.	2007	DG-2	Size	Immune system algorithm	IEEE 9,33 bus system	Static	Hybrid
Teng and Liu	2003	DG-1	Location	ABC	IEEE 9,33 bus system	Static	Hybrid
Vlachogiannis et al.	2005	DG-1	Load	ABC	IEEE 9,39 bus system	Static	Hybrid
Merlin and Back	1975	DG-4	Loss	Spanning tree	IEEE 15 bus system	Static	Hybrid
Lee and El-Sharkawi	2002	DG-1	Loss	HA	IEEE 9,37,69 bus system	Static	Hybrid
Dorigo and Gambardella	1997	DG-3	Cost	ABC	IEEE 9,33 bus system	Static	Hybrid
Grenard and Strbac	2003	DG-1	Cost	OT	IEEE 9,39 bus system	Static	Hybrid
Heffner et al.	1998	DG-4	Cost	OT	IEEE 9,39 bus system	Static	Hybrid
Carrano et al.	2005	DG-1	Location	GA+BFGS	IEEE 9,39 bus system	Static	Hybrid
Miranda et al.	1994	DG-1	Location+cost	GA	IEEE 37 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Rizy et al.	1989	DG-1	Voltage	OT	IEEE 9,37,69 bus system	Static	Hybrid
Singh et al.	2007a	DG-1	Voltage+location	AP	IEEE 9,33 bus system	Static	Hybrid
Carvalho et al.	1998	DG-4	Size	Evolutionary convergence method	IEEE 9 bus system	Static	Hybrid
Willis et al.	1996	DG-3	Location	AP	IEEE 9,39 bus system	Static	Hybrid
Singh et al.	2009b	DG-1	Location+cost	AP	IEEE 9,37,69 bus system	Static	Dynamic
Ackermann et al.	2001	DG-2	Location	AP	IEEE 15 bus system	Static	Hybrid
Keane and O'Malley	2005	DG-1	Allocation	ANN	IEEE 9,39 bus system	Static	Hybrid
Goméz et al.	2004	DG-1	Location	ABC	IEEE 9,37,69 bus system	Static	Hybrid
Duan and Yu	2003	DG-1	Cost	OT	IEEE 9,39 bus system	Static	Hybrid
Salazar et al.	2006	DG-1	Loss	ANN	IEEE 9,37,69 bus system	Static	Hybrid
Song et al.	1997	DG-1	Loss	FZ	IEEE 9,33 bus system	Static	Hybrid
Shin et al.	2007	DG-3	Location	Optimal routing algorithm	IEEE 9,39 bus system	Static	Hybrid
Daly and Morrison	2001	DG-1	Cost	OT	IEEE 9,39 bus system	Static	Hybrid
Osborn	2004	DG-1	Cost	OT	IEEE 9,33 bus system	Static	Hybrid
EI-Khattam and Salama	2004	DG-3	Definitions	FZ	IEEE 9,37,69 bus system	Static	Hybrid
Lind and Karlsson	1996	DG-1	Voltage	OT	IEEE 9 bus system	Static	Hybrid
Venkatesh et al.	2000	DG-1	Loss+voltage	FZ	IEEE 9,33 bus system	Static	Hybrid
Jeon et al.	2002	DG-1	Size	SA	IEEE 9,37,69 bus system	Static	Hybrid
Joos et al.	2000	DG-3	Size	OT	IEEE 9,39 bus system	Static	Hybrid
Joos	2008	DG-3	Cost	Quantification method	IEEE 9,37 bus system	Static	Hybrid
Dobson and Lu	1992a	DG-1	Voltage	Bifurcation	IEEE 15 bus system	Static	Hybrid
Hasan et al.	2008	DG-1	Location	AP	IEEE 9 bus system	Static	Hybrid
Carpinelli et al.	2005	DG-3	Location+size	Double trade off method	IEEE 9,33 bus system	Static	Hybrid
Burke et al.	1988	DG-1	Location	Trade off method	IEEE 9,39 bus system	Static	Hybrid
Méndez et al.	2006	DG-1	Loss	OT	IEEE 15 bus system	Static	Hybrid
Ochoa et al.	2008b	DG-1	Location+cost	AP	IEEE 9, 39 bus system	Time varying	Hybrid
Hegazy et al.	2003	DG-2	Adequacy	Monte Carlo simulation	IEEE9,37 bus system	Static	Hybrid
Kataoka	2003	DG-1	Voltage	Probabilistic nodal method	IEEE 9,37,69 bus system	Static	Hybrid
Dobson and Lu	1992b	DG-3	Voltage	OT	IEEE 9,33 bus system	Static	Hybrid
Augugliaro et al.	1999	DG-4	Loss+location	GSA+TS	IEEE 9,39 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Zhu et al.	2006	DG-1	Location	AP	IEEE 9,39,69 bus system	Time varying	Hybrid
El-Khattam et al.	2005	DG-1		OT	IEEE 9 bus system	Static	Hybrid
Celli et al.	2005	DG-4	Location+size	Evolutionary algorithm	IEEE 9,37,69 bus system	Static	Hybrid
Ahuja et al.	2007	DG-1	Cost+size	Hybrid approach	IEEE 9,33 bus system	Static	Hybrid
Donnelly et al.	1996	DG-1	Stability	OT	IEEE 9,37,69 bus system	Static	Hybrid
Reza et al.	2003	DG-1	Stability	OT	IEEE 9,39 bus system	Static	Dynamic
Cañizares	1998b	DG-1	Voltage	Bifurcation method	IEEE 9,39,67 bus system	Static	Hybrid
Chiang et al.	1995	DG-1	Stability	OPF	IEEE 9,39 bus system	Static	Hybrid
Rau and Wan	1994	DG-1	Location	OPF	IEEE 9,33 bus system	Static	Hybrid
Griffin et al.	2000b	DG-1	Loss	ABC	IEEE 9,39 bus system	Static	Hybrid
Celli and Pilo	2001b	DG-4	Location	AP	IEEE 9,37,69 bus system	Static	Hybrid
Sim and Sun	2003	DG-1	Size	ABC	IEEE 15 bus system	Static	MOF
Kim et al.	1998	DG-3	Planning	Algorithm	IEEE 9,39 bus system	Static	Hybrid
Cañizares	1998a	DG-1	Voltage	OT	IEEE 9 bus system	Static	Hybrid
Masters	2002	DG-2	Voltage	AP	IEEE 9,37,69 bus system	Static	Hybrid
Walling et al.	2008	DG-1	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Löf et al.	1995	DG-4	Voltage	OT	IEEE 9,39 bus system	Static	Hybrid
Cañizares and Alvarado	1993	DG-1	Voltage	OT	IEEE 9,39,69 bus system	Static	Hybrid
Baran and El-Markabi	2007	DG-1	Voltage	Multiagent based technique	IEEE 9,33 bus system	Static	Hybrid
Carrano et al.	2006	DG-2	Location+loss	GA	IEEE 15 bus system	Static	Hybrid
Celli et al.	2005	DG-1	Location +size	MOEA	IEEE 9,37,69 bus system	Static	Hybrid
Greene et al.	1996	DG-1	Voltage	OT	IEEE 9 bus system	Static	Hybrid
Van	1991	DG-1	Voltage	LPF	IEEE 9,37 bus system	Static	Hybrid
Ramfrez-Rosado and Bernal-Agustin	1998	DG-2	Power	GA	IEEE 9,33 bus system	Static	Hybrid
Blum and Dorigo	2004	DG-4	Location	ABC	IEEE 9 bus system	Static	Hybrid
Kuo and Wan	2007	DG-1	Location	AP	IEEE 9,39 bus system	Static	Hybrid
Bhowmik et al.	2003	DG-1	Penetration	Model	IEEE 9,39 bus system	Static	Hybrid
Chiou et al.	2004	DG-1	Location	Hybrid algorithm	IEEE 9,33 bus system	Static	Hybrid
Mendoza et al.	2007	DG-3	Voltage	GA	IEEE 15 bus system	Static	Hybrid
Singh et al.	2007	DG-1	Size	OT	IEEE 9 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Ochoa et al.	2006	DG-1	Impacts	Multi objective Index	IEEE 9,69 bus system	Static	Hybrid
Singh et al.	2009b	DG-1	Location	OT	IEEE 9,33 bus system	Static	Hybrid
Mutale et al.	2000	DG-1	Loss	OT	IEEE 9 bus system	Static	Hybrid
Haesen et al.	2005	DG-1	Location +size	GA	IEEE 9,37,69 bus system	Static	Hybrid
Kim et al.	2008	DG-1	Location	FZ+GA	IEEE 15 bus system	Static	Hybrid
Gao et al.	2001	DG-3	Stability+Voltage	GA	IEEE 9 bus system	Static	MOF
Kim et al.	1998	DG-4	Location	HRA	IEEE 9,39 bus system	Static	Hybrid
Hetzer et al.	2008	DG-3	Cost	OT	IEEE 9,33 bus system	Static	MOF
Shim et al.	2005	DG-2	Cost + location	OT	IEEE 9,37,69 bus system	Static	Hybrid
Cheng and Kou	1994	DG-1	Location	SA	IEEE 9,39 bus system	Static	Hybrid
Prasad et al.	2005	DG-1	Location	GA	IEEE 9,37,69 bus system	Static	Hybrid
Chiradeja and Ramakumar	2004	DG-1	Benefits	GA	IEEE 9,37,69 bus system	Static	Hybrid
Das et al.	1994	DG-2	Location	OT	IEEE 9 bus system	Static	Hybrid
Chis et al.	1997	DG-2	Location	HA	IEEE 9,37,69 bus system	Static	Hybrid
Vitorino et al.	2000	DG-1	Loss	OT	IEEE 15 bus system	Static	Hybrid
Chandramohana et al.	2010	DG-3	Cost	GA	IEEE 9,33 bus system	Static	Hybrid
Gomes et al.	2006	DG-1	Loss	OPF	IEEE 9,37,69 bus system	Static	Hybrid
Liu et al.	1988	DG-1	Loss	OT	IEEE 9 bus system	Static	Hybrid
Quetzada et al.	2006	DG-1	Loss	GA	IEEE 37 bus system	Static	Hybrid
Nag et al.	2000	DG-4	Location	OT	IEEE 9 bus system	Static	Hybrid
Le et al.	2007	DG-1	Loss+cost	OT	IEEE 37,69 bus system	Static	Dynamic
Le et al.	2005	DG-1	Voltage	OT	IEEE 15 bus system	Static	Hybrid
Wang and Nehrir	2004	DG-1	Power	AP	IEEE 9,37,69 bus system	Static	Hybrid
Gözel and Hocaoglu	2009	DG-1	Location+size	AP	IEEE 9 bus system	Static	Hybrid
Vasebi et al.	2007	DG-1	Loss+cost	HA	IEEE 9,33 bus system	Static	Hybrid
Teng	2003	DG-1	Location+loss	LFT	IEEE 9,37,69 bus system	Static	Hybrid
Acharya et al.	2006	DG-4	Allocation	AP	IEEE 9 bus system	Static	Hybrid
Harrison et al.	2008	DG-3	Size	GA+OPF	IEEE 9,69 bus system	Static	Hybrid
Nagendra Rao and Ravishankar Deekshit	2006	DG-2	Loss	OT	IEEE 9,37 bus system	Static	Hybrid
Thomson	2007	DG-4	Loss	OPF	IEEE 9,37,69 bus system	Static	Hybrid
Dent et al.	2010	DG-1	Capacity	OPF	IEEE 15 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Borges and Falcao	2006	DG-1	Cost+location+voltage	OT	IEEE 9,33 bus system	Static	Hybrid
Jabr and Pal	2009b	DG-1	Location+size	OT	IEEE 15 bus system	Static	Hybrid
Popovic et al.	2005	DG-1	Location	OT	IEEE 9,37 bus system	Static	Hybrid
Vovos et al.	2005	DG-1	Fault	OPF	IEEE 9,37,69 bus system	Static	Hybrid
Ayed et al.	2009	DG-1	Loss	Model	IEEE 9 bus system	Static	Hybrid
Barker and De Mello	2000	DG-1	Loss	OT	IEEE 9,39 bus system	Static	Hybrid
Moradi and Abedini	2012	DG-4	Size+location	GA+PSO	IEEE 9,37,69 bus system	Static	Hybrid
Shirmohammadi et al.	1988	DG-1	Loss	OPF	IEEE 9,33 bus system	Static	Hybrid
Ochoa et al.	2010	DG-1	Capacity	Model	IEEE 9 bus system	Static	Hybrid
Soroudi and Ehsan	2011	DG-3	Loss	OT	IEEE 9,37,69 bus system	Static	Hybrid
Wang and Hsshem	2004	DG-3	Location	AP	IEEE 9,69 bus system	Static	Hybrid
Ochoa et al.	2008d	DG-2	Capacity	OT	IEEE 9,37 bus system	Static	Hybrid
Karki and Billinton	2004	DG-2	Cost	OT	IEEE 15 bus system	Static	Hybrid
Salameh et al.	1995	DG-1	Capacity	OT	IEEE 9 bus system	Static	Hybrid
Keane and O'Malley	2007	DG-1	Loss	OT	IEEE 9,33 bus system	Static	Hybrid
Keane and O'Malley	2006	DG-4	Power loss	OPF	IEEE 9,37,69 bus system	Static	Hybrid
Su	2010	DG-1	Voltage	Detailed distribution models	IEEE 9,37,69 bus system	Static	Hybrid
Delbem et al.	2005	DG-1	Loss	Evolutionary algorithm	IEEE 9,69 bus system	Static	Hybrid
Greatbanks et al.	2003	DG-1	Security and capacity	OT	IEEE 9 bus system	Static	Hybrid
Liang and Wang	2003	DG-1	Power +voltage	FZ	IEEE 9,33 bus system	Static	MOF
El-Khattam et al.	2004	DG-1	Cost	OT	IEEE 9 bus system	Static	Hybrid
Moshtagh et al.	2010	DG-4	Size+location	PSO	IEEE 9,39 bus system	Static	Hybrid
Khalesi et al.	2011	DG-1	Location+loss	Dynamic programming	IEEE 9,37,69 bus system	Static	Hybrid
Popovic et al.	2005b	DG-4	Security + Reliability	OT	IEEE 9,33 bus system	Static	Hybrid
Borges and Falcao	2006	DG-3	Voltage+ Losses+Location	OT	IEEE 9 bus system	Static	Hybrid
Liu et al.	2009	DG-1	Power +voltage	Switching operations	IEEE 9 bus system	Static	Hybrid
Boehme et al.	2007	DG-1	Load	OPF	IEEE 9,37,69 bus system	Static	Hybrid
Boehme et al.	2010	DG-1	Size	OT	IEEE 9,37,69 bus system	Static	Hybrid
Teng et al.	2007	DG-3	Reliability + cost	OT	IEEE 9,33 bus system	Static	Hybrid
Keane et al.	2011	DG-3	Voltage	PSO	IEEE9,37,69 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Park and Lee	2005	DG-1	Cost	PSO	IEEE 9,33 bus system	Static	MOF
Selvakumar and Thanushkodi	2007	DG-1	Cost	PSO	IEEE 9,37,69 bus system	Static	Hybrid
Su and Lee	2001	DG-1	Loss	OT	IEEE 9 bus system	Static	Hybrid
Chang	2008	DG-1	Loss	ABC	IEEE 9,37,69 bus system	Static	Hybrid
Carvalho et al.	2008	DG-1	Power +voltage	ABC	IEEE 9,33 bus system	Static	MOF
Haghifam et al.	2008	DG-1	Location	AP	IEEE 9,37,69 bus system	Static	Hybrid
Lee and Park	2009	DG-1	Location +size	Kalman filter algorithm	IEEE 9,37,69 bus system	Static	Hybrid
Abu-Mouti and El-Hawary	2007	DG-3	Loss	OPF	IEEE 9,33 bus system	Static	Hybrid
Basturk and Karaboga	2006	DG-3	Loss+cost	ABC	IEEE 9 bus system	Static	Hybrid
Mekhamer et al.	2002	DG-3	Loss	FZ+HA	IEEE 9,33 bus system	Static	Hybrid
Shukla et al.	2010	DG-1	Size	AP	IEEE 9,37,69 bus system	Static	Hybrid
Roy et al.	2010	DG-4	Impact	Wind generation	IEEE 9 bus system	Static	Hybrid
Sundhararajan and Pahwa	1994	DG-4	Loss	GA	IEEE 9,37,69 bus system	Static	Hybrid
Gallego et al.	2001	DG-1	Loss+location	OT	IEEE 15 bus system	Static	Hybrid
Akorede et al.	2011	DG-1	Location	OT	IEEE 9,33 bus system	Static	Hybrid
Zong	2009	DG-3	Location+loss	HA	IEEE 9 bus system	Static	Hybrid
Gonzlez-Longatt	2007	DG-1	Impact +loss	ABC	IEEE 9 bus system	Static	Hybrid
Wang and Singh	2008	DG-1	Location	ABC	IEEE 39 bus system	Static	Hybrid
Dan et al.	2006	DG-4	Reliability + Efficiency	Time-Varying Loads	IEEE 69 bus system	Static	Hybrid
Gözel and Hocaoglu	2009	DG-1	Size+location	OT	IEEE 9 bus system	Static	Hybrid
Ghosh et al.	2010	DG-4	Size+location	OT	IEEE 13 bus system	Static	Hybrid
Naresh et al.	2006	DG-1	Allocation	AP	IEEE 9 bus system	Static	Hybrid
Alarcon-Rodriguez et al.	2009	DG-1	Loss+cost	OT	IEEE 69 bus system	Static	Hybrid
Hamedи and Gandomkar	2012	DG-1	Location+loss	OT	IEEE 39 bus system	Static	Hybrid
Mendoza et al.	2009	DG-1	Loss+location+size	MMR Algorithm	IEEE 13 bus system	Static	MOF
Soo-Hyoun and Jung-Wook	2009	DG-1	Location +size	Kalman Filter Algorithm	IEEE 9 bus system	Static	Hybrid
Mardaneh and Gharehpetian	2004	DG-1	Location+size	GA+OPF	IEEE 9 bus system	Static	Hybrid
Senjuu et al.	2008	DG-1	Voltage	ABC	IEEE 13 bus system	Static	Hybrid
Zhang et al.	2008	DG-4	Loss	OT	IEEE 69 bus system	Static	Hybrid
Karaboga and Basturk	2007	DG-3	Location	ABC	IEEE 69 bus system	Static	Hybrid
Rao et al.	2008	DG-2	Loss	ABC	IEEE 13 bus system	Static	Hybrid
Keane et al.	2009	DG-1	Cost+location	OT	IEEE 39 bus system	Static	Hybrid
Jabr and Pal	2009b	DG-1	Location +sizing	Ordinal Model	IEEE 13 bus system	Static	Hybrid
Tuitemwong and Premrudeepreechacharn	2011	DG-4	Protection	OT	IEEE 9 bus system	Static	Hybrid

(continued on next page)

Table 3.1 (continued)

Author	Year	Different types of DGs	Objective function	Algorithms	Test system	Different types of load model	Future work
Harrison and Wallace	2005	DG-1	Capacity	GA	IEEE 69 bus system	Static	MOF
Keane and O'Malley	2005	DG-3	Allocation	Model	IEEE 13 bus system	Static	Hybrid
Acharya et al.	2006	DG-2	Allocation	AP	IEEE 69 bus system	Static	Dynamic
Kejun et al.	2011	DG-2	Allocation	GA	IEEE 38 bus system	Static	Hybrid
Payasi et al.	2013	DG-2	Voltage	GA	IEEE 38 bus system	Static	Hybrid
Singh et al.	2007b	DG-2	Loss+Voltage	GA	IEEE 38 bus system	Static	Hybrid
Singh et al.	2009c	DG-2	Loss+Voltage	GA	IEEE 38 bus system	Static	Hybrid
IEEE Task Force	1993	DG-2	Loss+Voltage	GA	IEEE 38 bus system	Static	Hybrid
Tiwari and Ghatak	2017	DG-2	Loss+Sizing	GA+DSTATCOM	IEEE 37 bus system	Static	Hybrid
Mishra and Singh	2017	DG-2	Loss+Sizing+Voltage	GA	IEEE 37 bus system	Static	Hybrid
Mahdi et al.	2016	DG-4	Loss+Sizing	PSO	IEEE -39 bus system	Static	Hybrid
Raju et al.	2016	DG-1	Loss+Sizing	Tabu Search Algorithms	IEEE -39 bus system	Static	Hybrid
Rajendran and Narayanan	2017	DG-3	Loss+Sizing+Voltage	Ant Bees Colony	IEEE 9 bus system	Static	Hybrid
Srivastava et al.	2016	DG-1	Loss+Sizing	PSO+GSA	IEEE 37 bus system	Static	Multi-task
Avyappa and Gaonkar	2016	DG-4	Loss+Voltage	GA	IEEE 9 bus system	Static	Multi-task
Singh et al.	2015b	DG-2	Loss+Sizing+Voltage	GA	IEEE 37 bus system	Static	Multi-task
Singh and Parida	2015	DG-2	Loss+Sizing+Voltage	PSO	IEEE -39 bus system	Static	Multi-task
Lu et al.	2018	DG-3	Loss+Sizing	ST	IEEE -37 bus system	Static	Multi-task
Herlambang et al.	2018	DG-2	Loss+Sizing+Voltage	GA	IEEE 9 bus system	Static	Hybrid

Table 4.1

The different conventional methods are reviewed in literatures for impact assessment of optimally placed DGs.

Conventional methods	No. of literatures reviewed out of 81	% of literatures reviewed out of 81
Eigenvalues method	4	2.9%
Modal method	38	27.94%
Added model method	26	19.11%
Index method	13	9.5%
OPF	28	20.5%
PST	5	3.68%
Monte-carlo method	3	2.21%
Tradeoff method	5	3.68%
LPF	11	8.09%
Newton-Raphson	3	2.21%

Table 4.2

The different Artificial intelligence techniques are reviewed in literatures for impact assessment of optimally placed DGs.

Artificial intelligence techniques	No. of literatures reviewed out of 188	% of literatures reviewed out of 188
Genetic algorithms	72	38.64
Artificial neural network	9	5.05
Fuzzy logic	9	5.05
Particle swarm optimization	20	10.64
Ant bees colony	29	16.29
Gravitational search algorithms	2	0.56
tabu search	2	1.12
Simulated annealing	4	2.24
Heuristic algorithms	15	8.42
Kalman filter algorithms	3	1.68
Two stage planning algorithms	1	0.56
MMR algorithms	1	0.56
Evolutionary algorithms	2	1.12
Optimal algorithms	1	0.56
Immune system algorithms	1	0.56
Henceforced algorithms	2	1.12
Other	15	8.42

Table 4.3

The different optimization methods are reviewed in literatures for impact assessment of optimally placed DGs.

Optimization methods	No. of literatures reviewed out of 178	% of literatures reviewed out of 178
Dynamic programming method	36	20.22%
Linear programming method	20	11.23%
Non-Linear programming method	62	34.83%
Mixed integer non-linear programming method	44	24.71%
Dual programming method	5	2.80%
Other programming method	11	6.17%

Table 4.4

The different hybrid intelligence techniques are reviewed in literatures for impact assessment of optimally placed DGs.

Artificial intelligence techniques	No. of literatures reviewed out of 18	% of literatures reviewed out of 18
FZ + GA	6	35.29%
PSO + Model	1	5.88%
OPF + Newton method	1	5.88%
TS + SA	1	5.88%
PSO + FZ	2	11.76%
GA + BFGS	1	5.88%
GSA + TS	1	5.88%
GA + OPF	2	11.76%
GA + PSO	2	11.76%
FZ + HA	1	5.88%

Table 4.5

The different other techniques are reviewed in literatures for impact assessment of optimally placed DGs.

Other techniques	No. of literatures reviewed out of 4	% of literatures reviewed out of 4
Wind generation	2	50%
Industrial Planning	1	25%
Switching operation	1	25%

5. Conclusions and future scope

5.1. Conclusions of papers

The following conclusions from this survey article A survey on enhancement of power system performances by optimally placed DG in distribution networks as follows:

- Improve power system security.
- Reduction of power system oscillation.
- Improve power system reliability.
- Improve the available power transfer capability capacity of system.
- System power factor Improvement.
- Bandwidth of operation increase.
- Enhancement of system voltage profile.
- Enhancement the loadability of system.
- Reduce the SSR problems.
- Improve power system stability.
- Reduction of real and reactive power losses of the system.

5.2. Future scope of paper

The future scopes of this work are as follows:

- Two or more DG can be used in hybrid manner to improve the power system performances.
- In future the type of DG such as DG-1, DG-2, DG-3 and DG-4 can be used for reactive power supporter in power distribution system for enhancement of voltage profile.
- The different type of Artificial intelligence technique such as PSO, Tabu search, search algorithm, Ant bees colony algorithm, Simulated annealing algorithm etc. can be use in future for the optimal placement of DG in distribution power system for enhancement of power system performances.
- Hybrid artificial intelligence technique such as combination of FZ + GA, PSO + Model, OPF + Newton method, TS + SA, PSO + FZ, GA + BFGS, GSA + TS, GA + OPF, GA + PSO, FZ + HA etc. can be use for the optimal placement of DG in distribution power system for enhancement of power system performances.
- Overall cost of per unit electricity is reduced due to minimization of real and reactive power loss of the system by using DGs.
- Practical implementations of these things are possible for benefits of society.

References

- Abbey, C., Joós, G., 2005. Effect of low voltage ride through (LVRT) Characteristic on voltage stability. In: Proc. IEEE PES General Meeting, San Francisco, CA, pp. 12–16.
- Abdel-Magid, Y.L., Bettayeb, M., Dawoud, M.M., 1997. Simultaneous stabilisation of power systems using genetic algorithms. IEE Proc.-Gener. Transm. Distrib. 144 (1), 39–44.
- Abou El-Ela, A.A., Allam, S.M., Shatla, M.M., 2010. Maximal optimal benefits of distributed generation using genetic algorithms. Electr. Power Syst. Res. 80, 869–877.
- Abu-Mouti, F.S., El-Hawary, M.E., 2007. A new and fast power flow solution algorithm for radial distribution feeders including distributed generations. Proc. IEEE Int. Conf. Syst. Man, Cybern. 2668–2673.
- Abur, A., 1996. A modified linear programming method for distribution system reconfiguration. Int. J. Electr. Power Energ. Syst. 18, 469–474.
- Acharya, N., Mahat, P., Mithulanthan, N., 2006. An analytical approach for DG allocation in primary distribution network. Int. J. Electr. Power Energy Syst. 28 (10), 669–678.
- Ackermann, T., Andersson, G., Soder, L., 2000. Electricity market regulations and their impact on distributed generation. In: Proc. Int. Conf. Elect. Utility Deregulation Restructuring Power Technology London, U.K, pp. 608–613.
- Ackermann, T., Anderson, G., Söder, L., 2001. Distributed generation: a definition. Electr. Power Syst. Res. 57, 195–204.
- Ahuja, A., Das, S., Pahwa, A., 2007. An AIS-ACO hybrid approach for multiobjective distribution system reconfiguration. IEEE Trans. Power Syst. 22 (3), 1101–1111.
- Akorede, M.F., Hizam, H., Aris, I., Ab Kadir, M.Z.A., 2010. A review of strategies for optimal placement of distributed generation in power distribution systems. Res. J. Appl. Sci. 5 (2), 137–145.
- Akorede, M.F., Hizam, H., Aris, I., Kadir, M.Z.A., 2011. Effective method for optimal allocation of distributed generation units in meshed electric power systems. IET Gene. Trans. Dist. 5 (2), 276–287.
- Alarcon-Rodriguez, A., Haesen, E., Ault, G.W., Driesen, J., Belmans, R., 2009. Multi-objective planning framework for stochastic and controllable distributed energy resources. IET Renew. Power Gen. 3 (2), 227–238.
- Alrashidi, M.R., El-Hawary, M.E., 2009. A survey of particle swarm optimization applications in electric power systems. IEEE Trans. Evol. Comput. 13 (4), 913–918.
- Amanifar, O., Golshan, M.E., 2011. Optimal distributed generation placement and sizing for loss and THD reduction and voltage profile improvement in distribution systems using particle swarm optimization and sensitivity analysis. Int. J. Tech. Phys. Probl. Eng. 3 (2), 47–53.
- Amany, M. EL-Zonkoly, 2010. Optimal placement of multi DG units including different load models using PSO. Sci. Res. Smart Grid Renew. Energy Syst. 160–171.
- Augugliaro, A., Dusonchet, L., Favuzza, S., Sanseverino, S.R., 2004. Voltage regulation and power losses minimization in automated distribution networks by an evolutionary multiobjective approach. IEEE Trans. Power Syst. 19 (3), 1516–1527.
- Augugliaro, A., Dusonchet, L., Ippolito, M.G., Sanseverino, E.R., 2001. An efficient iterative method for load-flow solution in radial distribution networks. In: Proc. IEEE Porto Power Tech Conf. Porto, Portugal.
- Augugliaro, A., Dusonchet, L., Mangione, S., 1995. An efficient greedy approach for minimum loss reconfiguration of distribution networks. Electr. Power Syst. Res. 35, 167–176.
- Augugliaro, A., Dusonchet, L., Riva Sanseverino, E.R., 1999. Genetic simulated annealing and tabu search algorithms: Three heuristic methods for optimal reconfiguration and compensation of distribution networks. Eur. Trans. Electr. Power. 9 (1), 35–41.
- Ault, G.W., Foote, C.T.E., McDonald, J.R., 2002. Distribution system planning in focus. IEEE Power Eng. Rev. 22, 60–62.
- Ault, G.W., McDonald, J.R., 2000. Planning for distributed generation within distribution networks in restructured electricity markets. IEEE Power Eng. Rev. 20, 52–54.
- Ault, G.W., McDonald, J.R., Burt, G.M., 2003. Strategic analysis framework for evaluating distributed generation and utility strategies. Proc. Inst. Elect. Engg. Gener. Transm. Distrib. 150, 475–481.
- Ayappa, S.K., Gaonkar, D.N., 2016. Performance analysis of a variable-speed wind and fuel cell-based hybrid distributed generation system in grid-connected mode of operation. J. Electr. Power Compon. Syst. 44 (2), 506–517.
- Ayed, A., Algarni, S., Bhattacharya, K., 2009. Disco operation considering DG units and their goodness factors. IEEE Trans. Power Syst. 24 (4).
- Bakirtzis, A.G., Biskas, P.N., Zoumas, C.E., Petridis, V., 2002. Optimal power flow by enhanced genetic algorithm. IEEE Trans. Power Syst. 17 (2), 229–236.
- Bala, J.L., Kuntz, P.A., Pebbles, M.N., 1997. Optimum capacitor allocation using a distribution-analyzer-recorder. IEEE Trans PWRD. 12 (1), 464–469.
- Baran, M.E., El-Markabi, I.M., 2007. A multiagent-based dispatching scheme for distributed generators for voltage support on distribution feeders. IEEE Trans. Power Syst. 22 (1), 52–59.
- Baran, M.E., Wu, F.F., 1989a. Optimal sizing of capacitors placed on aradial distribution system. IEEE Trans. Power Deliv. 4 (1), 735–743.
- Baran, M.E., Wuf, F., 1989b. Network reconfiguration in distribution systems for loss reduction and load balancing. IEEE Trans. Power Deliv. 4 (2), 1401–1407.
- Barker, P.P., 2003. Determining the impact of distributed generation on power systems: Part 1-Radial distribution systems. In: Proc. IEEE Power Eng. Soc. Summer Meeting, pp. 1645–1656.
- Barker, P.P., De Mello, R.W., 2000. Determining the impact of distributed generation on power systems. I. Radial distribution systems. In: Power Engineering Society Summer Meeting, Vol. 3. IEEE, pp. 1645–1656.
- Basturk, B., Karaboga, D., 2006. An artificial bee colony (ABC) algorithm for numeric function optimization. In: Proc. IEEE Swarm Intell. Symp. Indianapolis.
- Bernardon, D.P., Garcia, V.J., Ferreira, A.S.Q., Canha, L.N., 2005. Reconfiguration of distribution networks to minimize loss and disruption costs using genetic algorithms. IEEE Trans. Power Deliv. 25 (4), 2684–2691.
- Bhowmik, A., Maitra, A., Halpin, S.M., Schatz, J.E., 2003. Determination of allowable penetration levels of distributed generation resources based on harmonic limit considerations. IEEE Trans. Power Deliv. 18 (2), 619–624.
- Biswas, S., Goswami, S.K., 2010. Genetic algorithm based optimal placement of distributed generation reducing loss and improving voltage sag performance. In: Proc. of Int. Conf. on Advances in Electrical & Electronics, pp. 49–51.
- Blum, C., Dorigo, M., 2004. The hyper-cube framework for ant colony optimization. IEEE Trans. Syst. Man, Cybern. B, Cybern. 34 (2), 1161–1172.

- Boardman, J., Meckiff, C., 1985. A branch and bound formulation to electricity distribution planning problems. *IEEE Trans. Power App. Syst.* 104 (8), 2112–2118.
- Boehme, T., Harrison, G.P., Wallace, A.R., 2010. Assessment of distribution network limits for non-firm connection of renewable generation. *IET Renew. Power Gener.* 4 (1), 64–74.
- Boehme, T., Wallace, A.R., Harrison, G.P., 2007. Applying time series to power flow analysis in networks with high wind penetration. *IEEE Trans. Power Syst.* 22 (3), 951–957.
- Borazan, V., Rajicic, D., Ackovski, R., 1997. Minimum loss reconfiguration of unbalanced distribution networks. *IEEE Trans. Power Deliv.* 12, 435–441.
- Borges, C.L.T., Falcao, D.M., 2003. Impact of distributed generation allocation and sizing on reliability, losses and voltage profile. In: IEEE Bolonga power technology conference.
- Borges, C.L.T., Falcao, D.M., 2006. Optimal distributed generation allocation for reliability, losses and voltage improvement. *Int. J. Electr. Power Energy Syst.* 28 (6), 413–420.
- Borozan, V., Rajakovic, N., 1997. Minimum loss distribution network configuration: analysis and management. *IEE Conf.* 2 (5), 618–630.
- Borozan, V., Rajicic, D., Ackovski, R., 1995. Improved method for loss minimization in distribution networks. *IEEE Trans. Power App. Syst.* 10, 1420–1424.
- Brahma, S.M., Giris, A.A., 2004. Development of adaptive protection scheme for distribution systems with high penetration of distributed generation. *IEEE Trans. Power Deliv.* 19 (1), 56–63.
- Brian, B.C., Shin, C., 1994. Development of the loss minimization function for real time power system operations: a new tool. *IEEE Trans. Power Syst.* 9, 2028–2034.
- Broadwater, R.P., Khan, A.H., Shaalan, H.E., Lee, R.E., 1993. Time varying load analysis to reduce distribution losses through reconfiguration. *IEEE Trans. Power Deliv.* 8 (1), 294–300.
- Broadwater, R.P., Thompson, J.C., Rahman, S., Sargent, A., 1994. An expert system for integrated protection design with configurable distribution circuits. Part I. *IEEE Trans. Power Deliv.* 9 (2), 1115–1121.
- Brown, R.E., 2002. Modeling the reliability impact of distributed generation. In: Proc. IEEE Power Eng. Soc. Summer Meeting, Vol. 1, pp. 442–446.
- Brown, R.E., Freeman, L.L.A., 2001. Analyzing the reliability impact on distributed generation. *IEEE Power Eng. Soc. Summer Meet.* (2), 1013–1018.
- Brown, R.E., Pan, J., Feng, X., Koutlev, K., 2001. Siting distributed generation to defer T&D expansion. In: Proc. IEEE Transmission and Distribution Conf. and Expo, Vol. 2, pp. 622–627.
- Burke, W.J., Merrill, H., Schwepp, F.C., Lovell, B.E., McCoy, M.F., Monohon, S.A., 1988. Trade-off methods in system planning. *IEEE Trans. Power Syst.* 3 (3), 1284–1290.
- Caire, R., Retiere, N., Martino, N., Andrieu, N., Hadjsaid, N., 2002. Impact assessment of LV distributed generation on MV distribution network. In: IEEE Power Engineering Society Summer Meeting.
- Cañizares, C.A., 1998a. Applications of optimization to voltage collapse analysis. In: Proc. IEEE Power Eng. Soc. Summer Meeting, San Diego.
- Cañizares, C.A., 1998b. Calculating optimal parameters to maximize the distance to saddle node bifurcations. *IEEE Trans. Circuits Syst. I* 45 (3), 225–237.
- Cañizares, C.A., Alvaro, F.L., 1993. Point of collapse and continuation methods for large ac/dc systems. *IEEE Trans. Power Syst.* 8 (1), 1–8.
- Carpaneto, E., Chicco, G., Akilimali, J.S., 2006. Branch current decomposition method for loss allocation in radial distribution systems with distributed generation. *IEEE Trans. Power Syst.* 21 (3), 1170–1179.
- Carpinelli, G., Celli, G., Moccia, S., Pilo, F., Russo, A., 2005. Optimisation of embedded generation sizing and siting by using a double trade-off method. *Proc. Inst. Elect. Eng.-Gen. Transm. Dist.* 152 (4), 503–513.
- Carpinelli, G., Celli, G., Pilo, F., Russo, A., 2001. Distributed generation siting and sizing under uncertainty. In: Proc. IEEE Porto Power Tech.
- Carpinelli, G., Celli, G., Russo, A., 2001. A generation siting and sizing under uncertainty. In: Proceedings IEEE Porto Power Technology.
- Carrano, E.G., Soares, L.A.E., Takahashi, R.H.C., Saldanha, R.R., Neto, O.M., 2006. Electric distribution multiobjective network design using a problem-specific genetic algorithm. *IEEE Trans. Power Deliv.* 21 (2), 995–1005.
- Carrano, E.G., Takahashi, R.H.C., Cardoso, E.P., Neto, O.M., Saldanha, R.R., 1998. Optimal substation location and energy distribution network design using an hybrid GA-BFGS algorithm. *IEE Proc. Gener. Transm. Distrib.* 152 (6), 919–926.
- Carreno, E.M., Romero, R., Padilha-Feltrin, A., 2008. An efficient codification to solve distribution network reconfiguration for loss reduction problem. *IEEE Trans. Power Syst.* 23 (4), 1542–1551.
- Carvalho, P.M.S., Correia, P.F., 2008. Distributed reactive power generation control for voltage rise mitigation in distribution networks. *IEEE Trans. Power Syst.* 23 (2), 766–772.
- Carvalho, P.M.S., Correia, P.F., Ferreira, L.A.F.M., 2008. Distributed reactive power generation control for voltage rise mitigation in distribution networks. *IEEE Trans. Power Syst.* 23 (2), 766–772.
- Carvalho, P.M.S., Ferreira, L.A., Lobo, F.G., Barruncho, L.M., 1998. Optimal distribution network expansion planning under uncertainty by evolutionary decision convergence. *Elect. Power Energy Syst.* 20 (2), 125–129.
- Cebrian, J.C., Kagan, N., 2010. Reconfiguration of distribution networks to minimize loss and disruption costs using genetic algorithms. *Electr. Power Syst. Res.* 80, 53–62.
- Celli, G., Ghiani, E., Moccia, S., 2005. A multiobjective evolutionary algorithm for the sizing and siting of distributed generation. *IEEE Trans. Power Syst.* 20 (2), 750–757.
- Celli, G., Pilo, F.M.V., 2001a. Network planning under uncertainties on distributed generation penetration. In: Proc. IEEE Power Eng. Soc. Summer Meeting, Vol. 1, pp. 485–490.
- Celli, G., Pilo, F., 2001b. Optimal distributed generation allocation in MV distribution networks. In: Proc. 22nd IEEE PES Int. Conf. on Power Industry Computer Applications, PICA 2001, Sydney, Australia, May.
- Chandramohana, S., Atturulua, N., Kumudini, D., Venkatesh, B., 2010. Operating cost minimization of a radial distribution system in a deregulated electricity market through reconfiguration using NSGA. *Int. J. Electr. Power Energy Syst.* 32 (2), 126–132.
- Chang, C.F., 2008. Reconfiguration and capacitor placement for loss reduction of distribution systems by ant colony search algorithm. *IEEE Trans. Power Syst.* 23 (4), 1747–1755.
- Chang, H.C., Kuo, C.C., 1994. Network reconfiguration in distribution system using simulated annealing. *Electr. Power Syst. Res.* 29, 227–238.
- Chao, X.Y., Feng, X.M., Slump, D.J., 1999. Impact of deregulation on power delivery planning. *Proc. IEEE Transm. Distrib. Conf.* 1, 340–344.
- Chen, G.P., Malik, O.P., Hope, G.S., Qin, Y.H., Xu, G.Y., 1993. An adaptive power system stabilizer based on the self-optimizing pole shifting control strategy. *IEEE Trans. Energy Convers.* 8 (4), 639–645.
- Cheng, H.C., Kou, C.C., 1994. Network reconfiguration in distribution systems using simulated annealing. *Electr. Power Syst.* 29 (3), 227–238.
- Chiang, H.D., 1991. A decoupled load flow-method for distribution power networks: algorithms, analysis and convergency study. *Electr. Power Energy Syst.* 13 (3), 130–138.
- Chiang, H.D., Flueck, A., Shah, K.S., Balu, N., 1995. CPFLOW: A practical tool for tracing power system steady-state stationary behavior due to load and generation variations. *IEEE Trans. Power Syst.* 10 (2), 623–634.
- Chiang, H., Jean-Jumeau, R., 1990a. Optimal network reconfigurations in distribution system: part 1: a new formulation and solution methodology. *IEEE Trans. Power Deliv.* 5, 1902–1909.
- Chiang, H.D., Jean-Jumeau, R., 1990b. Optimal network reconfigurations in distribution systems, part 2: Solution algorithms and numerical results. *IEEE Trans. Power Deliv.* 5 (3), 1568–1574.
- Chin, H.C., Huang, K.Y., 2000. A simple distribution reconfiguration algorithm for loss minimization. *IEEE Trans. Power Syst.* 2 (2), 607–611.
- Chiou, J.P., Chang, C.F., Su, C.T., 2004. Ant direction hybrid differential evolution for solving large capacitor placement problems. *IEEE Trans. Power Syst.* 19 (4), 1794–1800.
- Chiou, J.P., Chang, C.F., Su, C.T., 2005. Variable scaling hybrid differential evolution for solving network reconfiguration of distribution systems. *IEEE Trans. Power Syst.* 20 (2), 668–674.
- Chiradeja, P., Ramakumar, R., 1998. A review of distributed generation and storage. *Proc. Front. Power Conf.* 11, 4–8.
- Chiradeja, P., Ramakumar, R., 2001. A probabilistic approach to the analysis of voltage profile improvement with distributed wind electric generation. In: Proc. Frontiers of Power Conf. pp. 1–10.
- Chiradeja, P., Ramakumar, R., 2004. An approach to quantify the technical benefits of distributed generation. *IEEE Trans. Energy Convers.* 19 (4), 764–773.
- Chis, M., Salama, M.M.A., Jayaram, S., 1997. Capacitor placement in distribution systems using heuristic search strategies. *IEE Proc. Gener. Transm. Distrib.* 144, 225–230.
- Choi, S.-B., 2007. Assessment of reliability in the distribution system of an industrial complex. *J. Electr. Eng. Technol.* 2 (2), 201–207.
- Chowdhury, A.A., Agarwal, S.K., Koval, D.O., 2003. Reliability modelling of distributed generation in conventional distribution systems planning and analysis. *IEEE Trans. Ind. Appl.* 39 (5), 1493–1498.
- Ciric, R.M., Padilha-Feltrin, A., Ochoa, L.F., 2003. Power flow in four-wire distribution networks-general approach. *IEEE Trans. Power Syst.* 18 (4), 1283–1290.
- Civanlar, S., Grainger, J.J., Yin, H., Lee, S.S.H., 1988. Distribution feeder reconfiguration for loss reduction. *IEEE Trans. Power Deliv.* 3 (3), 1217–1223.
- Coles, L., Beck, R.W., 2001. Distributed generation can provide an appropriate customer price response to help fix wholesale price volatility. In: IEEE Power Eng. Soc. Winter Meeting, Vol. 1.
- Concordia, C., Ihara, S., 1982. Load representation in power systems stability studies. *IEEE Trans. Power App. Syst.* 101 (4), 969–977.
- Conejo, A.J., Arroyo, J.M., Alguacil, N., Guijarro, A.L., 2002. Transmission loss allocation: A comparison of different practical algorithms. *IEEE Trans. Power Syst.* 17 (3), 571–576.
- Costa, P.M., Matos, M.A., 2015. Loss allocation in distribution networks with embedded generation. *IEEE Trans. Power Syst.* 19 (1), 384–389.
- Dale, L., 2002. Distributed generation transmission. In: Proc. IEEE Power Engineering Society Winter Meeting, Vol. 1, pp. 132–134.

- Daly, P.A., Morrison, J., 2001. Understanding the potential benefits of distributed generation on power delivery systems. In: Proc. IEEE Rural Electric Power Conf. Little Rock.
- Dan, Z., Robert, P., Broadwater, , Tam, Kwa-Sur, Seguin, Rich, Asgeirsson, Haukur, 2006. Impact of DG placement on reliability and efficiency with time-varying loads. *IEEE Trans. Power Syst.* 21 (1), 419–427.
- Das, D.A., 2006. fuzzy multiobjective approach for network reconfiguration of distribution systems. *IEEE Trans. Power Deliv.* 21 (1), 202–209.
- Das, D., Kothari, D.P., Kalam, A., 1995. Simple and efficient method for load flow solution of radial distribution networks. *Electr. Power Energy Syst.* 17 (5), 335–346.
- Das, D., Nagi, H.S., Kothari, D.P., 1994. Novel method for solving radial distribution networks. *IEE Proc. -Gener. Transm. Distrib.* 141, 291–298.
- De Macêdo Braz, H.D., Alencar de Souza, B.A., 2011. Distribution network reconfiguration using genetic algorithms with sequential encoding: subtractive and additive approaches. *IEEE Trans. Power Syst.* 26 (2), 582–593.
- De Monaco, J.L., 2000. Current status of distributed generation technologies presented. In: 31st Energy Information Dissemination Program. Oklahoma State Univ. and Stillwater.
- De Oliveira, L.E., 2010. Optimal reconfiguration and capacitor allocation in radial distribution systems for energy losses minimization. *Int. J. Electr. Power Energy Syst.* 32 (8), 840–848.
- Del Valle, Y., Venayagamoorthy, G.K., Mohagheghi, S., 2008. Particle swarm optimization: Basic concepts, variants and applications in power systems. *IEEE Trans. Evol. Comput.* 12 (2), 171–195.
- Delbem, A.C.B., Carvalho, A.C.P.L.F., Bretas, N.G., 2005. Main chain representation for evolutionary algorithms applied to distribution system reconfiguration. *IEEE Trans. Power Syst.* 20 (1), 425–436.
- Dent, C., Ochoa, L.F., Harrison, G.P., 2005. Network distributed generation capacity analysis using OPF with voltage step constraints. *IEEE Trans. Power Syst.* 25 (1), 296–304.
- Dent, C., Ochoa, L.F., Harrison, G.P., Bialek, J.W., 2010b. Efficient secure AC OPF for network generation capacity assessment. *IEEE Trans. Power Syst.* 25 (1), 575–583.
- Ding, X., Girgis, A.A., 2001. Optimal load shedding strategy in power systems with distributed generation. *IEEE Winter Meeting Power Eng. Soc.* 12 (2), 788–793.
- Dobson, I., Lu, L., 1992a. Computing an optimum direction in controlspace to avoid stable node bifurcation and voltage collapse in electric power systems. *IEEE Trans. Autom. Control.* 37 (10), 1616–1620.
- Dobson, I., Lu, L., 1992b. Voltage collapse precipitated by the immediate change in stability when generator reactive power limits are encountered. *IEEE Trans. Circuits Syst. I* 39 (9), 762–766.
- Dommel, H.W., Tinney, W.F., 1968. Optimal power flow solutions. *IEEE Trans. Power App. Syst.* 87, 1866–1876.
- Donnelly, M.K., Dagle, J.E., Trudnowski, D.J., Rogers, G.J., 1996. Impacts of the distributed utility on transmission system stability. *IEEE Trans. Power Syst.* 11 (2), 741–746.
- Dorigo, M., Gambardella, L.M., 1997. Ant colony system: A cooperative learning approach to the Traveling salesman problem. *IEEE Trans. Evol. Comput.* 1, 53–66.
- Doyle, M.T., 2002. Reviewing the impacts of distributed generation on distribution-system protection. In: Proc. IEEE Power Eng. Soc. Summer Meeting, vol. 1, pp. 103–105.
- Duan, G., Yu, Y., 2003. Power distribution system optimization by an algorithm for capacitated Steiner tree problems with complex-flows and arbitrary cost functions. *Elect. Power Energy Syst.* 25, 515–523.
- Dugan, R.C., Dermott, T.E.Mc., Ball, G.E., 2001. Planning for distributed generation. *IEEE Ind. Appl. Mag.* 7, 80–88.
- Dugan, R.C., McDermont, T.E., 2002. Distributed generation. *IEEE Ind. Applicat. Mag.* 19–25.
- Dugan, R.C., Price, S.K., 2002. Issues for distributed generations in the US. In: Proc. IEEE Power Engineering Society Winter Meeting, Vol. 1, pp. 121–126.
- Eberly, T.W., Schaefer, R.C., 2002. Voltage versus VAr/power-factor regulation on synchronous generators. *IEEE Trans. Ind. Appl.* 38 (6), 1682–1687.
- Eduardo, G.C., Frederico, G.G., Ricardo, H.C., 2007. Electric distribution network expansion under load-evolution uncertainty using an immune system inspired algorithm. *IEEE Trans. Power Deliv.* 22 (2).
- Edwards, F.V., Dudgeon, G.J., McDonald, J.R., Leithead, W.E., 2000. Dynamics of distribution networks with distributed generation. In: Proc. IEEE PES Summer Meeting, pp. 1032–1037.
- El-Hawary, M.E., 1998. *Electric Power Applications of Fuzzy Systems*. IEEE Press, New York.
- El-Khattam, W., Salama, M.M.A., 2004. Distributed generation technologies, definitions and benefits. Elsevier *Electr. Power Syst. Res.* 71, 119–128.
- El-Khattam, W., Bhattacharya, K., Hegazy, Y., Salama, M.M.A., 2004. Optimal investment planning for distributed generation in a competitive electricity market. *IEEE Trans. Power Syst.* 19 (3), 1674–1684.
- El-Khattam, W., Bhattacharya, K., Hegazy, Y., Salama, M.M.A., 2004. Optimal investment planning for distributed generation in a competitive electricity market. *IEEE Trans. Power Syst.* 19 (3), 1674–1684.
- El-Khattam, W., Hegazy, Y.G., Salama, M.M.A., 2005. An integrated distributed generation optimization model for distribution system planning. *IEEE Trans. Power Syst.* 20 (2), 1158–1165.
- El-Metwally, K.A., Hancock, G.C., Malik, O.P., 1996. Implementation of a fuzzy logic pss using a micro-controller and experimental test results. *IEEE Trans. Energy Convers.* 11 (1), 91–96.
- Eminoglu, U., Hocaoglu, M.H., 2005. A new power flow method for radial distribution systems including voltage dependent load models.
- Enrique, L., Opazo, H., Garcia, L., Bastard, P., 2004. Online reconfiguration considering variability demand: Application to real networks. *IEEE Trans. Power Syst.* 19 (1).
- Etemadi, A.H., Fotuhi, F.M., 2008. Distribution system reliability enhancement using optimal capacitor placement. *IET Gener. Transm. Distrib.* 2 (5), 621–631.
- Ettehad, M., Ghasemiand, H., Vaez-Zadeh, S., 2013. Voltage stability-based DG placement in distribution networks. *IEEE Trans. Power Syst.* 28 (1).
- Fahad, S., El-Hawary, M.E., 2011. Optimal distributed generation allocation and sizing in distribution systems via artificial bee colony algorithm. *IEEE Trans. Power Deliv.* 26 (4).
- Fahim, S.R., Helmy, W., Badr, M.A.L., 2001. Optimal study of distributed generation impact on electrical distribution networks using GA and generalized reduced gradient. *Recent Res. Commun. Electr. Computer Eng.* 77–82.
- Fan, J.Y., Zhang, L., McDonald, J.D., 1996. Distribution network reconfiguration: Single loop optimization. *IEEE Trans. Power Syst.* 11 (3), 1643–1647.
- Fraile, A.J., Zufiria, P.J., 2005. Adaptive power system stabilizer using ANFIS and genetic algorithms. In: 44th IEEE Conference on Decision and Control, and the European Control Conference Seville, Spain, pp. 12–15.
- Friedman, R., 1998. Microturbine power generation: Technology development needs and challenges presented. Environmental Electric Energy Opportunities for the Next Century, IEEE/EPRI Vision-21, Washington DC.
- Gallego, R.A., Monticell, A.J., Romero, R., 2001. Optimal capacitor placement in radial distribution networks. *IEEE Trans. Power Syst.* 16 (4), 630–637.
- Ganjavi, M.R., 2001. Coordinated comprehensive design of distribution systems at medium and low voltage levels. *Proc. 16th Int. Conf. Exhib. Elect. Distrib.* 5 (29), 1–6.
- Gao, Y., Hill, D.J., Wang, Y., 2001. Global transient stability and voltage regulation for power systems. *IEEE Trans. Power Syst.* 16 (4), 678–688.
- Gareth, P., Harrison, G.P., Antonio, P.A., 2007. Exploring the tradeoffs between incentives for distributed generation developers and DNOs. *IEEE Trans. Power Syst.* 22 (2).
- Georgilakis, P.S., Hatziyargyriou, N.D., 2013. Optimal distributed generation placement in power distribution networks: Models, methods, and future research. *IEEE Trans. Power Syst.* 28 (3), 3420–3428.
- Ghosh, S., Das, D., 1999. Method for load flow solution of radial distribution network. In: Proc. IEE Generation Transmission and Distribution, Vol. 146.
- Ghosh, S., Ghoshal, S.P., Ghosh, S.A., 2010. Optimal sizing and placement of distributed generation in a network system. *Int. J. Electr. Power* 32 (8), 849–856.
- Gil, H.A., Joos, G., 2006. On the quantification of the network capacity deferral value of distributed generation. *IEEE Trans. Power Syst.* 21 (4), 1592–1599.
- Girgis, A., Brahma, S., 2000. Effect of distributed generation on protective device coordination in distribution systems. In: Proc. IEEE PES Summer Meeting, pp. 115–1119.
- Glamocanin, V., 1990. Optimal loss reduction of distribution networks. *IEEE Trans. Power Syst.* 5, 774–781.
- Gomes, F.V., Carneiro, S., Pereira, J.L.R., Vinagre, M.P., Garcia, P.A.N., Araujo, L.R., 2005. A new heuristic reconfiguration algorithm for large distribution systems. *IEEE Trans. Power Syst.* 20 (3), 1375–1378.
- Gomes, F.V., Carneiro, S., Pereira, J.L.R., Vinagre, M.P., Garcia, P.A.N., Araujo, L.R., 2006. A new distribution system reconfiguration approach using optimum power flow and sensitivity analysis for loss reduction. *IEEE Trans. Power Syst.* 21 (4), 1616–1623.
- Gómez, J.F., Khodr, H.M., De Oliveira, P.M., Ocque, L., Yusta, J.M., Villasana, R., Urdaneta, A.J., 2004. Ant colony system algorithm for the planning of primary distribution circuits. *IEEE Trans. Power Syst.* 19 (2), 996–1004.
- Gonen, T., Ramírez-Rosado, I.J., 1986. Review of distribution system planning models: A model for optimal multistage planning. *Proc. Inst. Elect. Eng.* 133 (7), 397–408.
- Gonzlez-Longatt, F.M., 2007. Impact of distributed generation over power losses on distribution system. In: Proc. of 9th International Conference on Electrical Power Quality and Utilisation.
- Gopiya, S., Naik, D.K., Sharma, M.P., 2013. Optimum allocation of combined DG and capacitor for real power loss minimization in distribution network. *Electr. Power Energy Syst.* 53, 967–973.
- Goswami, S.K., Basu, S.K., 1992. A new algorithm for the reconfiguration of distribution feeders for loss minimization. *IEEE Trans. Power Deliv.* 7 (3), 1484–1491.
- Goswami, S.K., Basu, S.K., 1992. A new algorithm for the reconfiguration of distribution feeders for loss minimization. *IEEE Trans. Power Deliv.* 7 (3), 1484–1491.

- Gözel, T., Hocaoglu, M.H., 2009. An analytical method for the sizing and siting of distributed generators in radial systems. *Electr. Power Syst. Res.* 79 (6), 912–918.
- Gray, T., 1998. Wind gets competitive in the US. *Solar Today* 12 (2), 18–21.
- Greatbanks, J.A., Popovic, D.H., Begovic, M., Pregelj, A., Green, T.C., 2003. On optimization for security and reliability of power systems with distributed generation. In: Proc. IEEE Bologna Power Tech Conf.
- Greene, S., Dobson, I., Alvarado, F.L., 1996. Sensitivity of the loading margin to voltage collapse with respect to arbitrary parameters. In: Proc. IEEE Power Eng. Soc. Winter Meeting.
- Greene, S., Dobson, I., Alvarado, F.L., 1997. Contingency analysis for voltage collapse via sensitivities from a single nose curve. In: Proc. IEEE PES Summer Meeting.
- Grenard, S., Strbac, G., 2003. Effect of regulation on distribution companies investment policies in the UK. In: Proc. IEEE Bologna Power Tech Conf. Bologna, Italy.
- Griffin, T., Tomsovic, K., Secret, D., 2000a. Placement of dispersed generation systems for reduced losses. In: Proc. 33rd Annu. Hawaii Int. Conf. Systems Sciences Maui HI.
- Griffin, T., Tomsovic, K., Secret, D., Low, A., 2000b. Placement of dispersed generation systems for reduced losses. In: Proc. 33rd Annu. Hawaii Int. Conf. Syst. Sciences, HICSS, Big Island, HI, pp. 1446–1454.
- Guimaraes, M.A.M., Castro, C.A., Romero, R., 2010. Distribution systems operation optimization through reconfiguration and capacitor allocation by a dedicated genetic algorithm. *IET Gener. Transm. Distrib.* 4 (11), 1213–1222.
- Gupta, N., Swarnkar, A., Niazi, K.R., Bansal, R.C., 2010. Multi-objective reconfiguration of distribution systems using adaptive genetic algorithm in fuzzy framework. *IET Gener. Transm. Distrib.* 4 (12), 1288–1298.
- Hadjisaid, N., Canard, J.F., Dumas, F., 1999a. Dispersed generation impact on distribution networks. *IEEE Comput. Appl. Power.* 12 (2), 22–28.
- Hadjisaid, N., Canard, J., Dumas, F., 1999b. Dispersed generation increases the complexity of controlling and maintaining the distribution systems. *IEEE Comput. Appl. Power.* 12, 23–28.
- Haesen, E., Espiniza, M., Plummers, B., Goethals, I., Thong, V., Driesen, J., Belmans, R., De Moore, B., 2005. Optimal placement and sizing of distributed generator units using genetic optimization algorithms. *Electr. Power Qual. Utilisation* J. 11 (1), 97–104.
- Haghifam, M.R., Falaghi, H., Malik, O.P., 2008. Risk-based distributed generation placement. *IET Gener. Transm. Distrib.* 2 (2), 252–260.
- Hajizadeh, A., Hajizadeh, E., 2008. PSO-Based planning of distribution systems with distributed generations. *Int. J. Electr. Electron. Eng.* 2 (1), 33–38.
- Hamed, H., Gandomkar, M., 2012. A straight forward approach to minimizing unsupplied energy and power loss through DG placement and evaluating power quality in relation to load variations over time. *Int. J. Elec. Power* 35, 93–96.
- Haque, M.H., 1996. Load flow-solution of distribution systems with voltage dependent load models. *Elec. Power Syst. Res.* (36), 151–156.
- Hariri, A., Malik, O.P., 1986. A fuzzy logic based power system stabilizer with learning ability. *IEEE Trans. Energy Convers.* 11 (4), 721–727.
- Harrison, G.P., Piccolo, A., Siano, P., Wallace, A.R., 2008. Hybrid GA and OPF evaluation of network capacity for distributed generation connections. *Electr. Power Syst. Res.* 78 (3), 392–398.
- Harrison, G.P., Wallace, A.R., 2005. Optimal power flow evaluation of distribution network capacity for the connection of distributed generation. *IEE Proc. Gener. Transm. Distrib.* 152 (1), 115–122.
- Hasan, H., Nabaviniaki, S.A., Akbarimajd, A., 2008. A method for placement of DG units in distribution networks. *IEEE Trans. Power Syst.* 23 (3).
- Heffner, G., Woo, C.K., Horii, B., Lloyd-Zannetti, D., 1998. Variations in area and time-specific marginal capacity costs of electricity distribution. *IEEE Trans. Power Syst.* 13 (2), 560–567.
- Hegazy, Y.G., Salama, M.M.A., Chikhani, A.Y., 2003. Adequacy assessment of distributed generation systems using Monte Carlo simulation. *IEEE Trans. Power Syst.* 18 (1), 48–52.
- Hejazi, H.A., Araghi, A.R., Vahidi, B., Hosseiniyan, S.H., Abedi, M., Rad, H.M., 2013. Independent distributed generation planning to profit both utility and DG investors. *IEEE Trans. Power Syst.* 28 (2).
- Herlambang, S., Awan, U.K., Mithulanthan, N., Hossain, M.J., 2018. Modal interaction of power systems with high penetration of renewable energy and BES systems. 97, 385–395.
- Hetzter, J., Yu, C., Bhattacharai, K., 2008. An economic dispatch model incorporating wind power. *IEEE Trans. Energy Convers.* 23 (2), 603–611.
- Hien, N.C., Mithulanthan, N., Bansal, R.C., 2013. Location and sizing of distributed generation units for loadability enhancement in primary feeder. *IEEE Trans. Power Syst.* 28 (2).
- Hobbs, B.F., Meier, P.M., 1994. Multi-criteria methods for planning: An experimental comparison. *IEEE Trans. Power Syst.* 9, 167–173.
- Hoff, T., Shugar, D.S., 1995. The value of grid-support photovoltaics in reducing distribution system losses. *IEEE Trans. Energy Convers.* 10, 569–576.
- Hong, Ying-Yi, Ho, Saw-Yu, 2005. Determination of network configuration considering multiobjective in distribution systems using genetic algorithms. *IEEE Trans. Power Syst.* 20 (2).
- Hossain, S.M., Nabavi, M., Masoum, A.S., 2011. Placement and sizing of distributed generation units for congestion management and improvement of voltage profile using PSO. *IEEE*.
- Hsiao, Y.T., Chen, C.Y., 2001. Multiobjective optimal feeder reconfiguration. *Proc. Inst. Elect. Eng. Gener. Transm. Distrib.* 148, 333–336.
- Hsiao, Y.T., Chien, C.Y., 2001. Optimisation of capacitor allocation using an interactive trade off method. *Proc. Inst. Elect. Eng.-Gen. Transm. Dist.* 148 (4), 371–374.
- Huang, S.J., 2001. Enhancement of hydroelectric generation scheduling using ant colony system based optimization approaches, energy conversion. *IEEE Trans. Energy Convers.* 16 (3), 296–301.
- Huang, J.S., Jiang, Z.H., Negnevitsky, M., 2013. Loadability of power system and optimal SVC placement. *Electr. Power Energy Syst.* 167–174.
- Huddleston, C.T., Broadwater, R.P., Chandrasekaran, A., 1990. Reconfiguration algorithm for minimizing losses in radialelectric distribution systems. *Electr. Power Syst. Res.* *IEEE Distrib. Syst.* 18 (1), 57–67.
- Hugo, A., Geza, J., 2006. On the quantification of the network capacity deferral value of distributed generation. *IEEE Trans. Power Syst.* 21 (4).
1993. IEEE task force on load representation for dynamic performance, load representation for dynamic performance analysis. *IEEE Trans. Power Syst.* 8(2), 472–482.
- Iwamoto, S., Tamura, Y., 1981. A load flow-calculation method for ill conditioned power systems. *IEEE Trans. Power Appar. Syst.* 100 (4), 1736–1743.
- Jabr, R., Pal, B., 2009a. Intermittent wind generation in optimal power flow dispatching. *IET Gen. Transm. Distrib.* 3 (1), 66–74.
- Jabr, R.A., Pal, B.C., 2009b. Ordinal optimisation approach for locating and sizing of distributed generation. *IET Gener. Transm. Distrib.* 3 (8), 713–723.
- Jain, S., Ganga, A., Shilpa, K., 2015. Evaluation of optimal access location and capacity of dg for insertion in distribution system with condensed power losses showing improved critical bus voltage stipulation. *Electr. Electron. Eng.: Int. J.* 4 (1).
- Jain, N., Singh, S.N., Srivastava, S.C., 2010. Particle swarm optimization based method for optimal siting and sizing of multiple distributed generators. In: Proceedings of 16th National Power Systems Conference, pp. 669–674.
- Jasmon, G.B., Lee, L.H.C., 1991. Distribution network reduction for voltage stability analysis and load flow calculations. *Elec. Power Energy Syst.* 13 (1), 9–13.
- Jenkins, N., Allan, R., Crossley, P., Kirschen, D., Strbac, G., 2000. Embedded generation. In: *IEE Power and Energy Series*, 31, *Inst. Elect. Eng.*, London, UK.
- Jeon, Y.J., Kim, J.C., 2000. Network reconfiguration in radial distribution system using simulated annealing and tabu search. In: Proc. IEEE Power Eng. Soc. Winter Meeting, pp. 23–27.
- Jeon, Y.J., Kim, J.C., Kim, J.O., Shin, J.R., Lee, K.Y., 2002. An efficient simulated annealing algorithm for network reconfiguration in large-scale distribution systems. *IEEE Trans. Power Deliv.* 17 (4), 1070–1078.
- Shin, J.R., Kim, B.S., Park, J.B., Kwang, Y., Lee, K.Y., 2007. A new optimal routing algorithm for loss minimization and voltage stability improvement in radial power systems. *IEEE Trans. Power Syst.* 22 (6).
- Joos, H.A., 2008. Models for quantifying the economic benefits of distributed generation. *IEEE Trans. Power Syst.* 23 (2).
- Jóos, G., Ooi, B.T., McGillivray, D., Galiana, F.D., Marceau, R., 2000. The potential of distributed generation to provide ancillary services. In: Proc. IEEE Power Eng. Soc. Summer Meeting, Seattle, WA.
- Kamel, R.M., Kermanshahi, B., 2009. Optimal size and location of distributed generations for minimizing power losses in a primary distribution network. *Sci. Iranica, Comput. Sci. Eng. Electr. Eng. Trans.* D 16 (6), 137–144.
- Kansal, S., Sai, BBR., Tyagi, B., Kumar, V., 2011. Optimal placement of distributed generation in distribution networks. *Int. J. Eng. Sci. Technol.* 3 (3), 47–55.
- Karaboga, D., Basturk, B., 2007. A powerful and efficient algorithm for numerical function optimization: Artificial bee colony (ABC) algorithm. *J. Global Optim.* 39, 459–471.
- Karki, R., Billinton, R., 2004. Cost-effective wind energy utilization for reliable power supply. *IEEE Trans. Energy Convers.* 19 (2), 435–440.
- Kashem, M.A., Ganapathy, V., Jasmon, G.B., 1999. Network reconfiguration for load balancing in distribution networks. *Proc. Inst. Elect. Eng. Gener. Transm. Distrib.* 146, 563–567.
- Kashem, M.A., Ganapathy, V., Jasmon, G.B., 2000a. Network reconfiguration for enhancement of voltage stability in distribution networks. *Proc. Inst. Elect. Eng. Gen. Transm. Distrib.* 147 (3), 171–175.
- Kashem, M.A., Ganapathy, V., Jasmon, G.B., Buhari, M.I., 2000b. A novel method for loss minimization in distribution networks. *Electr. Utility Deregulation Restruct. Power Technol.* 2 (7), 4–7.
- Kashem, M.A., Le, A.D.T., Negnevitsky, M., Ledwich, G., 2006. Distributed generation for minimization of power losses in distribution systems. In: Proc. IEEE Power Eng. Soc. Gen. Meeting, pp. 1–8.
- Kashem, M.A., Moghavemi, M., Mohamed, A., Jasmon, G.B., 1998. Loss reduction in distribution networks using new network reconfiguration algorithm. *Electr. Mach. Power Syst.* 26 (8), 815–829.
- Kataoka, Y., 2003. A probabilistic nodal loading model and worst case solutions for electric power system voltage stability assessment. *IEEE Trans. Power Syst.* 18 (6), 1507–1514.

- Keane, A., Ochoa, L.F., Vittal, E., Dent, C.J., Harrison, G.P., 2011. Enhanced utilization of voltage control resources with distributed generation. *IEEE Trans. Power Syst.* 26 (1), 252–260.
- Keane, A., O'Malley, M., 2005. Optimal allocation of embedded generation on distribution networks. *IEEE Trans. Power Syst.* 20 (3), 1640–1646.
- Keane, A., O'Malley, M., 2006. Optimal distributed generation plantmix with novel loss adjustment factors. In: Proc. IEEE PES General Meeting.
- Keane, A., O'Malley, M., 2007. Optimal utilization of distribution networks for energy harvesting. *IEEE Trans. Power Syst.* 22 (1), 467–475.
- Keane, A., Zhou, Q., Bialek, J., O'Malley, M., 2009. Planning and operating non-firm distributed generation. *IET Renew. Power Gen.* 3 (4), 455–464.
- Kejun, Q., Chengke, Z., Malcolm, A., Yue, Y., 2011. Effect of load models on assessment of energy losses in distributed generation planning. *Int. J. Electr. Power Energy Syst.* 33, 1243–1250.
- Kellogg, W., Nehrir, M.H., Venkataraman, G., Gerez, V., 1998. Generationunit sizing and cost analysis for stand-alone wind, photovoltaic, and hybrid wind/PV systems. *IEEE Trans. Energy Convers.* 13, 70–75.
- Kersting, W.H., 1991. Radial distribution test feeders. *IEEE Trans. Power Syst.* 6 (3), 975–985.
- Kersting, W.H., 2003. The computation of neutral and dirt currents and power losses. In: Proc. IEEE Power Eng. Soc. Transmission Distribution Conf. Expo.
- Kersting, W.H., 1991. IEEE distribution planning working group report: Radial distribution test feeders. *IEEE Trans. Power Syst.* 6 (3), 975–985.
- Khalesi, N., Rezaei, N., Haghifam, M.R., 2011. DG allocation with application of dynamic programming for loss reduction and reliability improvement. *Int. J. Electr. Power Energy Syst.* 33 (2), 288–295.
- Khan, H., Choudhry, M.A., 2010a. Implementation of distributed generation (IDG) algorithm for performance enhancement of distribution feeder. *Int. J. Electr. Power Energy Syst.* 32 (9), 985–997.
- Khan, H., Choudhry, M.A., 2010b. Implementation of distributed generation (IDG) algorithm for performance enhancement of distribution feeder under extreme load growth. *Int. J. Electr. Power Energy Syst.* 32 (9), 985–997.
- Khator, S.K., Leung, L.C., 1997. Power distribution planning: A review of models and issues. *IEEE Trans. Power Syst.* 12, 1151–1159.
- Khattamet, W., Bhattacharya, K., Hegazy, Y., Salama, M.M.A., 2004. Optimal investment planning for distributed generation in a competitive electricity market. *IEEE Trans. Power Syst.* 19 (3).
- Khodr, H.M., Silva, M.R., Vale, Z., Ramos, C., 2010. A probabilistic methodology for distributed generation location in isolated electrical service area. *Electr. Power Syst. Res.* 80 (4), 390–399.
- Khodr, H.M., Martínez-Crespo, J., Matos, M.A., Pereira, J., 2009. Distribution systems reconfiguration based on OPF using Benders decomposition. *IEEE Trans. Power Deliv.* 24 (4), 2166–2176.
- Kim, H., Ko, Y., Jung, K.H., 1993. Artificial neural-network based feeder reconfiguration for loss reduction in distribution systems. *IEEE Trans. Power Deliv.* 8 (3), 1356–1366.
- Kim, J.E., Hwang, J.S., 2001. Islanding detection method of distributed generation units connected to power distribution system. In: Proc. IEEEPES Summer Meeting, 643–647.
- Kim, J.O., Nam, S.W., Park, S.K., Singh, C., 1998. Dispersed generation planning using improved here for branch algorithm. *Electr. Power Syst. Res.* 47 (1), 47–55.
- Kim, K.H., Lee, Y.J., Rhee, S.B., Lee, S.K., You, S.K., 2002. Dispersed generator placement using fuzzy-GA in distribution systems. In: IEEE power engineering society summer meeting, Chicago, IL, Vol. 3, pp. 1148–1153.
- Kim, K.H., Song, K.B., Joo, S.K., Lee, Y.J., Okim, J., 2008. Multiobjective distributed generation placement using fuzzy goal programming with genetic algorithm. *Eur. Trans. Electr. Power* 18, 217–230.
- Kotamarty, S., Khushalani, S., Schulz, N., 2008. Impact of distributed generation on distribution contingency analysis. *Electr. Power Syst. Res.* 78 (9), 1537–1545.
- Kotari, M.L., Bhattacharya, K., Nanda, J., 1996. Adaptive power system stabiliser based on pole-shifting technique. *IEEE Proc. Gener. Transm. Distrib.* 143 (1), 96–98.
- Kotb, M.F., Shebl, K.M., Khazendar, M.E., Husseiny, A.E., 2010. Genetic algorithm for optimum siting and sizing of distributed generation. In: Proceedings of 14th International Middle East Power Systems Conference, pp. 433–440.
- Kruerasuk, W., Ongsakul, W., 2006. Optimal placement of distributed generation using particle swarm optimization. In: Proceedings of Power Engineering Conference in Australasian Universities, Australia.
- Kuersuk, W., Ongsakul, W., 2006. Optimal placement of distributed generation using particle swarm optimization. In: Australian universities power engineering conference, AUPEC 06.
- Kumar, S., Kumar, N.P., 2011. Optimal planning of distributed generation for improved voltage stability and loss reduction. *Int. J. Computer Appl.* 15 (1), 40–46.
- Kumarand, A., Gao, W., 2010. Optimal distributed generation location using mixed integer non-linear programming in hybrid electricity markets. *IET Gener. Transm. Distrib.* 4 (2), 281–298.
- Kuo, W., Wan, R., 2007. Recent advances in optimal reliability allocation. *IEEE Trans. Syst. Man, Cybern. A. Syst. Humans.* 37 (2), 143–156.
- Kuri, B., Redfern, M., Li, F., 2004. Optimization of rating and positioning of dispersed generation with minimum network disruption. In: Proc. IEEE Power Eng. Soc. Gen. Meeting, Denver, CO, Vol. 2, pp. 2074–2078.
- Lalitha, M.P., Veera Reddy, V.C., Sivarami Reddy, N., Reddy, K.S., 2010. Clonal selection algorithm for DG sources allocation for minimum loss in distribution system. *Int. J. Computer Sci. Emerg. Technol.* 1, 85–91.
- Lalitha, M.P., Veera Reddy, V.C., Sivarami Reddy, N., Reddy, V.U., 2011. A two stage methodology for siting and sizing of DG for minimum loss in radial distribution system using RCGA. *Int. J. Computer Appl.* 5 (2), 10–16.
- Lasseter, R.H., 1998. Control of distributed resource. In: Proc. Bulk Power Syst. Dynamics Control IV, Santorini, Greece, pp. 323–329.
- Lavorato, M., Franco, J.F., Rider, M.J., Romero, R., 2012. Imposing radiality constraints in distribution system optimization problems. *IEEE Trans. Power Syst.* 27 (1), 172–180.
- Le, A.D.T., Kashem, M.A., Negnevitsky, M., Ledwich, G., 2005. Maximising voltage support in distribution systems by distributed generation. In: Proc. IEEE TENCON Conf., pp. 1–6.
- Le, A.D.T., Kashem, M.A., Negnevitsky, M., Ledwich, G., 2007. Optimal distributed generation parameters for reducing losses with economic consideration. In: Proc. IEEE Power Eng. Soc. Gen. Meeting, pp. 1–8.
- Lee, K.Y., El-Sharkawi, M.A., 2002. Modern heuristic optimization techniques with applications to power systems. *IEEE Power Eng. Soc.*
- Lee, S.-H., Park, J.-W., 2009. Selection of optimal location and size of multiple distributed generations by using Kalman filter algorithm. *IEEE Trans. Power Syst.* 24 (3), 1393–1400.
- Liang, J., Qin, A., Suganthan, P., Baskar, S., 2006. Comprehensive learning particle swarms optimizer for global optimization of multimodal functions. *IEEE Trans. Evol. Comput.* 10 (3), 281–295.
- Liang, R.H., Wang, Y.S., 2003. Fuzzy-based reactive power and voltage control in a distribution system. *IEEE Trans. Power Deliv.* 18 (2), 610–618.
- Lin, W.N., Cheng, F.S., Tsay, M.T., 2000. Distribution feeder reconfiguration with refined genetic algorithm. *Proc. Inst. Elect. Eng. Gener. Transm. Distrib.* 147, 349–354.
- Lind, R., Karlsson, D., 1996. Distribution system modelling for voltage stability studies. *IEEE Trans. Power Syst.* 11 (4), 1677–1682.
- Liu, M.B., Caizares, C.A., Huang, W., 2009. Reactive power and voltage control in distribution systems with limited switching operations. *IEEE Trans. Power Syst.* 24 (2), 889–899.
- Liu, C.C., Lee, S.J., Venkata, S.S., 1988. An expert system operational aid for restoration and loss reduction of distribution system. *IEEE Trans. Power Syst.* 3 (2), 619–626.
- Löf, P.A., Andersson, G., Hill, D., 1995. Voltage dependent reactive power limits for voltage stability studies. *IEEE Trans. Power Syst.* 10 (1), 220–228.
- Lopes, J.A.P., 2002. Integration of dispersed generation on distribution networks—impact studies. In: Proc. IEEE Power Eng. Soc. Winter Meeting, Vol. 1, pp. 323–328.
- Lopez, E., Opazo, H., Garcia, L., Bastard, P., 2004. Online reconfiguration considering variability demand: applications to real networks. *IEEE Trans. Power Syst.* 19 (1), 549–553.
- Lopez, E., Opazo, H., Garcia, L., Poloujadoff, M., 2002. Minimal loss reconfiguration based on dynamic programming approach: application to real systems. *Power Compon. Syst.* 30 (7), 693–704.
- Lopez-Lezama, J.M., Contreras, J., Padilha-Feltrin, A., 2012. Location and contract pricing of distributed generation using a genetic algorithm. *Int. J. Elec. Power Energy Syst.* 36 (1), 117–126.
- Luan, W.P., Irving, M.R., Daniel, J.S., 2002. Genetic algorithm for supply restoration and optimal load shedding in power system distribution networks. *Proc. Inst. Elect. Eng.-Gener. Transm. Distrib.* 149, 145–151.
- Luo, G.X., Semlyen, A., 1990. Efficient load flow for large weakly meshed networks. *IEEE Trans. Power Syst.* 5 (4), 1309–1316.
- M, Al-A., Ali, A.A., Eid, A.M., 2011. Optimal Size and Location of Distributed Generation Unit for Voltage Stability Enhancement. IEEE.
- Mahdi, Sedghi, Ali, Ahmadian, Masoud, Aliakbar-Golkar, 2016. Optimal storage planning in active distribution network considering uncertainty of wind power distributed generation. *IEEE Trans. Power Syst.* 3 (1), 304–316.
- Mardaneh, M., Gharehpetian, G.B., 2004. Siting and sizing of DG units using GA and OPF based technique. In: Proc. IEEE Region 10 TENCON Conf., Vol. 3, pp. 331–334.
- Marei, M.I., El-Saadany, E.F., Salama, M.M.A., 2004. A novel control algorithm for the DG interface to mitigate power quality problems. *IEEE Trans. Power Deliv.* 19 (3), 1384–1392.
- Masters, C.L., 2002. Voltage rise: The big issue when connecting embedded generation to long 11 kv overhead lines. *IET Power Eng.* 16 (1), 5–12.
- McDermott, T., Drezga, I., Broadwatwer, R., 1999. A heuristic nonlinear constructive method for distribution system reconfiguration. *IEEE Trans. Power Syst.* 14, 478–483.
- Mekhamer, S.F., El-Hawary, M.E., Mansour, M.M., Moustafa, M.A., Soliman, S.A., 2002. Fuzzy and heuristic techniques for reactive power compensation of radial

- distribution feeders: A comparative study. *Proc. IEEE Can. Conf. Elect. Comput. Eng.* 1, 112–121.
- Meliopoulos, A.P.S., Cokkinides, G.J., Chao, X.Y., 1990. A new probabilistic power flow analysis method. *IEEE Trans. Power Syst.* 5 (1), 182–190.
- Méndez, V.H., Rivier, A.J., Gómez, S.T., 2006. Assessment of energy distribution losses for increasing penetration of distributed generation. *IEEE Trans. Power Syst.* 21 (2), 533–540.
- Mendoza, J.E., Lopez, M.E., Coello, C.A.C., Lopez, E.A., 2009. Microgenetic multiobjective reconfiguration algorithm considering power losses and reliability indices for medium voltage distribution network generation. *Transm. Distrib., IEE Proc.* 3 (9), 825–840.
- Mendoza, J.E., Morales, D.A., Lopez, R.A., Lopez, E.A., Vannier, L.C., Coello, C.A.C., 2007. Multiobjective location of automatic voltage regulators in radial distribution network using a micro genetic algorithm. *IEEE Trans. Power Syst.* 22 (1), 404–412.
- Merlin, A., Back, G., 1975. Search for minimum-loss operational spanning tree configuration for an urban power distribution system. In: *Proc. 5th Power Syst. Conf.* Cambridge, UK, pp. 1–18.
- Milligan, M.R., Graham, M.S., 1996. An enumerated probabilistic simulation technique and case study: Integrating wind power into utility production cost models. In: National Renewable Energy Lab. for Wind Energy Program.
- Miranda, V., Ranito, J.V., Proençā, L.M., 1994. Genetic algorithms in optimal multi-stage distribution network planning. *IEEE Trans. Power Syst.* 9 (4), 1927–1933.
- Mishra, D., Singh, B., 2017. Enhancement of power system performance by optimal placement of distributed generation using genetic algorithms. *IRJET* 4 (9), 370–377.
- Mithulanthan, N., Than, O., Phu, L.V., 2004. Distributed generator placement in power distribution system using genetic algorithm to reduce losses. *Thammasat Int. J. Sci. Technol.* 55–62.
- Mohammad, M., Nasab, M.A., 2011. DG placement with considering reliability improvement and power loss reduction with GA method. *Res. J. Appl. Sci. Eng. Technol.* 3 (8), 838–842.
- Mok, S., Elangovan, S., Longjian, C., Salama, M., 2000. A new approach for power-flow analysis of balanced radial distribution systems. *Electr. Mach. Power Syst.* 28, 325–340.
- Moradi, M.H., Abedini, M., 2012. A combination of genetic algorithm and particles warm optimization for optimal DG location and sizing in distribution systems. *Int. J. Electr. Power Energy Syst.* 34, 66–74.
- Morton, A.B., Mareels, I.M.Y., 2000. An efficient brute-force solution to the network reconfiguration problem. *IEEE Trans. Power Deliv.* 15 (3), 996–1000.
- Moshtagh, J., Jalali, A., Karimizadeh, K., 2010. Optimum placement and sizing of DG using binary PSO algorithm to achieve the minimum electricity cost for consumers. *Int. Rev. Electr. Eng.-I* 5 (6), 2873–2881.
- Murthy, V.V.S.N., Kumar, A., 2013. Comparison of optimal DG allocation method in radial distribution systems based on sensitivity approaches. *Electr. Power Energy Syst.* 53, 450–467.
- Mutale, J., Strbac, G., Curcic, S., Jenkins, N., 2000. Allocation of losses in distribution system with embedded generation. *Proc. Inst. Elect. Eng. Gen. Transm. Distrib.* 147 (1), 7–14.
- Nag, H.N., Salama, M.M.A., Chikhani, A.Y., 2000. Classification of capacitor allocation techniques. *IEEE Trans. Power Deliv.* 387–392.
- Nagendra Rao, P.S., Ravishankar Deekshit, R.S., 2006. Energy loss estimation in distribution feeders. *IEEE Trans. Power Deliv.* 21 (3).
- Naik, S.G., Khatod, D.K., Sharma, M.P., 2013. Optimum allocation of combined DG and capacitor for real power loss minimization in distribution network. *Electr. Power Energy Syst.* 53, 967–973.
- Nara, K., Hayashi, Y., Ikeda, K., Ashizawa, T., 2001. Application of tabu search to optimal placement of distributed generators. In: *Proc. IEEE Power Eng. Soc. Winter Meeting*, pp. 918–923.
- Nara, K., Kuwabara, H., Kitagawa, M., Ohtaka, K., 1994. Algorithm for expansion planning in distribution systems taking faults into consideration. *IEEE Trans. Power Syst.* 9 (1), 324–330.
- Nara, K., Shiose, A., Kitagawa, M., Ishihara, T., 1992. Implementation of genetic algorithm for distribution systems loss minimum re-configuration. *IEEE Trans. Power Syst.* 7, 1044–1051.
- Nara, K., Song, Y.H., 2002. Modern heuristics application to distribution system optimization. In: *Proc. IEEE Power Eng. Society Winter Meeting*, pp. 826–832.
- Naresh, A., Pukar, M., Mithulanthan, N., 2006. An analytical approach for DG allocation in primary distribution network. *Electr. Power Energy Syst.* 28, 669–678.
- Nehrir, M.H., Wang, C., Gerez, V., 2003. Impact of wind power distributed generation on distribution systems. In: *Proc. 17th Int. Conf. Electricity Distribution, CIRED*, Barcelona, Spain.
- Niketut, A., Abdillah, A., Soeprijanto, A., 2011. Optimal placement and sizing of distributed generation using Quantum genetic algorithm for reducing loss and improving voltage profile. In: *IEEE TENCON*.
- Ochoa, L.F., Dent, C.J., Harrison, G.P., 2008a. Maximisation of intermittent distributed generation in active networks. In: *Proc. CIREDSeminar 2008: Smart Grids for Distribution*.
- Ochoa, L.F., Dent, C.J., Harrison, G.P., 2010. Distribution network capacity assessment: Variable DG and active networks. *IEEE Trans. Power Syst.* 25 (1), 87–95.
- Ochoa, L.F., Feltrin, A.P., Gareth, P., Harrison, G.P., 2008b. Evaluating distributed time-varying generation through a multi objective index. *IEEE Trans. Power Syst.* 23 (2).
- Ochoa, L.F., Feltrin, A.P., Harrison, G.P., 2006. Evaluating distributed generation impacts with a multi objective index. *IEEE Trans. Power Deliv.* 21 (3), 1452–1458.
- Ochoa, L.F., Padilha, F.A., Harrison, G.P., 2008c. Evaluating distributed time-varying generation through a multiobjective index. *IEEE Trans. Power Deliv.* 23 (2), 1132–1138.
- Ochoa, L.F., Padilha-Feltrin, A., Harrison, G.P., 2008d. Time-series based maximization of distributed wind power generation integration. *IEEE Trans. Energy Convers.* 23 (3), 968–974.
- Osborn, M., 2004. Experiences in aggregating distributed generation for system benefit. In: *IEEE Power Eng. Soc. GeneralMeeting*, Denver.
- Paiva, P.C., Khodr, H.M., Dominguez-Navarro, J.A., Yusta, J.M., Urdaneta, A.J., 2004. Integral planning of primary–secondary distribution systems using mixed integer linear programming. *IEEE Trans. Power Syst.* 20 (2).
- Paliwal, P., Patidar, N.P., 2010. Distributed generator placement for loss reduction and improvement in reliability. *World Acad. Sci. Eng. Technol.* 69, 809–813.
- Parada, V., Ferland, J.A., Daniels, M.A.K., 2004. Optimization of electrical distribution feeders using simulated annealing. *IEEE Trans. Power Deliv.* 19 (3), 1135–1141.
- Park, J., Lee, K., 2005. A particle swarm optimization for economic dispatch with non-smooth cost functions. *IEEE Trans. Power Syst.* 20 (1), 34–42.
- Pavlos, S., Georgilakos, N.D., Hatzigaryiou, D., 2013. Optimal distributed generation placement in power distribution networks: Models methods and future research. *IEEE Trans. Power Syst.* 28 (3).
- Payasi, R.P., Singh, A.K., Singh, D., 2013. Effect of voltage step constraint and load models in optimal location and size of distributed generation. In: *IEEE International Conference on Power, Energy and Control, ICPEC*, pp. 710–716.
- Peponis, G.P., Papadopoulos, M.P., Hatzigaryiou, N.D., 1995. Distribution network reconfiguration to minimize resistive line losses. *IEEE Trans. Power Deliv.* 10 (3), 1338–1342.
- Peponis, G., Papadopoulos, M., Hatzigaryiou, N., 1996. Optimal operation of distribution networks. *IEEE Trans. Power Syst.* 11, 59–67.
- Philipson, L., 2000. Distributed and dispersed generation: Addressing the spectrum of consumer needs. In: *Proc. IEEE Power Engineering Society Summer Meeting*, vol. 3, pp. 1663–1665.
- Piccolo, A., Siano, P., 2009. Evaluating the impact of network investment deferral on distributed generation expansion. *IEEE Trans. Power Syst.* 24 (3), 1559–1567.
- Ponnavakkal, M., Prakasa, K.S., Venkata, S.S., 1987. Distribution system planning through a quadratic mixed-integer programming approach. *IEEE Trans. Power Deliv.* 2 (4), 1157–1163.
- Popovic, D.H., Greatbanks, J.A., Begovic, M., Pregelj, A., 2005. Placement of distributed generations and reclosers for distribution network security and reliability. *Int. J. Electr. Power Energy Syst.* 27 (5–6), 398–408.
- Porkar, S., Poure, P., Abbaspour, T.F.A., Saadate, S., 2011. Optimal allocation of distributed generation using a two-stage multi-objective mixed-integer-nonlinear programming. *Eur. Trans. Electr. Power.* 21 (1), 1072–1087.
- Prasad, K., Ranjan, R., Sahoo, C., Chaturvedi, A., 2005. Optimal reconfiguration of radial distribution systems using a fuzzy mutated genetic algorithm. *IEEE Trans. Power Deliv.* 20 (2), 1211–1213.
- Pregelj, A., Begovic, M., Rohatgi, A., 2018. Recloser allocation for improved reliability of DG-enhanced distribution networks: Analysis and tuning of the genetic algorithm. *IEEE Trans. Power Syst.* (submitted for publication).
- Pregelj, A., Fellow, M.B., Rohatgi, A., 2006. Recloser allocation for improved reliability of DG enhanced distribution networks. *IEEE Trans. Power Deliv.* 21 (3), 1442–1448.
- Price, D.L., 2002. Distributed generation in general and micro turbines presented. In: *33rd Energy Information Dissemination Program*. Oklahoma State Univ. Stillwater.
- Quezada, V.H.M., Abbad, J.R., Romn, T.G.S., 2006. Assessment of energy distribution losses for increasing penetration of distributed generation. *IEEE Trans. Power Syst.* 21 (2), 533–540.
- Quintana, V.H., Temraz, H.K., Hipel, K.W., 1993. Two-stage power system-distribution-planning algorithm. *Proc. Inst. Elect. Eng. Gener. Transm. Distrib.* 140, 17–29.
- Rahman, S., 2001. Fuel cell as a distributed generation technology. In: *Proc. IEEE Power Engineering Society Summer Meeting*, Vol. 1, pp. 551–552.
- Raiissi, A.T., Banerjee, A., Scheinko, K.G., 1997. Current technology of fuel cell systems. *Proc. Intersoc. Energy Convers. Eng. Conf.* 45 (7), 1953–1957.

- Rajendran, A., Narayanan, K., 2017. Optimal installation of different DG types in radial distribution system considering load growth. *J. Electr. Power Compon. Syst.* 45 (7), 739–751.
- Raju, M., Saikia, L.C., Sinha, N., 2016. Automatic generation control of a multi-area system using ant lion optimizer algorithm based PID plus second order derivative controller. *Int. J. Electr. Power Energy Syst.* 80, 52–63.
- Ramakumar, R., 2001. Technology and economic market integration of DG. In: Proc. Frontiers of Power Conf., pp. 11–14.
- Ramakumar, R., Chiradeja, P., 2002. Distributed generation and renewable energy systems. In: Proc. Intersociety Energy Conversion Engineering Conf. IECEC, vol. 7, pp. 1–8.
- Ramírez-Rosado, I.J., Bernal-Agustín, J.L., 1998. Genetic algorithms applied to the design of large power distribution systems. *IEEE Trans. Power Syst.* 13 (2), 696–703.
- Ramírez-Rosado, I.J., Bernal-Agustín, J.L., 1998. Genetic algorithm applied to design of large power distribution systems. *IEEE Trans. Power Syst.* 13 (2), 696–703.
- Ramírez-Rosado, I.J., Bernal-Augustín, J.L., 1998. Genetic algorithms applied to the design of large power distribution systems. *IEEE Trans. Power Syst.* 13 (2), 696–703.
- Ramírez-Rosado, I.J., Gönen, T., 1991. Planning for expansion of power distribution systems. *IEEE Trans. Power Syst.* 6 (1), 245–254.
- Ramos, E.R., Expósito, A.G., Santos, J.R., 2005. Path-based distribution network modeling: Application to reconfiguration for loss reduction. *IEEE Trans. Power Syst.* 20 (2), 556–564.
- Rao, R.S., Narasimham, S.V.L., Ramalingaraju, M., 2008. Optimization of distribution network configuration for loss reduction using artificial bee colony algorithm. *Int. J. Electr. Power Energy Syst.* 1 (2).
- Rashid, H., Al-Rubayi, , Azhar, M.A., 2010. Optimal size and location of distributed generators using intelligent techniques. *Engg. Tech. J.* 28 (23), 6623–6633.
- Rau, N.S., Wan, Y.H., 1994. Optimum location of resources in distributed planning. *IEEE Trans. Power Syst.* 9 (4), 2014–2020.
- Renato Cespedes, G., 1990. New method for the analysis of distribution networks. *IEEE Trans. Power Deliv.* 5 (1), 391–396.
- Reza, S., Hussain Shareef, A.M., 2012. Optimal allocation of shunt var compensator in power system using a novel global harmony search algorithm. *Electr. Power Energy Syst.* 43, 562–572.
- Reza, M., Slootweg, J.G., Schavemaker, P.H., Kling, W.L., Vander Sluis, L., 2003. Investigating impacts of distributed generation on transmission system stability. In: Proc. IEEE Power Tech. Rome, Italy.
- Rezaei, P., Vakilian, M., 2010. Distribution system efficiency improvement by reconfiguration and capacitor placement using a modified particle swarm optimization algorithm. In: Proceedings of the Electric Power and Energy Conference, EPEC, pp. 1–6.
- Rezazadeh, M.A., Alavian, A., 2009. Optimal sizing and siting of distributed generation for power system transient stability enhancement using genetic algorithm. *IACSIT Int. J. Computer Theory Eng.* 1 (5), 387–390.
- Rizy, D.T., Lawler, J.S., Patten, J.B., Nelson, W.R., 1989. Measuring and analyzing the impact of voltage and capacitor control with high speed data acquisition. *IEEE Trans. Power Deliv.* 4 (1), 704–714.
- Rodrigo, R.P., Luis, S., Vargas, L.S., Alejandro Jofre, A.A., 2005. Distribution company energy acquisition market model with integration of distributed generation and load curtailment options. *IEEE Trans. Power Syst.* 20 (4), 1718–1727.
- Roger, J.J., 1993. ANFIS: adaptive-network-based fuzzy inference system. *IEEE Trans. Syst. Man Cybern.* 23 (3), 665–685.
- Roy, N.K., Hossain, M.J., 2013. Reactive power management of distribution networks with wind generation for improving voltage stability. 58, 85–94.
- Roy, N.K., Mahmud, M.A., Hossain, M.J., Pota, H.R., 2010. Impact of distributed wind generation on distribution networks. In: Proc. of Solar 2010, the 48th AuSES Annual Conference, 1–3 Dec.
- Roytelman, I., Melnik, V., Lee, S., Lugu, R., 1996. Multi objective feeder reconfiguration by distribution management system. *IEEE Trans. Power Syst.* 11, 661–667.
- Salama, M., Chikhani, A.Y., 1993. A simplified network approach to the VAR control problem for radial distribution systems. *IEEE Trans. Power Syst.* 8 (3), 1529–1535.
- Salameh, Z.M., Borowy, B.S., Amin, A.R.A., 1995. Photovoltaic module-site matching based on the capacity factors. *IEEE Trans. Energy Convers.* 10 (2), 326–332.
- Salazar, H., Gallego, R., Romero, R., 2006. Artificial neural networks and clustering techniques applied in the reconfiguration of distribution systems. *IEEE Trans. Power Deliv.* 21 (3), 1735–1742.
- Salvatore, F.S., Giorgio, G., Mariano, M.G., Sanseverino, E.R., 2007. Optimal electrical distribution systems reinforcement planning using gas micro turbines by dynamic ant colony search algorithm. *IEEE Trans. Power Deliv.* 22 (2).
- Santhikumar, S., Raja, J., 2008. Optimization of distributed generation capacity for line loss reduction and voltage profile improvement using pso. *Electrika* 10, 41–48.
- Sarfí, R., Salama, M., Chikhani, A., 1994. A survey of the state of the art in distribution system reconfiguration for system loss reduction. *Electr. Power Syst. Res.* 61–70.
- Sarfí, R., Salama, M., Chikhani, Y., 1996. Distribution system reconfiguration for loss reduction: an algorithm based on network partitioning theory. *IEEE Trans. Power Syst.* 11, 504–510.
- Scott, W.G., 1998. Micro-turbine generators for distributed system. *IEEE Ind. Appl. Mag.* 5, 7–62.
- Sedighzadeh, M., Dakhem, M., Sarvi, M., Kordkheili, H.H., 2014. Optimal reconfiguration and capacitor placement for power loss reduction of distribution system using improved binary particle swarm optimization. *Int. J. Energy Environ. Eng.*
- Selvakumar, A.I., Thanushkodi, K., 2007. A new particle swarm optimization solution to nonconvex economic dispatch problems. *IEEE Trans. Power Syst.* 22 (1), 42–51.
- Senju, T., Miyazato, Y., Yona, A., Urasaki, N., Funabashi, T., 2008. Optimal distribution voltage control and coordination with distributed generation. *IEEE Trans. Power Deliv.* 23 (2), 1236–1242.
- Shaaban, M.F., Atwa, Y.M., El-Saadany, E.F., 2013. DG allocation for benefit maximization in distribution networks. *IEEE Trans. Power Syst.* 28 (2).
- Sharma, K., Vittal, K.P., 2010. A heuristic approach to distributed generation source allocation for electrical power distribution systems. *Iranian J. Electr. Electron. Eng.* 6 (4), 224–231.
- Shenkar, A.I., 1990. Energy loss computation by using statistical techniques. *IEEE Trans. Power Deliv.* 5, 254–258.
- Shereen, Md., 2012. Optimal allocation of DG units for radial distribution systems using genetic algorithm. *IJEAT* 1 (6), 2249–8958.
- Shim, H., Park, J.H., Bae, I.S., Kim, J.O., 2005. Optimal capacity and allocation of distributed generation by minimum operation cost in distribution systems. *KIEE Int. Trans. Power Eng.* 5 (1), 9–15.
- Shirmohammadi, D., Hong, H.W., 1989. Reconfiguration of electric distribution networks for resistive line losses reduction. *IEEE Trans. Power Deliv.* 4 (2), 1492–1498.
- Shirmohammadi, D., Hong, H.W., Semlyen, A., Luo, G.X., 1988. A compensation-based power-flow method for weakly meshed distribution and transmission networks. *IEEE Trans. Power Syst.* 3 (2), 753–762.
- Shukla, T.N., Singh, S.N., Srinivasarao, V., Naik, K.B., 2010. Optimal sizing of distributed generation placed on radial distribution systems. *Electr. Power Compon. Syst.* 38 (3), 260–274.
- Siano, P., Ochoa, L.F., Harrison, G.P., Piccolo, A., 2009. Assessing the strategic benefits of distributed generation ownership for dnios. *IET Gen. Transm. Distrib.* 3(3), 225–236.
- Silvestri, A., Berizzi, A., Buonanno, S., 1999. Distributed generation planning using genetic algorithms. In: Proc. IEEE PowerTech, Vol. 257.
- Sim, K.M., Sun, W.H., 2003. Ant colony optimization for routing and load balancing: Survey and new directions. *IEEE Trans. Syst. Man, Cybern. A, Syst. Humans* 33 (5), 560–572.
- Singh, M., Kannan, T., Kumar, P., Indrani, K., 2015a. Real-time coordination of electric vehicles to support the grid at the distribution substation level. *IEEE Syst. J.* 9 (3), 23–45.
- Singh, R.K., Goswami, S.K., 2009. Optimum siting and sizing of distributed generations in radial and networked systems. *Electr. Power Compon. Syst.* 37 (2), 127–145.
- Singh, R.K., Goswami, S.K., 2010. Optimum allocation of distributed generations based on nodal pricing for profit, loss reduction, and voltage improvement including voltage rise issue. *Int. J. Electr. Power Energy Syst.* 32 (6), 637–644.
- Singh, D., Mishra, R.K., Singh, D., 2007a. Effect of load models on distributed generation planning. *IEEE Trans. Power Syst.* 22 (4), 2204–2212.
- Singh, B., Mukherjee, V., Tiwari, P., 2015b. A survey on impact assessment of DG and FACTS controllers in power systems. *Renew. Sustain. Energy Rev.* 42, 846–882.
- Singh, A.K., Parida, S.K., 2015. Allocation of distributed generation using proposed DMSP approach based on utility and customers aspects under deregulated environment. *Int. J. Electr. Power Energy Syst.* 68, 159–169.
- Singh, D., Singh, D., Verma, K.S., 2007b. GA based optimal sizing & placement of distributed generation for loss minimization. *Int. J. Electr. Computer, Energetic, Electron. Commun. Eng.* 1 (11), 1604–1610.
- Singh, D., Singh, D., Verma, K.S., 2009a. Distributed generation planning strategy with load models in radial distribution system. *Int. J. Computer Electr. Eng.* 1 (3), 362–375.
- Singh, D., Singh, D., Verma, K.S., 2009b. Distributed generation planning strategy with load models in radial distribution system. *Int. J. Computer Electr. Eng.* 1 (3), 1793–8163.
- Singh, D., Singh, D., Verma, K.S., 2009c. Multi-objective optimization for DG planning with load models. *IEEE Trans. Power Syst.* 24 (1), 427–436.
- Singh, B., Verma, K.S., Singh, D., Singh, S.N., 2011. A novel approach for optimal placement of distributed generation & FACTS controllers in power system. *Int. J. Rev. Comput.* 7, 2076–3328.
- Song, Y.H., Wang, G.S., Johns, A.T., Wang, P.Y., 1997. Distribution network reconfiguration for loss reduction using fuzzy controlled evolutionary programming. *Proc. Inst. Elect. Eng. Gen. Trans. Distrib.* 144 (4), 345–350.

- Soo-Hyoun, L., Jung-Wook, P., 2009. Selection of optimal location and size of multiple distributed generations by using kalman filter algorithm. *IEEE Trans. Power Syst.* 24 (3).
- Soroudi, A., Ehsan, M.A., 2010. Distribution network expansion planning model considering distributed generation options and techo-economical issues. *Energy* 35 (8), 3364–3374.
- Soroudi, A., Ehsan, M., 2011. A possibilistic-probabilistic tool for evaluating the impact of stochastic renewable and controllable power generation on energy losses in distribution networks-a case study. *Renew. Sustain. Energy Rev.* 15 (1), 794–800.
- Soroudi, A., Ehsan, M., Caire, R., Hadjsaid, N., 2011a. Possibilistic evaluation of distributed generations impacts on distribution networks. *IEEE Trans. Power Syst.* 26 (4), 2293–2301.
- Soroudi, A., Ehsan, M., Zareipour, H., 2011b. A practical eco-environmental distribution network planning model including fuel cells and non-renewable distributed energy resources. *Renew. Energy* 36 (1), 179–188.
- Srinivas, M., Patnaik, L.M., 1994. Adaptive probabilities of crossover and mutation in genetic algorithms. *IEEE Trans. Syst. Man. Cybern.* 24 (4), 656–667.
- Srivastava, A., Tripathi, J.M., Mohanty, S.R., Panda, B., 2016. Optimal over-current relay coordination with distributed generation using hybrid particle swarm optimization–gravitational search algorithm. *J. Electr. Power Compon. Syst.* 44 (5), 506–517.
- Stott, B., Alsac, O., 1974. Fast decoupled load flow. *IEEE Trans. Power Appar. Syst.* 93 (3), 859–869.
- Su, C.-L., 2010. Stochastic evaluation of voltages in distribution network with distributed generation using detailed distribution models. *IEEE Trans. Power Syst.* 25 (2), 786–795.
- Su, C.T., Chang, C.F., Chiou, J.P., 2005. Distribution network reconfiguration for loss reduction by ant colony search algorithm. *Electr. Power Syst. Res.* 75, 190–199.
- Su, C.T., Lee, C.S., 2001. Feeder reconfiguration and capacitor setting for loss reduction of distribution systems. *Electr. Power Syst. Res.* 58 (2), 97–102.
- Su, C.T., Lee, C.S., 2003. Network reconfiguration of distribution systems using improved mixed-integer hybrid differential evolution. *IEEE Trans. Power Deliv.* 18 (3), 1022–1027.
- Sundhararajan, S., Pahwa, A., 1994. Optimal selection of capacitor for radial distribution systems using a genetic algorithm. *IEEE Trans. Power Syst.* 9 (3), 1499–1507.
- Swarup, K.S., Yamashiro, S., 2002. Unit commitment solution methodology using genetic algorithm. *IEEE Trans. Power Syst.* 17 (1), 87–91.
- Taleski, R., Rajcic, D., 1997. Distribution network reconfiguration for energy loss reduction. *IEEE Trans. Power Syst.* 12 (1), 398–406.
- Taylor, T., Lubkeman, D., 1990. Implementation of heuristic search strategies for distribution feeder reconfiguration. *IEEE Trans. Power Deliv.* 5, 239–246.
- Teng, J.H., 2003. A direct approach for distribution system load flow solutions. *IEEE Trans. Power Deliv.* 18 (3), 882–887.
- Teng, J.H., Liu, Y.H., 2003. A novel ACS-based optimum switches relocation method. *IEEE Trans. Power Syst.* 18 (1), 113–120.
- Teng, J.H., Liu, Y.H., Chen, C.Y., 2007. Value-based distributed generator placements for service quality improvements. *Int. J. Electr. Power Energy Syst.* 29 (3), 268–274.
- Teng, J.H., Luor, T.S., Liu, Y.H., 2002. Strategic distributed generator placements for service reliability improvements. In: Proc. IEEE Power Engineering Society Summer Meeting, Vol. 2, pp. 719–724.
- Thirault, D., Besanger, Y., Hadjsaid, N., Almeida, A., Huard, G., 2002. Cost estimation of different electric systems for rural areas in developing countries. In: Proc. IEEE Power Engineering Society Summer Meeting, Vol. 1, pp. 23–28.
- Thomson, M., 2007. Infield DG network power-flow analysis for a high penetration of distributed generation. *IEEE Trans. Power Syst.* 22 (3), 1157–1162.
- Tinney, W.G., Hart, C.E., 1967. Power flow solutions by Newton's method. *IEEE Trans. Power Appar. Syst.* 86, 1449–1457.
- Tiwari, D., Ghatak, S.R., 2017. Performance enhancement of distribution system using optimal allocation of distributed generation & DSTATCOM. In: IEEE Conference Feb, pp. 21–23.
- Tong, S., Miu, K.N., 2005. A network-based distributed slack bus model for DGs in unbalanced power flow studies. *IEEE Trans. Power Syst.* 20 (2), 835–842.
- Tripathy, S.C., Prasad, G.D., Malik, O.P., Hope, G.S., 1982. Load flow solutions for ill-conditioned power systems by a Newton-like method. *IEEE Trans. Power Appar. Syst.* 101 (10), 3648–3657.
- Tuba Gözel, T., Hakan Hocaoglu, M., Söder, L., 2009. An analytical method for the sizing and siting of distributed generators in radial systems. *Electr. Power Syst. Res.* 79, 912–918.
- Tuitemwong, K., Premrudeepreechacharn, S., 2011. Expert system for protection coordination of distribution system with distributed generators. *Int. J. Electr. Power* 33, 466–471.
- Ullah, N.R., Bhattacharya, K., Thiringer, T., 2009. Wind farms as reactive power ancillary service providers- technical and economic issues. *IEEE Trans. Energy Convers.* 24 (3), 661–672.
- Usaola, J., 2009. Probabilistic load flow in systems with wind generation. *IET Gen. Transm. Distrib.* 3 (12), 1031–1041.
- Usta, O., Redfem, M., 2001. Protection of dispersed storage and generation units against islanding. In: Proc. IEEE PES Summer Meeting, pp. 976–979.
- Van, C.T., 1991. A method to compute reactive power margins with respect to voltage collapse. *IEEE Trans. Power Syst.* 6 (1), 145–156.
- Vasebi, A., Fesanghary, M., Bathaei, S.M.T., 2007. Combined heat and power economic dispatch by harmony search algorithm. *Int. J. Electr. Power Energy Syst.* 29 (10), 713–719.
- Venkatesh, B., Sadasivam, G., Khan, M.A., 2000. A new optimal reactive power scheduling method for loss minimization and voltage stability margin maximization using successive multi-objective fuzzy LP technique. *IEEE Trans. Power Syst.* 15 (2), 844–851.
- Viswanadha Raju, G.K., Bijwe, P.R., 2008. An efficient algorithm for minimum loss reconfiguration of distribution system based on sensitivity and heuristics. *IEEE Trans. Power Syst.* 23 (3), 1280–1287.
- Vitorino, R.M., Neves, L.P., Jorge, H.M., 2000. Network reconfiguration to improve reliability and efficiency in distribution systems. *IEEE*.
- Vlachogiannis, J.G., Hatzigiorgiou, N.D., Lee, K.Y., 2005. Ant colony system-based algorithm for constrained load flow problem. *IEEE Trans. Power Syst.* 20 (3), 1241–1249.
- Vovos, P.N., Harrison, G.P., Wallace, A.R., Bialek, J.W., 2005. Optimal power flow as a tool for fault level-constrained network capacity analysis. *IEEE Trans. Power Syst.* 20 (2), 734–741.
- Vovos, P.N., Kiprakis, A.E., Wallace, A.R., Harrison, G.P., 2007. Centralised and distributed voltage control: Impact on distributed generation penetration. *IEEE Trans. Power Syst.* 22 (1), 476–483.
- Wagner, T., Chikhani, A., Hackman, R., 1991. Feeder reconfiguration for loss reduction: an application of distribution automation. *IEEE Trans. Power Deliv.* 6, 1922–1933.
- Walid, El-K., Hegazy, Y.G., Salama, M.M.A., 2005. An integrated distributed generation optimization model for distribution system planning. *IEEE Trans. Power Syst.* 20 (2).
- Walid, El-K., Hegazy, Y.G., Salama, M.M.A., 2006. Investigating distributed generation systems performance using Monte Carlo simulation. *IEEE Trans. Power Syst.* 21 (2).
- Wall, S.R., 2001. Performance of inverter interfaced distributed generation. In: IEEE/Power Eng. Soc. Transm. Distrib. Conf. Expo, pp. 945–950.
- Walling, R.A., Saint, R., Dugan, R.C., Burke, J., Kojovic, L.A., 2008. Summary of distributed resources impact on power delivery systems. *IEEE Trans. Power Deliv.* 23 (3), 1636–1644.
- Wang, C., Hsshem, M.N., 2004. Analytical approaches for optimal placement of distributed generation sources in power system. *IEEE Trans. Power Syst.* 19 (4).
- Wang, C., Nehrir, M.H., 2002. Analytical approaches for optimal placement of distributed generation sources in power system. *IEEE Trans. Power Syst.* 2, 719–724.
- Wang, C., Nehrir, M.H., 2004. Analytical approaches for optimal placement of distributed generation sources in power systems. *IEEE Trans. Power Syst.* 19 (4), 2068–2076.
- Wang, L., Singh, C., 2008. Reliability constrained optimum placement of reclosers and distributed generators in distribution networks using an ant colony system algorithm. *IEEE Trans. Syst. Man Cyber. C. Appl.* 38 (6), 757–764.
- Lu, Wang, Suleiman, S., Andy, C., 2008. Optimal decentralized coordination of electric vehicles and renewable generators in a distribution network using a search technique, Vol. 98, pp. 474–487.
- Warren, C.A., Ammon, R., Welch, G., 2006. A survey of distribution reliability measurements practices in the US. *IEEE Trans. Power Deliv.* 14 (1), 250–258.
- Wenger, H.J., Hoff, T.E., Farmer, B.K., 1994. Measuring the value of distributed photovoltaic generation: Final results of the Kerman grid support project. In: 1st IEEE World Conf. and Exhib. on Photovoltaic Solar Energy Conversion, WCPEC, Honolulu, HI, pp. 5–9.
- Willis, H.L., 1997. Power distribution planning. In: Reference Book. Marcel Dekker, New York.
- Willis, H.L., 2000a. Analytical methods and rules of thumb for modeling DG-distribution interaction. In: IEEE Power Eng. Soc. Summer Meeting, pp. 1643–1644.
- Willis, H.L., 2000b. Analytical methods and rules of thumb for modelling DG-distribution interaction. In: Proc. 2000 IEEE Power Engineering Society Summer Meeting, Vol. 3, pp. 1643–1644.
- Willis, H.L., Northcote, G., 1985. Comparison of several computerized distribution planning methods. *IEEE Trans. Power App. Syst.* 104 (1), 233–240.
- Willis, H.L., Tram, H., Engel, M.V., Finley, F., 1995. Optimization applications to power distribution. *IEEE Comput. Appl. Power* 8 (4), 12–17.
- Willis, H.L., Trans, H., Engel, L., 1996. Selecting and applying distribution optimization methods. *IEEE Comput. Appl. Power* 9 (1), 12–17.
- Wu, Y.K., Lee, C.Y., Liu, L.C., Tsai, S.H., 2010. Study of reconfiguration for the distribution system with distributed generators. *IEEE Trans. Power Deliv.* 25 (3), 1678–1685.
- Xu, Ding, Girgis, A.A., 2001. Optimal load shedding strategy in power systems with distributed generation. In: Power Engineering Society Winter Meeting, Vol. 2. IEEE, pp. 788–793.

- Yang, L., Guo, Z., 2008. Comprehensive optimization for energy loss reduction in distribution networks. In: Proceedings of the IEEE PES general meeting. 1–8.
- Yassami, H., Moeini, A., Rafiei, S.M.R., 2011. Optimal distributed generation planning considering reliability, cost of energy and power loss. *Sci. Res. Essays* 6 (9), 1963–1976.
- Yiming, M., Miu, K.N., 2003. Switch placement to improve system reliability for radial distribution systems with distributed generation. *IEEE Trans. Power Syst.* 18(4), 1346–1352.
- Yokoyama, R., Bae, S.H., Morita, T., Sasaki, H., 1998. Multiobjective optimal generation dispatch based on probability security criteria. *IEEE Trans. Power Syst.* 3, 317–324.
- Yun, S.Y., Oh, J.H., Rim, S.J., Kim, J.C., 2000. Mitigation of voltage sag using feeder transfer in power distribution system. In: Proc. IEEE Power Eng. Soc. Summer Meeting, Vol. 3, pp. 1421–1426.
- Zangeneh, A., Jadid, S., Rahimi-Kian, A., 2009. Normal boundary intersection and benefit-cost ratio for distributed generation planning. *Eur. Trans. Elect. Power.* 1430–1440.
- Zhang, D., Fu, Z., Zhang, L., 2008. Joint optimization for power loss reduction in distribution system. *IEEE Trans. Power Syst.* 23 (1), 161–169.
- Zhang, F., Cheng, C.S., 1997. A modified Newton method for radial distribution system power flow analysis. *IEEE Trans. Power Syst.* 12 (1), 389–397.
- Zhou, Q.Q., Shirmohammadi, D., Edwin, L.W., 1997. Distribution feeder reconfiguration for operation cost reduction. *IEEE Trans. Power Syst.* 12, 730–735.
- Zhu, J.Z., 2002. Optimal reconfiguration of electrical distribution network using the refined genetic algorithm. *Electr. Power Syst. Res.* 62 (1), 37–42.
- Zhu, D., Broadwater, R.P., Tam, K.S., Seguin, R., Asgeirsson, H., 2006. Impact of DG placement on reliability and efficiency with time-varying loads. *IEEE Trans. Power Syst.* 21 (1), 419–427.
- Zhu, Y., Tomsovic, K., 2002. Adaptive power flow method for distribution systems with dispersed generation. *IEEE Trans. Power Deliv.* 17 (3), 822–827.
- Zong, W.G., 2009. *Music-Inspired Harmony Search Algorithm: Theory and Applications*. Springer.