

A Service of

ZBW

Leibniz-Informationszentrum Wirtschaft Leibniz Information Centre for Economics

Fitiwi, Desta; Lynch, Muireann Á.

# Working Paper Climate policy costs of spatially unbalanced growth in electricity demand: The case of datacentres

ESRI Working Paper, No. 657

**Provided in Cooperation with:** The Economic and Social Research Institute (ESRI), Dublin

*Suggested Citation:* Fitiwi, Desta; Lynch, Muireann Á. (2020) : Climate policy costs of spatially unbalanced growth in electricity demand: The case of datacentres, ESRI Working Paper, No. 657, The Economic and Social Research Institute (ESRI), Dublin

This Version is available at: https://hdl.handle.net/10419/237929

#### Standard-Nutzungsbedingungen:

Die Dokumente auf EconStor dürfen zu eigenen wissenschaftlichen Zwecken und zum Privatgebrauch gespeichert und kopiert werden.

Sie dürfen die Dokumente nicht für öffentliche oder kommerzielle Zwecke vervielfältigen, öffentlich ausstellen, öffentlich zugänglich machen, vertreiben oder anderweitig nutzen.

Sofern die Verfasser die Dokumente unter Open-Content-Lizenzen (insbesondere CC-Lizenzen) zur Verfügung gestellt haben sollten, gelten abweichend von diesen Nutzungsbedingungen die in der dort genannten Lizenz gewährten Nutzungsrechte.

#### Terms of use:

Documents in EconStor may be saved and copied for your personal and scholarly purposes.

You are not to copy documents for public or commercial purposes, to exhibit the documents publicly, to make them publicly available on the internet, or to distribute or otherwise use the documents in public.

If the documents have been made available under an Open Content Licence (especially Creative Commons Licences), you may exercise further usage rights as specified in the indicated licence.



# WWW.ECONSTOR.EU

# Working Paper No. 657

# March 2020

# Climate policy costs of spatially unbalanced growth in electricity demand: the case of datacentres

# Desta Fitiwi<sup>1</sup> and Muireann Á. Lynch<sup>1\*</sup>

*Abstract:* We investigate the power system implications of the anticipated expansion in electricity demand by datacentres. We perform a joint optimisation of Generation and Transmission Expansion Planning considering uncertainty in future datacentre growth under various climate policies. Datacentre expansion imposes significant extra costs on the power system, even under the cheapest policy option. A renewable energy target is more costly than a technology-neutral carbon reduction policy, and the divergence in costs increases non-linearly in electricity demand. Moreover, a carbon reduction policy is more robust to uncertainties in projected demand than a renewable policy. High renewable targets crowd out other low-carbon options such as Carbon Capture and Sequestration. The results suggest that energy policy should be reviewed to focus on technology-neutral carbon reduction policies.

*Keyword(s): Datacentres; generation expansion planning; transmission expansion planning; climate policy; renewable energy* 

#### \*Corresponding Author: muireann.lynch@esri.ie

Acknowledgements: Desta Fitiwi acknowledges funding from Science Foundation Ireland (SFI) under the SFI Strategic Partnership Programme Grant number SFI/15/SPP/E3125. Muireann Lynch acknowledges funding from the ESRI's Energy Policy Research Centre. The opinions, findings and conclusions or recommendations expressed in this material are those of the authors and do not necessarily reflect the views of the Science Foundation Ireland. We are grateful to ESRI seminar participants for useful comments and to EirGrid for providing much of the data necessary to complete this study, along with invaluable insights and advice. Disclaimers: ESRI working papers are not ESRI reports. They represent un-refereed work-in-progress by researchers who are solely responsible for the content and any views expressed therein. Any comments on these papers will be welcome and should be sent to the author(s) by email. Papers may be downloaded for personal use only.

<sup>&</sup>lt;sup>1</sup> Economic and Social Research Institute, Dublin

# 1 Introduction

The installed capacity and power consumption of datacentres has grown at an unprecedented rate in recent years [23]. This is due to ever-increasing creation, storage and utilisation of digital data. The future demands on the electricity system from datacentres are uncertain, not least due to new advances in energy efficiency within datacentres. The majority of the research on the topic of energy consumption by datacentres to date has focused on the potential for efficiency gains and demand reductions from the datacentres themselves [30, 6, 26, 8, 17, 36, 35, 5, 7], as well as the capacity for datacentres to exploit some flexibility in the timing of their electricity demand [40]. The EU's Joint Research Council has also produced a code of best practice in energy efficiency for datacentres [1] in an effort to facilitate voluntary participation in energy efficiency efforts by datacentre owners and operators. There is, however, a dearth of research on the impacts of datacentre growth on the electrical power system itself.

The profile of demand growth from datacentres is distinct from other sources of demand growth. Electricity demand in general is driven by both population and economic activity, but tempered by advances in energy efficiency. Future demand growth is likely to be driven primarily by electrification of the heating and transport sectors, and is therefore spatially dispersed broadly in line with the population. Datacentre demand, in contrast, is spatially concentrated, as datacentre owners generally require that their facilities be located within a particular geographic area, due to the requirements of digital network design. Demand growth from datacentres is therefore spatially unbalanced, which has significant implications both for the optimal location of the electricity generation and transmission assets of the power system, and for optimal decarbonisation pathways and policies.

Decarbonisation policy in Europe has been driven to date by a mix of specific targets for emissions reduction, energy efficiency and renewable generation [16]. Because using multiple instruments to achieve a policy objective tends to be sub-optimal [33], these overlapping targets will lead to a final energy and technology portfolio that is no cheaper, and possibly more costly, than the least-cost policy that targets emissions reduction alone. For example, some low carbon technologies, such as nuclear power or carbon capture and sequestration (CCS), can aid in meeting a carbon reduction target, but not a renewable generation target. Any carbon abatement solution that can be arrived at under a policy mix that includes targets for emissions, renewable energy and energy efficiency can therefore also be arrived at by a policy that targets emissions alone, but the converse is not necessarily true.

The extra costs of employing multiple differentiated climate targets has been considered in the literature already, for example in [4] in the case of the EU and in [41] in the case of the United States. [25] also points out that carbon reduction policies may lead to a more diverse electricity generation portfolio than a renewable generation policy. Furthermore, [11] finds that policies that explicitly target increased renewable energy can negatively affect the carbon market, resulting in favourable conditions for high-emissions technologies. This can be partly mitigated by combining renewable policy with carbon policy [3]. However, none of these studies quantify the costs and benefits of various climate policies given new spatially unbalanced electricity demand profiles. This gap in the literature motivates our contribution.

The environmental impact of the information and communication technology (ICT) sector has received some attention in the literature [38, 39]. From a global perspective, the sector is currently responsible for 3.5% of the greenhouse gas emissions emitted worldwide [2]. However, this is expected to reach approximately 15% in the coming decade or so, overtaking the shipping and the aviation sectors in terms of carbon footprint. Datacentres are expected to account for almost half of this, and are projected to consume more than one fifth of electrical power produced globally.

Many companies have located or plan to locate their European datacentres in Ireland,

due in part to its temperate climate and strategic location on the global map [22]. Irish government policy is also favourably inclined towards datacentres, seeing the ICT industry as a key driver in the Irish economy [27]. The Irish transmission system operator Eir-Grid therefore estimates that electricity demand from datacentres will account for 75% of electricity demand growth over the next decade, increasing the total share of electricity demand accounted for by datacentres from 2% in 2017 to a possible 36% by 2030 [10]. New datacentres are expected to locate in areas where the power network infrastructure is already under stress. Furthermore, Ireland is a small island power system with low levels of interconnection to Great Britain, and Ireland has targets to source 70% of electricity from renewable sources by 2030, both of which bring about extra challenges for power system planning and operation. The island of Ireland is therefore a useful test case for examining the power system impacts of spatially unbalanced electricity demand growth from datacentres. We model the possible effects of two alternative approaches to climate policy, namely a target for renewable electricity generation and a target for carbon emissions reduction. We also consider the impact of decentralising the datacentres, dispersing them across the country according to the capacity of the digital network, rather than concentrating them in Dublin, the capital city, as is currently envisaged. Dublin currently experiences high electricity grid congestion, and so increasing demand in this region adds particular strain on the transmission system.

The analysis performed in this article takes the form of Generation Expansion Planning (GEP) and Transmission Expansion Planning (TEP) models, both of which calculate the optimal investment in the electric power system given the need to ensure reliable electricity supply. GEP determines the optimal type, size and location of electricity generation investments, such as coal, gas, wind and solar, while TEP determines optimal investments in the electricity transmission network, comprising cables and transformers. GEP and TEP models seek to minimise the cost of the system, identifying the optimal power system under the assumption of perfect competition, or alternatively, assuming that a benign social planner is making all investment and operation decisions. As the share of electricity generated from variable renewable energy sources, such as wind and solar, increases, the TEP problem in particular increases in complexity. The transmission system must be planned in such a way as to transport electricity generated from large power stations located at a small number of strategically chosen locations.

Many datacentre companies seek to invest in renewable power themselves in order to offset the climate implications of datacentre demand: see for example [37, 15, 28]. However, the least cost analysis undertaken in this research makes no assumptions regarding ownership of the electricity generation investments themselves. Furthermore, the transmission system requirements that arise from datacentre demand and renewable investment remain unaltered if the renewable investment is undertaken by the datacentre companies themselves or by other energy companies. Therefore the least-cost analysis undertaken here is not affected by these actions, although the final price paid by consumers may be different.

In summary, this work undertakes an analysis of the power system impacts of spatiallyconcentrated increases in electricity demand from datacentres, subdivided into generation and transmission impacts, by means of a case study on the island system of Ireland. In order to account for the uncertainty in future datacentre location and demand growth, we consider four different scenarios, designated as "high demand", "moderate demand", "distributed demand" and "low demand" scenarios. Each case is considered under four different renewable generation policy targets and four different corresponding carbon reduction policy targets. In this manner we can distinguish between the marginal effects of both increased datacentre demand and increased stringency of policy targets on the power system.

The various policy alternatives yield widely varying results in terms of the final set of

generation technologies. Furthermore, the divergence in costs between a carbon reduction policy and a renewable generation policy increases non-linearly in datacentre demand. Optimally locating the datacentres along the fiber optics corridor has a significant impact on the transmission system investment, but has only a small effect on total costs. The results suggest that renewable energy targets are a significantly inferior policy to technologyneutral decarbonisation targets given the increased electricity demand from datacentres and suggest that Irish and EU energy policy should therefore be amended.

The remainder of this paper is structured as follows. Section 2 outlines the methodology employed in the current study. Data and assumptions are presented in section 3. Numerical results are provided in section 4 while section 5 covers a broad discussion of the results and concludes.

# 2 Methodology: the ENGINE model

To perform the analysis in the current paper, we use the Electricity Network and Generation INvEstment (ENGINE) model, partly described in [13]. The ENGINE model determines a joint optimisation of the Generation Expansion Planning (GEP) and Transmission Expansion Planning (TEP) problems in a least-cost manner, considering a number of technical, economic and environmental constraints. The model formulates these two problems using stochastic programming, which determines the optimal set of decisions under both long term and short term uncertainty. In this case, the ENGINE model considers several possible exogenously-determined long term realisations of demand from datacentres, and determines one optimal set of generation and transmission investments taking the various possible demand pathways into account. ENGINE also considers short term uncertainty in demand on an hour to hour basis, as well as uncertainty in the output of renewable power generation.

ENGINE is a spatial model, determining the optimal investment at each transmission node on the Irish grid (rather than determining the optimal investment for the whole island but without specifying the location of individual components). ENGINE also considers the optimal flow of power from one transmission node to the next, respecting physical constraints that are governed by Kirchoff's Laws. The model therefore respects voltage constraints as well as the constraints that govern the balance of supply and demand at each transmission node in real time. A simplified version of the ENGINE model is outlined in section A, in the Appendix.

# 3 Power system data and inputs

We use the 2017 power system of the island of Ireland for this analysis, described in detail in [13]. This system has a transmission network aggregated at 110 kV and higher, covering the entire Irish island. Data and further details of the system can be found in [9]. The transmission nodes that are candidate nodes for renewable power investment are shown in Figure 1.

We consider the evolution of the power system out to 2030, with three decision stages at the years 2020, 2025 and 2030. We consider carbon prices of 20, 25 and  $30 \in /tCO_2$ for 2020, 2025 and 2030, respectively, in line with the carbon price projections in [34]. However, we acknowledge that carbon prices could be higher than these figures.

Power system operation becomes increasingly complex as the amount of renewable power on the system at any point in time increases. For this reason, power system operators often impose a limit on the non-synchronous penetration at each point in time. Non-synchronous penetration is defined as the ratio of generation from variable renewable power sources plus electricity imported via direct current interconnectors to demand plus electricity exported via direct current interconnectors. In other words, it is the total demand, less electricity exported, that is met by renewables and/or imported electricity.



Figure 1: Candidate connection nodes of variable renewable generation (see green dots)

In our analysis, we impose a system non-synchronous penetration (SNSP) limit of 75%. We do not include interconnection to other electricity systems in our analysis as we are particularly interested in examining the impacts of datacentres in an isolated system. It is however important to note that while some of our results may find that the SNSP is almost equivalent to the percentage of demand met by renewable generation, in reality, total power generation can be higher (lower) than the total electricity demand, with the surplus (deficit) being exported (imported).

Existing generation is retired according to an exogenously-determined schedule, while investments in new thermal power plants are assumed to be in brownfield sites. The technical and economic assumptions regarding generation and storage technologies are presented in Table 3 in the Appendix. In order to ensure the model is tractable, the variable capturing investment in all generation and storage technologies is continuous, rather than discrete. The capital cost per MW of generation capacity is assumed to be fixed over the study, with the exception of storage, for which we assume 5 and 10% cost reductions in 2025 and 2030, respectively. This is because battery storage is a new and evolving technology, and the cost is expected to decrease over time [20].

#### 3.1 Demand and climate policy scenarios

The future pattern of expansion of datacentres is unknown, so we construct several scenarios to examine a range of possibilities. The transmission system operator, EirGrid, has four different demand projections [10]. These are shown in Figure 2. EirGrid denotes their scenarios as "Slow change", "Steady evolution", "Consumer action" and "Low carbon living". There are several differences between the EirGrid scenarios, concerning for example electric heating and transport, but the relevant variable for our purposes is the rollout of datacentre demand, the primary driver of increases in electricity demand. EirGrid assigns no probabilities to their projections, but historical trends suggest that EirGrid's highest demand scenario is unlikely to be realised, as it would require that all planned datacentre projects would be developed. Historically, at least some of the planned demand sources from large end-user sectors have failed to materialise.

The primary difference between our scenarios arises from the probability we assign to EirGrid's own four projections. We designate our scenarios as "High", "'Moderate", "Distributed" and "Low". In our "High" case, we assume EirGrid's four demand growth scenarios are equally probable. In our "Moderate" case, we assign greater probability weights of 40% to EirGrid's "Slow change" and "Steady evolution" projections, a 15% probability to their "Consumer action" projection and a probability of 5% to their "Low



Figure 2: EirGrid's datacentre growth projections over the planning horizon

Carbon Living" projection. Our "Distributed" case uses the same datacentre projections as the "Moderate" case, but assumes that 30% of the datacentres will be located according to the capacity of the digital network, shown in Figure 3, rather than concentrating all datacentres in Dublin. Finally, our "Low" case assumes that the datacentre capacity is frozen at the 2020 levels with no new datacentre investments taking place in the remaining years of the considered horizon, and assigns a probability of 25% to the other drivers of demand within each of the EirGrid scenarios (eg, electrification of heat and transport), which have a small impact compared to datacentre expansion. This case allows us to quantify the ramifications of increased electricity demand due to datacentres over the coming decade against a "business as usual" benchmark. These scenarios are summarised in Table 1.



Figure 3: Optimal locations of datacentres

<b>D</b> 1 .	$\operatorname{Prot}$	pability assigne	d to EirGrid	scenario	$\mathbf{S} \mathbf{patially}$
Demand scenario	Slow Change	Steady Evo- lution	Consumer Action	Low Carbon Living	dispersed datacentres
High	25%	25%	25%	25%	No
Moderate	40%	40%	15%	5%	No
Distributed	40%	40%	15%	5%	Yes
Low	25%	25%	25%	25%	NA

Table 1: Construction of different demand scenarios

Note that none of our scenarios considers the extreme case of the highest datacentre demand projected by EirGrid occurring with 100% probability. We essentially consider the probability of this eventuality to be so low as to render its examination unnecessary, based on the historical ratio of planned to actual investment by large industrial electricity users. However, should this level of datacentre investment take place, the power system impacts will be even greater than those modelled here.

The demand cases above are considered under two different climate policies, namely a renewable policy and a carbon policy. Under the renewable policy, we include a constraint that specifies a minimum percentage of generation that must come from renewable sources in 2030. Under the carbon policy, we instead include a technology-neutral constraint that limits the carbon intensity of the power system. The limit chosen corresponds to the carbon intensity realised under the renewable policy. Thus, both scenarios meet the same carbon target, but with (potentially) different technology and generation mixes, and the carbon policy will be cheaper than the corresponding renewable policy, at least weakly.

The renewable targets considered are 55%, 60%, 65% and 70% by 2030, with intermediate 2025 targets of 47% in the first case and 55% in all other cases. Therefore, we consider thirty-two scenario combinations in total, for two different climate policies, four different climate targets and four different demand scenarios (see Table 2).

Table 2: Climate and demand scenarios considered. Each of these scenarios is run for four different climate targets.

	Var	riables
Cases	Climate policy	Demand growth
$\begin{array}{c}1\\2\\3\\4\end{array}$	Renewable	Low demand Distributed demand Moderate demand High demand
5 6 7 8	Carbon reduction	Low demand Distributed demand Moderate demand High demand

## 4 Numerical Results

#### 4.1 Total and marginal costs of different policy and demand scenarios

The "Low" datacentre demand scenario with a carbon reduction policy is the lowest-cost scenario, and so we first consider the percentage increase in total costs for all other scenarios relative to this base case. Figure 4 presents these cost increases. The increased demand from datacentres increases costs substantially. Renewable targets are also more expensive than their carbon reduction counterparts, consistent with [24]. The "High" demand case

is roughly 6% more expensive than the "Low" case under all carbon reduction policies, but the differential between the "Low" and "High" cases increases from about 9% under the lowest renewable policy to 15% under the highest renewable policy. In other words, a renewable energy policy causes the electricity system costs due to datacentres to increase from 6% to 9%-15%, depending on the level of datacentre demand. The costs of a carbon reduction policy therefore increase linearly in demand, while the costs of a renewable policy increase non-linearly. This bolsters the case for technology-neutral climate policies in the face of uncertainty regarding future demand levels. Increasing the spatial distribution of demand (the "distributed" case) has only a very small impact on the total costs, under both climate policies.



Figure 4: A comparison of NPV differentials under both climate policies.

To further explore these results, figure 5 shows the shadow cost of both climate policies under the various demand growth levels. The shadow costs are defined as the increase in total costs that results from a marginal increase in the stringency of the policy constraint, and can be interpreted as a measure of abatement cost. Under both climate policies, the shadow cost of the climate policy increases non-linearly as the policy target becomes more stringent. The abatement cost curves for the renewable policies lie above the curves for the carbon policies for all demand scenarios. However, the abatement cost curves under the carbon policy diverge at higher carbon reduction policies, while for the renewable policy they converge at higher levels of renewable integration. The incremental cost of renewable integration at high renewable levels therefore decreases in sensitivity to increased demand from datacentres, while the opposite is true for the abatement cost of carbon.

#### 4.2 Generation and Network Investments

We now consider the generation and network investment decisions that drive the total costs outlined above. Figure 6 compares the final investments in generation and storage under the least stringent climate policies (i.e. the 55% RES-E and its equivalent carbon reduction target). In general, the renewable policy leads to an expansion mix dominated by onshore wind, photovoltaic (PV) solar and new Combined Cycle Gas Turbines (CCGTs). In contrast, the carbon policy sees investment in carbon capture and sequestration (CCS) technologies, with very low levels of solar and storage and no offshore wind investment. High renewable targets therefore crowd out other non-renewable, low carbon options such as CCS.

The investment in CCGTs under the two policies is of particular interest: there is higher investment in CCGTs under the renewable policy versus the carbon policy. This suggests that the variability in wind and solar output gives rise to shortfalls in supply that are sufficient to require investment in conventional generation technologies, but insufficient



Figure 5: Comparison of abatement costs between the climate policy types and targets.

to justify the increased cost of investment in CCS. This observation can be explained in terms of capacity factors, where the capacity factor is defined as the total generation from the technology compared to its maximum potential generation. A technology that spends a high proportion of time operating at partial capacity, or not operating at all, has a lower capacity factor. The variable renewable output decreases capacity factors of CCGTs, and therefore induces investment in non-CCS CCGTs only.

The lower capacity factors under the renewable policy are also evident in 6: the renewable policy sees higher total installations in generation capacity compared to the carbon policy. Even with substantial investment in storage, higher absolute levels of capacity with a lower average capacity factor are required under the renewable scenario.



Figure 6: Optimal power generation and storage expansion under each climate policy.

#### 4.2.1 Impact of increased demand from datacentres

Figure 7 shows the ratio of the increase in generation capacity investment (in MW) to the increase in datacentre capacity (in MW). The increase in generation capacity relative to demand is far higher under the renewable policy than the carbon policy. This is again due to the lower capacity factor under the renewable policy.



Figure 7: Impact of marginal increase in demand on generation and storage expansion.

Here, we find that the capacity to demand ratio of the more stringent carbon policy is slightly lower than the less stringent carbon policy, while the opposite is the case for the renewable policies. In other words, the total capacity investment required to meet new demand is slightly lower under a more stringent carbon reduction target than under a less stringent target. This result is driven by increased capacity factors for CCS technologies. In particular, because demand from datacentres does not vary over the course of the day, datacentre demand can be met in a cost-effective low-carbon manner by CCS technologies, whose output can be kept constant over the course of the day. The variable nature of renewables, on the other hand, is less complementary to the load profile of datacentres.

Generally, generation investment increases nonlinearly in demand. This effect is more pronounced under low climate policy targets. For instance, under the 55% renewable target, about 3.3 MW of new generation capacity (including storage) is needed for every MW increase in demand under the "High demand" case, with only 2.6 MW and 2.8 MW required for the "Low" and "Medium" demand cases, corresponding to 15% and 21% reductions, respectively. Figure 7 also indicates that these effects are much lower under carbon reduction targets. These figures indicate that overestimating future demand, and over-specifying the system as a result, is particularly costly under a renewables policy. The carbon reduction policy is therefore more robust to uncertainty in future demand.

Figure 8 shows the locational marginal prices, calculated as the marginal cost of increasing demand, at each node where datacentres are located for eight regions within Ireland, averaged across all time periods. In general, prices are lower under the carbon policies relative to the renewable policies. Prices are fairly stable across regions, with the exception of the Dublin region, where most of the datacentres are located. Several nodes have extremely high prices, with the highest occurring under the high demand scenario with a low carbon policy target. This is a counterintuitive result, and is driven by the fact that the ENGINE model allows for some electricity demand to remain unmet, if the cost of meeting demand would be prohibitively high. Therefore, for some hours, the cost minimising-solution is to disconnect some customers, failing to meet all electricity demand, and incur a high penalty cost which is known as the Value of Lost Load (VOLL). The VOLL is very high because policy makers place a high value on reliable electricity supply, and so system operators only disconnect consumers as a last resort. The lowest carbon policy sees some hours where it is optimal to fail to meet demand rather than to invest in more generation technologies. The more stringent carbon policy scenarios lead to higher generation investment in CCS, reducing the number of hours where it is optimal to shed demand, and therefore reducing prices.



Figure 8: Marginal cost of increase in demand. Acronyms: MID = Midland; ME = Mid-East; MW = Mid-West; SE = South-East; SW = South-West

#### 4.2.2 Regional impacts

Figures 9 and 10 show the regional distribution of generation and storage builds under the "low" and "high" demand scenarios for the least stringent renewable and climate policies, respectively.



Figure 9: Optimal generation and storage investment in MW by region under the renewable policy.



Figure 10: Optimal generation and storage investment in MW by region under the carbon reduction policy.

The renewable policy sees large amounts of wind investment in the west of the country, where wind speed levels are higher, and the high demand case also sees significant PV investment in Dublin where the majority of the datacentres are concentrated, and where network congestion is relatively high. Storage levels are also relatively dispersed regionally under the renewable policy.

The carbon reduction target, however, has thermal generation investment taking place at only three nodes, the existing brownfield site of Moneypoint in the MidWest, Northern Ireland (which has significant projected undercapacity) and a small amount in the Southwest. The regional pattern of investment therefore varies considerably under the different policies, but the pattern is similar under low and high demand, albeit at a different scale.

#### 4.3 Emissions

Figure 11 displays the increase in expected emissions for each case, relative to the lowest demand case under the carbon reduction policy. The increased demand from datacentres increases emissions by 5% in the "Moderate" case and by 8% in the "High" case. The decrease in emissions under the "Distributed" case is very small, suggesting that the scale rather than the location of the datacentres drives emissions.



Figure 11: Changes in expected emissions relative to the "Carbon, Low demand" case.

#### 4.4 Transmission network investment and costs

The ENGINE model identifies the investments in the transmission network that are required to ensure reliable supply at each node of the electricity network, including investments both in transmission wires and in transformer stations. The grid investment model does not rigorously account for security criteria, such as the criterion that the system must prove robust to the loss of any one transmission asset. Thus, the grid investment requirements arrived at by ENGINE can be considered as a lower bound on the transmission investments required by a risk-averse system operator. Figure 12 compares the aggregate capacity of transmission network investments under the lowest and highest targets of each climate policy.



Figure 12: A comparison of cumulative network capacity investments under both climate policies.

In general, the carbon policy leads to higher grid investments than the renewables policy, with a greater divergence under the lowest climate policy targets. The increased levels of storage under the renewable targets drive this result. Higher renewable penetration renders storage investment more economic, which means that excess generation can be stored at the transmission node in question, rather than being exported to another node. The stored energy can then be used to meet demand during high demand periods, rather than requiring that electricity be imported from another node. The reduction in requirements to import and export electricity reduces the requirement for transmission network investment. In short, storage and transmission can be considered as substitutes.

Optimally distributing datacentres according to the digital network capacity reduces grid investment needs under every scenario, but the effect is more pronounced under the renewable policy than under the carbon policy. Network investments in the "distributed" case are 21% lower than the "moderate demand" case under the carbon policy, and 39% lower under the renewable policy. This is driven by the fact that RES-E and storage have a higher spatial distribution than the CCS investment seen under the carbon policy, and so increasing the spatial distribution of datacentre demand has a greater impact on transmission investments under the renewable policy compared to the carbon policy.

Network investment costs for the renewable policy range between 0.7% (under the low demand scenario and 70% RES-E target) and about 1.4% (under the highest demand portfolio) of the total NPV. For the carbon policy, these figures are 1.5% and about 2%, respectively. These figures explain why the difference in total costs between the "moder-ate" and "distributed" cases is quite low, under every set of inputs, and indicate that the scope for reducing power system impacts of datacentre demand by changing their spatial distribution is limited. However, the transmission network expansion is still of particular relevance to policy makers, for two reasons. The first is that datacentres themselves will

cover at least part of the extra generation system costs they give rise to via their electricity payments. Transmission system costs, on the other hand, are bourne by all electricity consumers, and are not necessarily linked to electricity usage. Transmission system costs that are driven by datacentre demand are therefore of interest over and above the generation costs. Secondly, the public acceptance of electricity system assets is a significant challenge for policy makers. The ENGINE model determines the economic cost of transmission assets only, but policymakers may see extra utility in reducing transmission system investments over and above the economic saving, if this decreases the costs of public acceptance.

The divergence again increases as the target becomes more stringent: the difference in network investment in the high versus the low demand scenarios is 17% under the least stringent renewable policy, rising to 39% under the most stringent. The most stringent carbon reduction policy however sees an 89% increase in transmission asset investments in the high demand scenario relative to the lowest demand. This again underlines the substitutive nature of transmission and storage.

#### 4.5 Consumer and producer analysis

The changes in system costs may affect both consumers and producers. Consumers are affected by changes in electricity prices, while producers are affected by changes both in prices, which affect their revenues, and in their fixed and variable production costs. We therefore analyse the impact increased datacentre demand and/or climate policy can have on consumer costs and producer profits.

Electricity demand is assumed to be inelastic, in that it does not vary as prices increase or decrease. This is representative of the majority of electricity consumers, and is a common assumption in the literature. Consumer costs are therefore calculated by the sumproduct of hourly demand and electricity prices at each transmission node, within a given year. Producer profits are calculated by subtracting the costs of power generation (including emission costs) from the sumproduct of hourly prices and actual power generation for a given year.

Figures 13 and 14 compare the percentage changes in consumer costs and producer profits for the various cases, respectively. As before, these are expressed relative to those recorded under the case of low demand outlook and carbon policy. Both consumer costs and generator surpluses increase nonlinearly with increasing demand. Furthermore, this impact is much more pronounced under the renewable policy than carbon policy (especially at higher demand levels). It should however be noted that, regardless of the climate policy, the absolute value of both consumer costs and generator surpluses show progressive declines with increasing stringency of climate policy targets, but with the greatest declines under the lower demand scenarios. The percentage difference between the low and high demand scenarios therefore increases.

Figures 13 and 14 also show that an optimal allocation of datacentres across the island slightly mitigates the impacts.

These results suggest that the impact of increased demand from datacentres is bourne by consumers via increased electricity bills. The profits of generation companies, however, are positively impacted both by increased demand and by increased stringency of climate targets. Furthermore, our analysis ignores the impact of subsidisation of technologies such as wind and solar, which would facilitate an even greater transfer of resources from consumer to producer. However, the analysis also ignores actions that could reduce producer profits and consumer costs. These include responsive demand from consumers, who may choose to reduce their electricity usage during high price periods, as well as action by government to place a cap on electricity prices. Finally, datacentre owners themselves are included in the consumer group, and so at least part of the increased consumer costs between datacentre owners and other consumer groups will be examined in further research.



Figure 13: Changes in consumer costs relative to the "Carbon, Low demand" case



Figure 14: Changes in producer surplus relative to the "Carbon, Low demand" case

# 5 Discussion and conclusions

The results outlined above have several common themes. Our finding that renewable policies are more expensive than technology-neutral decarbonisation policies accords with the literature, but the increased demand from datacentres augments and enhances this finding in several new respects.

First, the non-linear increase in costs under the renewable target compared to the carbon target is significant. This result appears to be driven primarily by the relatively low capacity factors of renewable generation, and the consequent lower capacity factors of thermal generation. The fact that CCS appears only in the carbon reduction policy shows how renewable technologies crowd out other low carbon technologies, and underlines the ability of policy to greatly alter the final technology portfolio, even under equal emission targets.

Second, the renewable policy is clearly more costly at higher levels of demand, and is therefore far more sensitive to overestimation of final demand. Given the considerable uncertainty in the future datacentre capacity, and indeed other sources of uncertainty in future demand, the case for a technology-neutral climate policy over a renewable policy is bolstered in this context.

Thirdly, the locational results show that the renewable policy leads to a far greater spatial dispersal of infrastructure compared to the carbon policy. The latter sees a few large scale investments in existing brownfield sites, while the former requires high investment in various regions. Given strong public opposition to renewable energy developments in Ireland and worldwide, this finding is of particular significance for policy-makers.

Conversely, the renewable policy sees a lower investment requirement in network assets, due to the fact that storage and transmission investment are substitutes. The impact of network investment on total costs is negligible, however. Furthermore, locating 30% of the demand outside of the Dublin region does little to mitigate the impacts of datacentre demand on system costs, suggesting that it is primarily the scale, rather than the location, of datacentre demand that drives the results. A reduction in transmission system investments does occur as a result of relocation of datacentre demand.

Finally, while both consumer costs and producer profits increase as datacentre demand increases, the effect is again non-linear, with the greatest impacts seen under the most stringent climate policies. This suggests that increased datacentre demand facilitates a transfer from consumers to producers, and this impact is magnified by adopting a renewable policy.

The ENGINE model minimises total costs, but does not model cost recovery by energy companies, which takes place by billing final energy users, including datacentres. The increase in total costs will be at least partially offset by the electricity payments made by datacentre companies themselves. Therefore, the electricity costs of other electricity consumers will not increase at the same rate as total system costs. However, given that electricity is billed on the basis of usage, this argument most likely holds in the case of variable costs such as generation and carbon costs. The fixed cost of transmission network investments are harder to apportion directly to the electricity users that gave rise to them, and is instead covered by all electricity users. The decomposition of the impacts of datacentre demand on different consumer groups is an important topic for future research.

Further limitations to this analysis include the fact that the ENGINE model is a longrun, least cost model, and some of the technical constraints of electricity generation are therefore neglected. Future work will consider more detailed short-run modelling that considers the operation of generation and transmission assets, but does not consider investment. The possibility for strategic behaviour by market participants has also been neglected in this analysis, but will be considered in future research.

Two policy-related points arise from this research. Firstly, our results suggest that Irish and EU energy policy should be reviewed, as a technology-neutral policy is significantly cheaper than a renewable target, particularly for consumers, and is also better able to withstand uncertainties in projected demand. Secondly, even under the lowest-cost policy, datacentres increase system costs significantly, by 6%, with an even greater increase in consumer costs. Given that the datacentres in question will store data for customers across Europe, there may be a carbon leakage argument to be made, namely that a portion of the emissions that arise due to electricity consumption from datacentres should be counted towards the national emissions of other countries. The feasibility of this policy will be explored in future research.

## A The ENGINE model

This appendix gives a simplified outline of the ENGINE model. The full model is described in [13].

The objective function of the ENGINE model, expressed in Equation 1, constitutes a sum of the net present values of five terms related to investment costs, variable costs, reliability costs, operation and maintenance and emission costs:

$$MinTC = TInvC + TMC + TEC + VOLL + TEmiC$$
(1)

TInvC denotes the NPV of total investment costs in new generation capacity, transmission and storage investments:

$$TInvC = \sum_{t \in \Omega^t} (1+r)^{-t} InvC_t^{gen}$$
<sup>(2)</sup>

where

$$InvC_t^{gen} = \sum_{g \in \Omega^g} \sum_{i \in \Omega^i} \frac{r(1+r)^{LT_g}}{(1+r)^{LT_g} - 1} IC_{g,i}(x_{g,i,t} - x_{g,i,t-1}); x_{g,i,0} = 0$$
(3)

 $IC_{g,i}$  represents the investment cost of generators,  $x_{g,i,t}$  is the investment variable of generator g,  $LT_g$  is the lifetime of generator g and r is the discount rate.

The second term, TMC, represents the net present value of fixed maintenance and operation costs of (new or existing) generators and of network components:

$$TMC = \sum_{t \in \Omega^t} (1+r)^{-t} \left( MntC_t^{gen} + MntC_t^{mtk} \right)$$
(4)

where  $MntC_t^{gen}$  is the maintenance costs of new and existing generators at each time stage:

$$MntC_t^{gen} = \sum_{g \in \Omega^g} \sum_{i \in \Omega^i} MC_g^N x_{g,i,t} + \sum_{g \in \Omega^g} \sum_{i \in \Omega^i} MC_g^E u_{g,i,t}$$
(5)

and  $MntC_t^{ntk}$  is the maintenance cost of an existing line. This cost is nonzero only if the corresponding utilisation variable u is nonzero:

$$MntC_t^{ntk} = \sum_{k \in \Omega^{el}} MC_k^E u_{k,t} + \sum_{tr \in \Omega^{E_{tr}}} MC_{tr}^E u_{tr,t}$$
(6)

TEC refers to the total cost of producing electricity in the system using both new and existing generators:

$$TEC = \sum_{t \in \Omega^t} (1+r)^{-t} (EC_t^{NG} + EC_t^{EG})$$
(7)

where

$$EC_t^{gen} = \sum_{s \in \Omega^s} \rho_s \sum_{w \in \Omega^w} \pi_w \sum_{g \in \Omega^g} \sum_{i \in \Omega^i} (\lambda_{g,s,w,t}^N P_{g,i,s,w,t}^N + \lambda_{g,s,w,t}^E P_{g,i,s,w,t}^E)$$
(8)

In other words, TEC denotes the variable costs of meeting the electricity demand i.e. the cost of power generation.

The fourth term in TC, VOLL, represents the total cost of unserved power in the system, i.e. the value of lost load or reliability cost:

$$VOLL = \sum_{t \in \Omega^t} (1+r)^{-t} ENSC_t \tag{9}$$

where

$$ENSC_t = \sum_{s \in \Omega^s} \rho_s \sum_{w \in \Omega^w} \pi_w \sum_{e \in \Omega^i} (\nu_{s,h}^P P_{i,s,w,t}^{PNS} + \nu_{s,h}^Q Q_{i,s,w,t}^{PNS})$$
(10)

and  $\nu_{s,h}^P$  and  $\nu_{s,h}^Q$  are penalty parameters corresponding to active and reactive power curtailments, respectively.

Finally, the term TEmiC calculates the total carbon emission costs in the system:

$$TEmiC = \sum_{t \in \Omega^t} (1+r)^{-t} (EmiC_t^{NG} + EmiC_t^{EG})$$
(11)

where

$$EmiC_t^{gen} = EmiC_t^{NG} + EmiC_t^{EG}$$
(12)

$$EmiC_t^{NG} = \sum_{s \in \Omega^s} \rho_s \sum_{w \in \Omega^w} \pi_w \sum_{q \in \Omega^g} \sum_{i \in \Omega^i} \lambda_{s,w,t}^{CO_2 e} ER_g^N P_{g,i,s,w,t}^N$$
(13)

$$EmiC_t^{EG} = \sum_{s \in \Omega^s} \rho_s \sum_{w \in \Omega^w} \pi_w \sum_{g \in \Omega^g} \sum_{i \in \Omega^i} \lambda_{s,w,t}^{CO_2 e} ER_g^E P_{g,i,s,w,t}^E$$
(14)

The objective function outlined above is minimised while respecting various constraints, which can be broadly classified as technical, economic, spatial and environmental constraints. For the full mathematical detail of the constraints, see [13].

Within the technical constraints, the model deploys Kirchnoff's current and voltage laws. Kirchnoff's current law states that the sum of all incoming flows to a node must equal the sum of all outgoing flows at any given time. Kirchnoff's voltage law, unlike the current law, is nonlinear and states that the sum of all voltages around a closed loop is equal to zero. This paper, however, linearises the non-linear expression of this law by making two practical assumptions, observed in the literature [12, 14]. The technical constraints also include boundary conditions of relevant system variables: power flows in each line should not exceed its maximum transfer capacity, network losses must be accounted for, active and reactive power production is constrained by the total capacity of each unit.

Economic constraints include logical constraints related to irreversibility of investment and budget constraints.

The investment planning is also subject to spatial constraints, depending on either the availability of resources, space or both. One example in this case is wind power, which requires the availability of both the primary energy source – wind speed – and space for its development.

Environmental constraints emanate from climate policy targets to abate greenhouse emissions. In this paper, there are two types of environmental constraints. One requires that a certain proportion of energy must be generated from renewable sources, while the other requires that the total carbon emissions from the system must be no greater than a predetermined target. The carbon target is set equal to the total carbon emissions observed under the renewable constraint, in order to ensure we compare like with like throughout our policy scenarios.

The model is executed in the Generic Algebraic Modelling System (GAMS). All simulations are carried out on a server with Intel Xeon E5-2630 dual processor clocking at 2.2 GHz and with 256 GB RAM.

#### Nomenclature

Indices and sets

$g/\Omega^g$	Index/set of all generators (existing and new)
$i,j/\Omega^i$	Index/set of all nodes
i'	Index for fictitious transformer nodes
$k/\Omega^k$	Index/set of all lines
$t/\Omega^t$	Index/set of all time stages
$tr/\Omega^{E_{tr}}$	Index/set of existing transformers
$s/\Omega^s$	Index/set of stochastic scenarios
$w, w'/\Omega^w$	Index/set of operational states
$\Omega^{RES}$	Set of all RES type power generators
$\Omega^{el}$	Set of existing lines

# Functions

$EC_t^{gen}$	Cost of energy generated by all generators $(\in)$
TC	Total system cost $(\in)$
TInvC	Total investment cost $(\in)$
TMC	Total maintenance cost $(\in)$
TEC	Total cost of power production $(\in)$
VOLL	Total cost of loss of load $(\in)$
TEmiC	Total cost of emissions $(\in)$
$EmiC_t^{NG}$	Cost of emissions from new generators $(\in)$
$EmiC_t^{EG}$	Cost of emissions from existing generators $(\in)$
$ENSC_t$	Expected cost of energy not served $(\in)$
$EC_t^{NG}$	Cost of power produced by new generators $(\in)$
$EC_t^{EG}$	Cost of power produced by existing generators $(\in)$
$MntC_t^{ntk}$	Maintenance cost of all lines and transformers $(\in)$
$MntC_t^{gen}$	Maintenance cost of all generators $(\in)$

# Variables

$P^N_{q,i,s,w,t}$	Power generated by new generator (MW)
$P_{q,i,s,w,t}^{E}$	Power generated by existing generator (MW)
$P_{i,s,w,t}^{PNS}$	Active power not served (MW)
$Q_{i,s,w,t}^{PNS}$	Active power not served (MVAr)
$x_{g,i,t}$	Generator investment variable (MW)

## Parameters

$ ho_s$	Probability of scenario
$\pi_w$	Snapshot weight
$\lambda_{s.w.t}^{CO_2e}$	Carbon price $(\in/tCO_2)$
$ER_q^N$	Emission rate of new generator $(tCO_2/MWh)$
$ER_a^E$	Emission rate of existing generator $(tCO_2/MWh)$
$\nu^P_{s,h}$	Penalty factor of unserved active power ( $\in$ /MW)
$\nu^Q_{s,h}$	Penalty factor of unserved reactive power ( $\in$ /MVAr)
r	Discount rate (%)
$\lambda_{q,s,w,t}^N$	Marginal cost of power production using new generator ( $\in$ /MWh)
$\lambda_{q,s,w,t}^E$	Marginal cost of power production using existing generator ( $\in$ /MWh)
$MC_k^E$	Maintenance cost of existing line $(\in)$
$u_{k,t}$	Availability of existing line
$MC_{tr}^E$	Maintenance cost of existing transformer $(\in)$
$MC_q^E$	Unit maintenance cost of existing generator $(\in)$
$MC_q^N$	Unit maintenance cost of new generator $(\in)$
$IC_{g,i}$	Unit investment cost of generator $(\in)$
$LT_g$	Lifetime of generator (years)
$u_{tr,t}$	Availability of existing transformer
$u_{q,i,t}$	Availability of existing generator

# **B** Generator and Storage Data

Table 3 shows the cost and operation assumptions of the generation technologies considered. Further assumptions for store so include a 00% round trip off signary a 10 year lifetime.

Further assumptions for storage include a 90% round-trip efficiency, a 10 year lifetime and an 80% depth of discharge [42, 31, 29].

### References

- Acton, M., Bertoldi, P., Booth, J., Flucker, S., Newcombe, L., Rouyer, A., Tozer, R., 2019. 2019 Best Practice Guidelines for the EU Code of Conduct on Data Centre Energy Efficiency, 71.
- Belkhir, L., Elmeligi, A., 2018. Assessing ICT global emissions footprint: Trends to 2040 & recommendations. Journal of Cleaner Production 177, 448-463. URL: https://linkinghub.elsevier.com/retrieve/pii/S095965261733233X, doi:10.1016/j.jclepro.2017.12.239.
- J., J., [3] Bird, L., С., W., Chapman, Logan, Sumner, Short, 2011.Evaluating renewable portfolio standards and carbon cap scenarios in the U.S. electric sector. Energy Policy 39,2573 - 2585. URL: http://www.sciencedirect.com/science/article/pii/S0301421511001054, doi:10.1016/j.enpol.2011.02.025.
- [4] Böhringer, C., Rutherford, T.F., Tol, R.S., 2009. The eu 20/20/2020 targets: An overview of the emf22 assessment. Energy economics 31, S268–S273.
- [5] Cioara, T., Anghel, I., Salomie, I., Antal, M., Pop, C., Bertoncini, M., Arnone, D., Pop, F., 2019. Exploiting data centres energy flexibility in smart cities: Business scenarios. Information Sciences 476, 392-412. URL: http://www.sciencedirect.com/science/article/pii/S0020025518305243, doi:10.1016/j.ins.2018.07.010.
- [6] Depoorter, V., Oró, E., Salom, J., 2015. The location as an energy efficiency and renewable energy supply measure for data centres in europe. Applied energy 140, 338-349.

- - E	Operation cost*	Emission rate	Investment cost	Cumu	llative cost	reductions (%)
Technology	(€/MWh)	(tCO2/MWh)	(M€/MW)	2020	2025	2030
Offshore wind	22.80	0.02	3.65	0.05	0.10	0.20
Onshore wind	13.00	0.02	1.40	0.05	0.10	0.20
Solar $PV$	11.40	0.05	1.50	0.05	0.10	0.20
Biomass	54.00	0.23	2.25	0.02	0.05	0.10
Coal	34.00	0.93	0.90	0.05	0.08	0.10
Coal with CCS	38.00	0.19	1.20	0.05	0.08	0.10
CCGT	40.00	0.37	0.90	0.05	0.08	0.10
CCGT with CCS	55.00	0.04	1.25	0.05	0.08	0.10
Hydro	10.50	0.01	ı	I	I	I
Gas oil fired	80.00	1.04	ı	I	I	I
Heavy fuel oil fired	100.00	0.77	ı	I	I	I
$\operatorname{Storage}$	5.00	0.00	1.00	0.00	0.05	0.10
* includes fuel costs	s but excludes emission	costs.				

Table 3: Parameter assumptions of generator and storage technologies [32, 19, 21, 18]

- [7] Deymi-Dashtebayaz, M., Valipour-Namanlo, S., 2019. Thermoeconomic and environmental feasibility of waste heat recovery of a data center using air source heat pump. Journal of Cleaner Production 219, 117-126. URL: http://www.sciencedirect.com/science/article/pii/S0959652619304408, doi:10.1016/j.jclepro.2019.02.061.
- [8] Ebrahimi, K., Jones, G., Fleischer, A., 2014. A review of data center cooling technology, operating conditions and the corresponding low-grade waste heat recovery opportunities. Renewable and Sustainable Energy Reviews 31. doi:10.1016/j.rser.2013.12.007.
- [9] EirGrid,2016.All-IslandTenYearTransmissionFore-castStatement2016.TechnicalReport.URL:http://www.eirgridgroup.com/site-files/library/EirGrid/All-Island-Ten-Year-Transmission
- [10] EirGrid, 2017. Tomorrow's Energy Scenarios 2017: Planning our Energy Future. Technical Report.
- R., Richstein, J.C., Hakvoort, R., De Vries, L., The [11] Fagiani, 2014.dvnamic impact of  $\operatorname{carbon}$ reduction and renewable support polithe electricity sector. Utilities Policy 28,28 - 41.URL: cies on http://www.sciencedirect.com/science/article/pii/S0957178713000726, doi:10.1016/j.jup.2013.11.004.
- [12] Fitiwi, D.Z., 2016. Strategies, methods and tools for solving long-term transmission expansion planning in large-scale power systems. Ph.D. thesis. URL: https://repositorio.comillas.edu/xmlui/handle/11531/14509.
- [13] Fitiwi, D.Z., Lnych, M., Bertsch, V., 2019. Optimal development of electricity generation mix considering fossil fuel phase-out and strategic multiarea interconnection. Working Paper 616. ESRI Working Paper. URL: https://www.econstor.eu/handle/10419/193952.
- [14] Fitiwi, D.Z., Santos, S.F., Cabrita, C.M.P., Catalão, J.P.S., 2017. Stochastic mathematical model for high penetration of renewable energy sources in distribution systems, in: 2017 IEEE Manchester PowerTech, pp. 1–6. doi:10.1109/PTC.2017.7981253.
- [15] Goiri, i., Haque, M.E., Le, K., Beauchea, R., Nguyen, T.D., Guitart, J., Torres, J., Bianchini, R., 2015. Matching renewable energy supply and demand in green datacenters. Ad Hoc Networks 25, 520-534. URL: http://www.sciencedirect.com/science/article/pii/S1570870514002649, doi:10.1016/j.adhoc.2014.11.012.
- [16] Hancher, L., Winters, M., 2017. The EU winter package: briefing paper. Technical Report.
- [17] He, Ζ., Τ., Liu, Υ., Li, Ζ., 2018.Ding. Analysis of  $\mathbf{a}$ district heating system usingwaste heat in a distributed cooling data Thermal Engineering 141,URL: center. Applied 1131 - 1140.http://www.sciencedirect.com/science/article/pii/S1359431117376226, doi:10.1016/j.applthermaleng.2018.06.036.
- [18] IEA, 2015. Projected Costs of Generating Electricity 2015 Edition, 215.
- [19] IRENA, 2017. Renewable power generation costs in 2017. Technical Report.
- [20] IRENA, 2019a. Electricity storage and renewables: Costs and markets to 2030, 20.

- [21] IRENA, 2019b. Renewable Capacity Statistics 2019. Technical Report. URL: /publications/2019/Mar/Capacity-Statistics-2019.
- [22] IWEA, 2015. Data-centre Implicatons for Energy Use in Ireland: Irish Data-centre Load Projections to 2020. Technical Report. URL: https://www.iwea.com/images/files/9660bdc9488d1ce95c4f2ba74ce340bfb4831f.pdf.
- [23] Jones, N., 2018. The information factories. Nature 561, 163–166.
- [24] Levin, T., Kwon, J., Botterud, A., 2019. The long-term impacts of carbon and variable renewable energy policies on electricity markets. Energy Policy 131, 53-71. URL: http://www.sciencedirect.com/science/article/pii/S0301421519301600, doi:10.1016/j.enpol.2019.02.070.
- [25] Lu, L., Preckel, P.V., Gotham, D., Liu, A.L., 2016. An assessment of alternative carbon mitigation policies for achieving the emissions reduction of the Clean Power Plan: Case study for the state of Indiana. Energy Policy 96, 661-672. URL: http://www.sciencedirect.com/science/article/pii/S0301421516303500, doi:10.1016/j.enpol.2016.06.045.
- [26] Masanet, E., Shehabi, A., Koomey, J., 2013. Characteristics of low-carbon data centres. Nature Climate Change 3, 627.
- [27] Miranda, Ν., Government Statement the Role on Centres Ireland's URL: of Data inEnterprise Strategy. https://dbei.gov.ie/en/Publications/Government-Statement-Data-Centres-Enterprise-Strate
- [28] Nadjaran Toosi, A., Qu, C., de Assunção, M.D., Buyya, R., 2017. Renewableaware geographical load balancing of web applications for sustainable data centers. Journal of Network and Computer Applications 83, 155-168. URL: http://www.sciencedirect.com/science/article/pii/S1084804517300590, doi:10.1016/j.jnca.2017.01.036.
- [29] O'Dwyer, Flynn, D., 2017.Efficient large-С., Ryan, L.L.B.., scale storage dispatch: in future high energy challenges renewables systems. IEEE Transactions on Power Systems 32,3439 -3450.https://researchrepository.ucd.ie/handle/10197/9103, URL: doi:10.1109/TPWRS.2017.2656245.
- [30] Oró, E., Depoorter, V., Garcia, A., Salom, J., 2015. Energy efficiency and renewable energy integration in data centres. strategies and modelling review. Renewable and Sustainable Energy Reviews 42, 429–445.
- [31] Santos, S.F., Fitiwi, D.Z., Cruz, M.R.M., Cabrita, C.M.P., Catalão, J.P.S., 2017. Impacts of optimal energy storage deployment and network reconfiguration on renewable integration level in distribution systems. Applied Energy 185, Part 1, 44-55. URL: http://www.sciencedirect.com/science/article/pii/S0306261916314970, doi:10.1016/j.apenergy.2016.10.053.
- [32] SEAI, 2016. Energy-Related Emissions in Ireland: CO2 Emissions from Fuel Combustion.
- [33] Tinbergen, J., 1956. Economic policy: principles and design. Books (Jan Tinbergen)
- С., [34] Tracker, 2018. ΕU carbon douprices could quadruple 2021 2030.URL: ble by and by https://www.carbontracker.org/eu-carbon-prices-could-double-by-2021-and-quadruple-by-20

- [35] Wahlroos, M., Pärssinen, M., Manner, J., Syri, S., 2017. Utilizing data center waste heat in district heating - Impacts on energy efficiency and prospects for low-temperature district heating networks. Energy 140, 1228-1238. URL: http://www.sciencedirect.com/science/article/pii/S0360544217314548, doi:10.1016/j.energy.2017.08.078.
- [36] Wahlroos, M., Pärssinen, M., Rinne, S., Syri, S., Manner, J., 2018. Future views on waste heat utilization - Case of data centers in Northern Europe. Renewable and Sustainable Energy Reviews 82, 1749-1764. URL: http://www.sciencedirect.com/science/article/pii/S1364032117314314, doi:10.1016/j.rser.2017.10.058.
- D.D., Τ., [37] Wang, Suevoshi, 2018.Climate change mitigation tar-Overview and implications for renewable gets set by global firms: en-Renewable and Sustainable Energy Reviews 94, 386-398. URL: ergy. http://www.sciencedirect.com/science/article/pii/S1364032118304593, doi:10.1016/j.rser.2018.06.024.
- [38] Whitehead, B., Andrews, D., Shah, A., Maidment, G., 2014. Assessing the environmental impact of data centres part 1: Background, energy use and metrics. Building and Environment 82, 151-159. URL: http://www.sciencedirect.com/science/article/pii/S036013231400273X, doi:10.1016/j.buildenv.2014.08.021.
- [39] Whitehead, B., Andrews, D., Shah, A., Maidment, G., 2015. Assessing the environmental impact of data centres part 2: Building environmental assessment methods and life cycle assessment. Building and Environment 93, 395-405. URL: http://www.sciencedirect.com/science/article/pii/S0360132314002674, doi:10.1016/j.buildenv.2014.08.015.
- [40] Wierman, A., Liu, Z., Liu, I., Mohsenian-Rad, H., 2014. Opportunities and challenges for data center demand response, in: International Green Computing Conference, IEEE. pp. 1–10.
- [41] Young, D., Bistline, J., 2018. The costs and value of renewable portfolio standards in meeting decarbonization goals. Energy Economics 73, 337-351. URL: http://www.sciencedirect.com/science/article/pii/S0140988318301427, doi:10.1016/j.eneco.2018.04.017.
- [42] Zakeri, B., Syri, S., 2015. Electrical energy storage systems: A comparative life cycle cost analysis. Renewable and Sustainable Energy Reviews 42, 569-596. URL: http://www.sciencedirect.com/science/article/pii/S1364032114008284, doi:10.1016/j.rser.2014.10.011. 00039.