

Bagdadee, Amam Hossain; Zhang, Li

**Article**

## Renewable energy based self-healing scheme in smart grid

Energy Reports

**Provided in Cooperation with:**

Elsevier

*Suggested Citation:* Bagdadee, Amam Hossain; Zhang, Li (2020) : Renewable energy based self-healing scheme in smart grid, Energy Reports, ISSN 2352-4847, Elsevier, Amsterdam, Vol. 6, Iss. 2, pp. 166-172,  
<https://doi.org/10.1016/j.egyr.2019.11.058>

This Version is available at:

<https://hdl.handle.net/10419/243874>

**Standard-Nutzungsbedingungen:**

Die Dokumente auf EconStor dürfen zu eigenen wissenschaftlichen Zwecken und zum Privatgebrauch gespeichert und kopiert werden.

Sie dürfen die Dokumente nicht für öffentliche oder kommerzielle Zwecke vervielfältigen, öffentlich ausstellen, öffentlich zugänglich machen, vertreiben oder anderweitig nutzen.

Sofern die Verfasser die Dokumente unter Open-Content-Lizenzen (insbesondere CC-Lizenzen) zur Verfügung gestellt haben sollten, gelten abweichend von diesen Nutzungsbedingungen die in der dort genannten Lizenz gewährten Nutzungsrechte.

**Terms of use:**


*Documents in EconStor may be saved and copied for your personal and scholarly purposes.*

*You are not to copy documents for public or commercial purposes, to exhibit the documents publicly, to make them publicly available on the internet, or to distribute or otherwise use the documents in public.*

*If the documents have been made available under an Open Content Licence (especially Creative Commons Licences), you may exercise further usage rights as specified in the indicated licence.*



<https://creativecommons.org/licenses/by-nc-nd/4.0/>



The 6th International Conference on Power and Energy Systems Engineering (CPESE 2019),  
September 20–23, 2019, Okinawa, Japan

## Renewable energy based self-healing scheme in smart grid

Amam Hossain Bagdadee\*, Li Zhang

*College of Energy and Electrical Engineering, Hohai University, Nanjing, China*

Received 2 October 2019; accepted 22 November 2019

---

### Abstract

The renewable energy based smart grid present a stable power supply system with low carbon emissions. The adaptability of work in smart grid-related approaches allows microgrids to load reliably. This research proposes a self-healing method with a large smart grid in different purpose. The proposed technologies include re-dispatch generation, reconfiguration organizations, and load restrictions. Smart network self-healing problems are defined as integer quadratic problems. This paper presents a flexible model solution to promote a horizontal generation. Innovation settings reliability of electrical reliability smart grid modification is used to instruct reproduction in various circumstances. The results of recreation show the ability of the proposed self-healing scheme because it reduces the cost of load outages and generation with ideal exchange activities. The proposed system demonstrates self-healing capabilities to ensure smart network security by constantly preventing fault and adaptation planning generations. Simulation results from the (Western Systems Coordinating Council) WSCC 3 generator system adjusted with the microgrid module confirm the power system of the proposed structure.

© 2019 Published by Elsevier Ltd. This is an open access article under the CC BY-NC-ND license

(<http://creativecommons.org/licenses/by-nc-nd/4.0/>).

Peer-review under responsibility of the scientific committee of the 6th International Conference on Power and Energy Systems Engineering (CPESE 2019).

*Keywords:* Smart grid; Self-healing; Microgrid; Reliability

---

### 1. Introduction

To ensure the security of a framework with a reliable power supply for a robust framework with a platform of expanded deregulation power and distributed power generation is difficult. The operator framework requires all stronger and more convincing operation to control and manage the security of the framework [8]. Smart self-healing grids are planned for this reason. The main contrast from conventional transmission networks is only the ability to avoid responsibility and self-correction. Smart grids with intelligent capabilities can achieve self-healing productively and reliably so that it will be more flexible and safer than when it is in memory recently [11]. Smart grid supplies reliable and inexpensive power with low carbon emissions. As a vital element of the smart grid, microgeneration complements the structure of the electricity network and offers several advantages. Smart grids are entirely different from large-scale electricity networks that require long transmission lines and supply network

---

\* Corresponding author.

*E-mail addresses:* [a.bagdadee@hhu.edu.cn](mailto:a.bagdadee@hhu.edu.cn) (A.H. Bagdadee), [zhanglinuaa@hhu.edu.cn](mailto:zhanglinuaa@hhu.edu.cn) (L. Zhang).

<https://doi.org/10.1016/j.egy.2019.11.058>

2352-4847/© 2019 Published by Elsevier Ltd. This is an open access article under the CC BY-NC-ND license (<http://creativecommons.org/licenses/by-nc-nd/4.0/>).

Peer-review under responsibility of the scientific committee of the 6th International Conference on Power and Energy Systems Engineering (CPESE 2019).

---

[1]. From now on that can eliminate the substantial speculation fees from the transmission line. Secondly, that is well maintained. Smart grids generally use inexhaustible assets (for example wind and solar oriented) as distributed power generations (DG), so that the release of atmospheric poisons and carbon is significantly reduced. Third, that is reliable and adaptive [10]. Microgrid generation can function in network-related and standalone modes. This will facilitate the release of the grid from significant power failures. Finally, integrate decentralized intelligence into the current network. Smart Grid provides solutions that are distributed to provide energy. Because of this concern, the number of the micropower generators is multiplying among electricity companies. In consideration of expanding the use of a broad area estimation framework in the electric power business, various leveling structures combined with multi-specialists are proposed to cure smart grids [5]. By implementing the proposed smart grid self-healing methodology, without respecting what operations are being carried out before autonomous generators can move and work in autonomous mode. This procedure includes re-dispatch generation, resetting, and load restrictions. This is specified as the problem of increasing mixed integers. Utilize the linearization procedure for the requirements of topological reconstruction; this problem was later formed into the problem of number four programming which provided comprehensive answers to encourage the facilitation of the micro generation [6]. Potential programming approaches are used to show the stochastic outcome limits of PV generation. The smart grid strategy is related to converting and linking opportunity constraints with integer quadratic problems. This research also consultation about communication between many microgrids that assist of smart grids network [7]. The reliability and flexibility of the smart grid have been improved.

## 2. Problem formulation

$$Min = \alpha_1 \sum_{i=\Omega L} k_i(M_{L,i}^0 - M_{L,i}) + \alpha_2 \sum_{k=\Omega n} (xM^2nk + yMnk + z) \tag{1}$$

If  $\alpha_1$  and  $\alpha_2$  are weighting factors for two purposes (i, k) is the need to load ( $M_{L,i}^0, M_{L,i}$ ) is MW of load  $I$  during stand-alone operations, x, y, and z are the calculation of costs This is the coefficient ( $\Omega L$ ) all are arranged to be equal, ( $\Omega n$ ) is a setting that considers all things. In Eq. (1), because  $\alpha_1$  is much higher than  $\alpha_2$ , minimizing the load limit has a higher requirement than limiting the cost of electricity generation. For warm units, generator cost capacity can be estimated with secondary capacity. For various types of generators, diesel or renewable generators and secondary, direct consistent (a small amount of work and maintenance costs for renewable generators) for generator cost work. When the (nk) coefficient is not zero, then the problem changes to the integer quadric problem. Depending on the purpose of the system administrator that can enter various cost capacities. For example, stack shedding costs, DG fees, reimbursement and loss costs due to reconfiguration, costs of lost power received. Fees and additional cost segments may be included in future work.

**Electric power balance:** The number of power plants and the number of loads must always be the same which is expressed as:

$$\sum_{i \in \Omega g} Mg, i \geq \sum_{k \in \Omega l} Ml, k \tag{2}$$

$$\sum_{i \in \Omega g} Ng, i \geq \sum_{k \in \Omega l} Nl, k \tag{3}$$

**Power flow conditions:** ( $Ml, i$ ) and ( $Nl, i$ ) are original and are given by the booster of reactive power ( $Ek, Ei$ ) during transportation, use AC power supply and transportation at the simultaneous microgrid. Analyze the voltage. ( $\theta_i$ ) is the magnitude of the voltage and the point of transportation ( $I, LiK$ ), ( $X, ik$ ) is the real and reactive part of the component ( $i, k$ ) of the transport guide framework, and ( $\Omega X$ ) are all considered in Tang et al. [9], sequential guesses are made for AC power flow.

$$Ml, i = \sum_{k \in \Omega X} E_i E_k [L_{i,k} \cos(\theta_i - \theta_k) + X_{i,k} \cos(\theta_i - \theta_k)], \forall \in \Omega_x \tag{4}$$

$$Nl, i = \sum_{k \in \Omega X} E_i E_k [L_{i,k} \cos(\theta_i - \theta_k) + X_{i,k} \cos(\theta_i - \theta_k)], \forall \in \Omega_x \tag{5}$$

The advantage of this strategy compared to the standard “DC” estimation is the voltage, and reactive power is modeled. Allegations of failed dialogs can be implied in. This guessing strategy applies to Eq. (4) moreover, (5) as given for pursuits.

$$M_{F,ik} = -(2E_i - 1)G_{ik} + (E_i + E_k + \cos \theta_{ik} - 2)G_{ik} + \theta_{ik}X_{ik}, \forall ik \in \Omega \quad (6)$$

$$N_{F,ik} = -(2E_i - 1)X_{ik} + (E_i + E_k + \cos \theta_{ik} - 2)X_{ik} + \theta_{ik}G_{ik}, \forall ik \in \Omega \quad (7)$$

Where  $(MF, ik)$  and  $(NF, ik)$  are actual and reactive power flows at the bus interface  $I$  and  $k$  and the differences in voltage points between bus  $I$  and  $k$  are under normal use conditions, the usual Scope and voltage is  $1.05 \leq E_i \leq 1.15$ , and  $|\theta_{ik}| \leq 40^\circ$ . Linearization  $(\cos \theta, i, k)$  appears as a follow: First, the introduction of interpolation the range  $(-40^\circ, 40^\circ)$  appears as a follow by taking a sample of  $10^\circ$  for  $\theta$ .

$$\theta_k, \cos \theta_k \quad k = 1, \dots, 9 = (-0.698, 0.766, -0.524, 0.866, -0.349, 0.940, -0.175, 0.985, 0, 1, 0.175, 0.985, 0.349, 0.940, 0.524, 0.866, 0.698, 0.766) \quad (8)$$

$$\theta = \delta \theta_i + (1 - \delta) \theta_{i+1}, i = 1, \dots, 9 \quad (9)$$

$$\cos \theta = \delta \cos \theta_i + (1 - \delta) \cos \theta_{i+1}, i = 1, \dots, 9 \quad (10)$$

$$\sum_{i=1}^9 n_i = 1 \quad (11)$$

$$\beta_i \leq n_i - 1 + n_i, i = 1, \dots, 9 \quad (12)$$

$$\sum_{i=1}^9 \beta_i = 1 \quad (13)$$

$$\theta = \sum_{i=1}^9 \beta_i \theta_i \quad (14)$$

$$\cos \theta = \sum_{i=1}^9 \beta_i \cos \theta_i \quad (15)$$

Here,  $\alpha_i \varepsilon$  ( $i = 1, 9$ ) is a constant variable for each cut-off point (I), this is the intermediate value  $h$   $[\theta_i, \theta_{k+1}]$ , This is twice the factor associated 9, where  $n_0 = n_9 = 0$  at the boundary. Constraint (11) only forces one (state)  $n_i^*$  to take self-esteem 1. Limitation (12) forces that  $\alpha_i$  non-zero to be  $\beta_i^*$  and  $\beta_i^* + 1$ . At that point limitation (13) and (14) assurance  $\beta_i^* = \delta$  and  $\beta_{i+1} = 1 - \delta$ , which corresponds to the boundary (9). The constraint condition (15) guarantees an exact estimate of the approximate  $\cos \theta$  in (10). Linearization of this limitation assists the reorganization of the topology to increase the autonomous microgrid.

**Restructuring limits:** It is accepted that there are several switches in a conventional open condition, which is selectively associate with new controls. Dual factor ‘ $H_{ik}$ ’ is accustomed to talking about the condition of the lane that connects buses  $I$  and  $k$ . At  $H_k = 1$ , the switch is turned on, and the power flow is pronounced by (6) and (7). In general, the switch is turned off, and the power is zero. This limit is displayed in the accompanying linear conditions.

$$-(1 - H_{ik})B \leq MF_{H, ik} - MF_{iK} \leq (1 - H_{ik})B, \forall iK \in \Omega \quad (16)$$

$$-(H_{ik})B \leq MF_{H, ik} - MF_{iK} \leq -H_{ik}B, \forall iK \in \Omega \quad (17)$$

$$-(1 - H_{ik})B \leq NF_{H, ik} - NF_{iK} \leq (1 - H_{ik})B, \forall iK \in \Omega \quad (18)$$

$$-H_{ik}B \leq NF_{H, ik} - NF_{iK} \leq -H_{ik}B, \forall iK \in \Omega \quad (19)$$

where,  $(MF_{H, ik})$  and  $(NF_{H, ik})$  is original and ineffective power flows between two buses  $I$  and  $k$  with switches,  $B$  is a number that can be expanded arbitrarily. More than four conditions assurance that the switch is closed when  $H_{ik} = 1$  and the power flow is distinct by (6) and (7). When  $H_{ik} = 0$ , the switch opens, and the power flow is zero.

**Generation limit value:** The generator limit value must be reliable in the range of maximum limit values  $(Mg_{max}, i)$   $(Ng_{max}, i)$  and lower limit values  $(Mg_{min}, i)$   $(Ng_{min}, i)$  given by the following equation:

$$Mg_{min}, i \leq Mg, i \leq Mg_{max}, i, \forall i \in \Omega_g \quad (20)$$

$$Ngmin, i \leq Ng, i \leq Ngmax, i, \forall i \in \Omega g \tag{21}$$

**Voltage Limit:** The voltage flow in each bus must be reliable in the range of the farthest limit ( $E_{max}$ ) and low limit ( $E_{min}$ ) as given in (22). The voltage limit is set to 1.05 and 1.15 p.u. As upper and lower limits,

$$Emin \leq Ei \leq Emax, \forall i \in \Omega k \tag{22}$$

**Line limit:** Each line flow ought to be inside its warm limit  $MFHmax$ , as given by

$$- HijMFHmax \leq MFH, ik \leq HikPFHmax, \forall ik \in \Omega L \tag{23}$$

This paper will focus on dynamic power flow. Given a clear power flow limit  $MFHmax$  (MVA), the limit of dynamic power flow can be determined by accepting false voltage:  $MFHmax = (gikl(g^2ik + X^2ik))H^2FH max$ . Along with this line, the constraint (17) is that it can be replaced by Eq. (23).

$$0 \leq ML, i \leq ML^o, i, \forall i \in \Omega L \tag{24}$$

**Load shedding limit:** When a load shedding is executed, the load shedding must be minor than the load condition.

**Distributed generation limitation:** The renewable energy, as the  $E_{PVi}$ , t generation can be accessed; PV must be the farthest limit of the inverter-based PV power injection. The mandatory firing plan for which the level  $\gamma_i$  of certainty for each PV generator is  $i$  is indicated as a chase.

$$Er\{E_{Invi,t} \leq E_{PVi,t}\} \geq \lambda i \tag{25}$$

Given [19], for each positive natural number, for a negative irregular variable X given

$$EX \geq a \leq VX/u \tag{26}$$

Applying,

$$\lambda i \leq Er_{eInvi,t} \leq E_{eVi,t} \leq E_{ePVi,t}/E_{Invi,t} \tag{27}$$

Experimental evaluations of the expected quality can be obtained through the common example [4]. In this way, considering the  $Rn$  test of  $EPVi$  irregular variables, t, estimation (27) can be achieved.

$$E_{Invi,t} \leq \frac{\sum_{R=1}^{Rn} E_{PVi,t}^R}{\lambda_i \cdot R_n} \tag{28}$$

The Latin sampling technique will lead to a large number of situations, driven from the right side (RHS) of (28)–(27). In short, the problem of microgrid independent recovery after remote islands is solved by MIQP (1), constraints (2)–(8), (11)–(16), (18) that can be specified as a problem.–(24), (28) and the  $Eg$  selection variable,  $i$  is the re-dispatch generation,  $EL, i$  shows the load limit, and  $Hik$  shows the topology reconstruction.

### 3. Smart grid self-healing scheme

The power system leads to a smart grid with a large number of microgrid modules with different renewable energies, such as wind farms, photovoltaic power plants, and battery energy storage systems. There are some systems to connect to this distributed system as part of artificial reasoning. Fig. 1 shows various leveling systems for smart grids that are combined with various microgrids. The focus control specialist top layer plans for a comprehensive smart grid management system of the entire system as a spirit of the microgrid, each microgrid interface with transmission and consists of active on/off operators in the module. At the top layer, wide area monitoring systems data is exchanged with control operators focused on security predictions on the information exchange pathway. At that point, control experts focused on calculating the power with TSF technology and sending control plans back to the micro network. The smart grid self-healing system allows crisis management activities to change from grid-related mode to autonomous mode smoothly [2]. The general plan is shown in Fig. 1. The center of this method is a MIQP-based improvement breaker. Sources of information including observed system information include generator results, power exchange with basic grids before independent operations, stacking conditions, and system topologies. The Latin sampling technique is enhancement motors process information and continues to provide comprehensive ideal setting [3]. The output is an ideal activity for crisis management, such as generation change, stack transfer, and




Fig. 1. Grid self-healing scheme.




Fig. 2. WSCC -3 generators 9 bus.

transfer activities for topology reconstruction. At each microgrid, the coordinating operator adjusts self-importance controls by the each physical equipment. Physical gadgets also have insurance operators with the ability to recognize losses by observing experts and avoiding problems by exchanging experts. The smart grid system design specialist notifies the microgrid interface that changes the status of the physical gadget compared. This sends a modified system topology to the focus control operator for predicting system stability.

**4. Result**

The self-healing method of the smart grid that was tried by various micro frameworks was used as shown in Fig. 3. The three types of generators distributed renewable resources are solar power (PV), microturbine, and wind turbines. The WSCC 3 generator 9 bus framework coordinated with multiple microgrids. Microgrids 1, 2 and 3 separately combine one load 1 for bus11-d and load 2 aggregators for bus 10-d. They are controllable loads in the range of [-5 MW, 5 MW] and [-3 MW, 3 MW] for load 1 aggregators. The upper and lower voltage limits are in




Fig. 3. Stability of micro grid.




Fig. 4. Stability of micro grid.

the range of [1.05, 1.15] p.u. Under normal working conditions, the multiple microgrid connections lines 11c–10f is turned off. All devices are sent with legitimate operators, as shown in the blue stub in Fig. 2. The operator is placed and accepts the structure of a fully distributed inspection strategy with time-domain simulation. Suppose a three-phase error has occurred on channels 10–10 for 0.5 s. Because gadget security specialists on channels 10–10a provide data about the results of the number of streams that are not zero, this indicates that a failure has occurred on channels 10–10a. This damaged area has communicated to all gadget operator operators on micro grid 2, and the direction of releasing errors is sent to change experts on lines 10–10a. The system will be expected to be in a stable condition if the error is removed by opening the breaker twice in 0.18 s by opening the electric switch opening time (5 cycles) and handoff from the elapsed travel time. Check the status on the 10–10a channel intermittently and report this ongoing error to the gadget security officer on the 10–10a channel and finally break 1 to the gadget security officer on channel 6–10 Request to open and avoid errors. This is only the monitoring operator’s inspection cycle, and the system is stable as shown in Fig. 3. In conventional overcurrent flowing protection devices are relays, the time delay is the time of correction between the primary and the backup protection that usually 0.4–0.5 s. Fig. 4 shows that the framework is unstable despite a temporary period of 0.4 s in conventional insurance. Although conventional guarantees damage the security of the framework, the guarantee of this framework is greatly enhanced by the structure proposed in the sampling technique. When the framework settles after a short transmission period, the micro grid 2 asks to re-supply its capacity to the transmission framework, if possible. Focus control specialists consult the system topology database and control microgrid 2 and three particular power paths such as lines 11c–10f. In this way, the focus control operator shows several microgrids to be connected via channels 11c–10f. Specialist changes on channels 11c–10f activate the comparator breakers, connect different microgrids, and push breakers 3 to turn off errors. Presently microgrid 2 and 3 recovers control supply and monitoring specialists report the system topology to the reconfiguration operator. Although, because of an extended power reinstatement way, nodal voltages of microgrid 2 and 3 are low someplace as appeared in Fig. 5 for the pre-fault condition that load 1 aggregator and load 2 charged power at a full rate such as load 1 = 5 MW and load 2 = 7 MW. Hence, the coordination operators in microgrid 1 and microgrid 2 consult to enhance the voltage profile. Considering the neighborhood generation




Fig. 5. Load fault condition.

is substantially more potent than the removed one to assist voltages, straightforward coordination is expected in a plummeting need as pursues. (1) The controllable load in microgrid 2, in particular, load 1 aggregator at bus 10-b. The power generation at a full releasing rate to assist voltage profile right off the load 1, while load 2 stop devouring power such as load 1 =  $-3$  MW and load 2 =  $0$  MW if voltages are not fulfilled. Load 2 in microgrid 3 completely releases as another power generation to additionally facilitate nodal voltages such as load 1 =  $-5$  MW and load 2 =  $-5$  MW; if voltage is as yet not fulfilled, some portion of loads would be drop off other than plan 2. Voltage is satisfied when both load 1 and load 2 functions as a power plant, as shown in Fig. 4 for node voltage of multiple microgrids. The proposed plan ensures the security of the framework by organizing generations adaptively in a straightforward manner. Regarding a complex and extendable framework, settings can be refined with ideal power flow strategies created around everything. After the system has reconfigured that need to change the security zone. After coordination with different microgrid controls the system topology, it disperses X4 and X5 as enhanced security for X6, as a substitute X3 as enhanced security for X4, X5, and X6 in a pre-failure state. The proposed structure with inspection procedures can be trusted and adaptively guarantee the control framework.

## 5. Conclusions

Renewable energy based smart grids supplies consistent, environmentally friendly power with low carbon surplus. The ability to operate in modes related to smart grid and autonomous modes, the microgrid can handle loads reliability. This paper proposes a multi-generation layer system for building smart networks that assist self-healing process. The upper layer predicts the stability of the framework by modern technology depends on wide area monitoring framework information, while the lower layer with the generation of multi-micro grid networks can implement a framework with exclusion measures that can be executed and appropriate generation correction. This paper proposes self-healing for smart grid networks from the main grid and discussion about extraordinary circumstances considering the possibility of renewable energy. This paper further expands the smart grid self-healing system for multi-micro grid conditions and discussion about the importance of collaboration between multiple microgrid networks. The proposed structure effectively adapts the stability framework and regulates generation adaptively to ensure the integrity of the framework and establish future electricity networks with self-healing abilities. Smooth in predicting and believing to prevent the progress of criticism before that happens. The ongoing effort focuses on the use of this structure and considers that communication between generations of multi-micro grid networks with a wide area control framework equipped. Reproductive results show the ability of self-healing procedures to reduce the costs of load shedding in the case of multiple microgrids. In particular, organizing redeployment is the most economical and reliable solution present by the self-healing smart grid-based microgrid system.

## Acknowledgment

This work was supported by Hohai University under China Scholarship Council (CSC) No. 2017GXZ019296.

## References

- [1] Bagdadee AH. Imitation intellect techniques implement for improving power quality in supply network. In: IEEE international conference on signal processing, communication, power and embedded system; 2016.
- [2] Bagdadee AH. Power quality analysis by the ripple technique. *J Appl Adv Res* 2016;2(4):227–34.
- [3] Bagdadee AH, Zhang L. *J Electr Eng Technol* 2019. <http://dx.doi.org/10.1007/s42835-019-00220-y>.
- [4] Baldursson F, Lazarczyk E, Ovaere M, Proost S. Cross-border exchange and sharing of generation reserve capacity. *Energy J* 2018;39(4):57–83.
- [5] Heaps CG. Long-range energy alternatives planning (LEAP) System. Somerville, MA, USA: Stockholm Environment Institute; 2018, 2016; Software version: 2018.1.4; Available online: <https://www.energycommunity.org>.
- [6] Moretti M, Njakou Djomo S, Azadi H, May K, De Vos K, Van Passel S. A systematic review of environmental and economic impacts of smart grids. *Renew Sustain Energy Rev* 2017;68(Part 2):888–98.
- [7] Shayesteh E, Yu J, Hilber P. Maintenance optimization of power systems with renewable energy sources integrated. *Energy* 2018;149:577–86.
- [8] Tamura Y. TM plane wave scattering and diffraction from a randomly rough half-plane: (part II) An evaluation of the diffraction kernel. *Waves Random Complex Media* 2006.
- [9] Tang Y, Liu Q, Jing J, Yang Y, Zou Z. A framework for identification of maintenance significant items in reliability centered maintenance. *Energy* 2017;118:1295–303.
- [10] Wang. Energy poverty in China: A dynamic analysis based on a hybrid panel data decision model. *Energies* 2017.
- [11] Wang Yue-Sheng, Gross Dietmar. Interaction of harmonic waves with a periodic array of interface cracks in a multi-layered medium: anti-plane case. *Int J Solids Struct* 2001.