

Make Your Publications Visible.

A Service of



Leibniz-Informationszentrum Wirtschaft Leibniz Information Centre

Sumair, Muhammad; Aized, Tauseef; Gardezi, Syed Asad Raza; Ubaid ur Rehman, Syed; Rehman, Syed Muhammad Sohail

Article

A newly proposed method for Weibull parameters estimation and assessment of wind potential in Southern Punjab

Energy Reports

Provided in Cooperation with:

Elsevier

Suggested Citation: Sumair, Muhammad; Aized, Tauseef; Gardezi, Syed Asad Raza; Ubaid ur Rehman, Syed; Rehman, Syed Muhammad Sohail (2020): A newly proposed method for Weibull parameters estimation and assessment of wind potential in Southern Punjab, Energy Reports, ISSN 2352-4847, Elsevier, Amsterdam, Vol. 6, pp. 1250-1261, https://doi.org/10.1016/j.egyr.2020.05.004

This Version is available at: https://hdl.handle.net/10419/244117

Standard-Nutzungsbedingungen:

Die Dokumente auf EconStor dürfen zu eigenen wissenschaftlichen Zwecken und zum Privatgebrauch gespeichert und kopiert werden.

Sie dürfen die Dokumente nicht für öffentliche oder kommerzielle Zwecke vervielfältigen, öffentlich ausstellen, öffentlich zugänglich machen, vertreiben oder anderweitig nutzen.

Sofern die Verfasser die Dokumente unter Open-Content-Lizenzen (insbesondere CC-Lizenzen) zur Verfügung gestellt haben sollten, gelten abweichend von diesen Nutzungsbedingungen die in der dort genannten Lizenz gewährten Nutzungsrechte.

Terms of use:

Documents in EconStor may be saved and copied for your personal and scholarly purposes.

You are not to copy documents for public or commercial purposes, to exhibit the documents publicly, to make them publicly available on the internet, or to distribute or otherwise use the documents in public.

If the documents have been made available under an Open Content Licence (especially Creative Commons Licences), you may exercise further usage rights as specified in the indicated licence.




NC ND https://creativecommons.org/licenses/by-nc-nd/4.0/



Contents lists available at ScienceDirect

Energy Reports

journal homepage: www.elsevier.com/locate/egyr



Research paper

A newly proposed method for Weibull parameters estimation and assessment of wind potential in Southern Punjab



Muhammad Sumair ^{a,*}, Tauseef Aized ^a, Syed Asad Raza Gardezi ^b, Syed Ubaid ur Rehman ^a, Syed Muhammad Sohail Rehman ^a

- ^a Department of Mechanical Engineering, University of Engineering and Technology, Lahore, Pakistan
- ^b Department of Mechanical Engineering, Bahauddin Zakariya University, Multan, Pakistan

ARTICLE INFO

Article history: Received 11 March 2020 Received in revised form 8 April 2020 Accepted 5 May 2020 Available online xxxx

Keywords:
Wind potential assessment in South Punjab
Energy pattern factor method
Method of moment
Modified method of moment
Energy production from wind turbines
Capacity factor

ABSTRACT

Accuracy of wind potential estimation using two-parameter Weibull distribution relies on the accuracy with which Weibull distribution models the wind data. Therefore, there is always a thirst for developing better methods for the estimation of Weibull parameters. Current work focusses on the investigation of a newly proposed method called Modified Method of Moment (MMOM) and comparing it with two other methods i.e. Energy Pattern Factor Method (EPFM) and Method of Moment (MOM) to assess wind potential in South Punjab. Five years (2014–2018) hourly wind data measured at 50 m height and collected from Pakistan Meteorological Department (PMD) was utilized. Performance of EPFM, MOM and MMOM was evaluated using coefficient of determination, root mean square error and power error. Monthly, seasonal and annual variations in wind speed, wind power density (WPD) and wind energy density (WED) were analyzed and annual energy production using six turbine models was also estimated. The analysis showed that MMOM is the best method followed by MOM and EPFM respectively. Furthermore, the highest wind potential is observed in summer while lowest in winter in whole region. Polar diagrams showed that the optimum wind direction in the area is southwest.

© 2020 Published by Elsevier Ltd. This is an open access article under the CC BY-NC-ND license

(http://creativecommons.org/licenses/by-nc-nd/4.0/).

1. Introduction

Owing to economic and environmental concerns, wind energy is seeking attention throughout the world these days (Shoaib et al., 2017; Milanese et al., 2017, 2019). Global wind installed capacity reaches about 597 GW in 2019 (World Wind Energy Association, 2019) with China as the leading one having a share of 37.01% in global installed capacity followed by USA (16.14%), Germany (9.93%), India (5.46 %) and Spain (3.85%) (ETEnergyWorld, 2019). According to International Renewable Energy Agency (IRENA) report, 2019 (IRENA, 2019), India has total installed capacity of 35 GW whereas Pakistan has only 1186 MW. As Pakistan is an energy deficient country, having a huge reliance on fossil fuels for both the primary energy (with 87% and 80% share as of 2014 and 2019 respectively) and electrical energy generation (with 61% and 64% share as of 2014 and 2019 respectively) (Baloch et al., 2016; Sarim, 2019), therefore, to achieve the sustainable development, there is a need to harness wind energy (Khahro et al., 2014b). Before the exploitation of wind energy, accurate estimation of wind potential is important (Bilir et al., 2015).

E-mail address: sumairliaqat@gmail.com (M. Sumair).

Two-parameter Weibull distribution has been used for wind potential estimation throughout the literature and the accuracy with which Weibull distribution models the wind data depends upon the method used to estimate Weibull parameters. There are a number of methods available for the estimation of Weibull parameters (Chang, 2011; Andrade et al., 2014; Saleh et al., 2012; Dorvlo, 2002) e.g. Graphical Method (GM), Empirical Method (EM), Energy Pattern Factor Method (EPFM), Power Density Method (PDM), Method of Moment (MOM), Maximum Likelihood Method (MLM), Modified Maximum Likelihood Method (MMLM), Least Square Method (LSM) and Alternative Maximum Likelihood Method (AMLM).

Chaurasiya et al. (2018) compared nine numerical methods for the estimation of Weibull parameters and concluded that MLM and MMLM have a good performance while GM, popularly used method in past, has poor performance. Akpinar and Akpinar (2005) conducted a comparative analysis of three methods known as EPFM, GM and MLM and concluded that EPFM is better in estimating the wind power potential than the other two methods. From literature, it is evident that a number of methods for Weibull parameters estimation are available and some of those methods have been modified in order to enhance the accuracy of Weibull distribution. However, there has always been a thirst regarding the development of new methods.

^{*} Correspondence to: Kanwanwali Chak No.166/R-B P.O. Same Tehsil Shahkot District Nankana Sahib, Punjab, Pakistan.

Chaurasiya et al. (2017) investigated wind characteristics in Kayathar, Tamil Nadu, India using wind speed data collected by SODAR technique. Comparative analysis of nine different Weibull parameters estimation methods was made. Furthermore, the wind shear effect was also investigated by conducting the analysis on three different heights i.e. 80 m, 100 m and 120 m. Finally, the study compared the accuracy of data collected using SODAR technique and cup anemometer method.

Wind potential at three cities (Chennai, Erode and Coimbatore) in the South Indian state of Tamil Nadu, India was investigated (Rehman et al., 2020) using thirty eight years wind data. Weibull distribution with three methods i.e. MLM, LSM and WASP algorithm was used. It was found that Chennai is the most ample site for wind energy utilization followed by Coimbatore and Erode respectively with wind power densities (WPDs) of 129 W m $^{-2}$, 97 W m $^{-2}$ and 76 W m $^{-2}$.

Techno-economic feasibility analysis of wind power harvesting at Hawke's Bay was performed (Hulio et al., 2019a) using Weibull distribution at three heights of 30 m, 60 m and 80 m respectively. Five Weibull parameters estimation methods i.e. EM, MLM, MMLM, EPFM and GM were compared using correlation coefficient and root mean square error and it was found that all methods except GM give good fit. Further it was found that the site has WPD of 184 W m⁻², 231.5 W m⁻² and 307.5 W m⁻² at 30, 60 and 80 m respectively. Moreover, economic assessment showed that unit cost of energy is \$0.0556.

Wind power potential at Jhimpir (Sindh, Pakistan) was investigated (Shoaib et al., 2019) using 10 min average wind data collected over a period of three years. Weibull probability density function was used with MLM, MMLM and EPFM to estimate Weibull parameters. Coefficient of determination, root mean square error and chi-square tests were applied to find the goodness of fit. Results showed that MLM and MMLM are better than EPFM. Monthly, seasonal and annual power potential was estimated and it was found that investigated site has 1691, 2851, 4572, and 916 kWh in winter, spring, summer and autumn respectively.

A site, Nooriabad Pakistan was investigated (Hulio et al., 2017) using wind data collected over 1 year period. Weibull and Rayleigh functions were used and compared to estimate wind potential two heights of 30 m and 50 m respectively. Five methods i.e. EM, MLM, MMLM, EPFM and GM used for Weibull parameters estimation were compared using correlation coefficient and root mean square error. It was found that Weibull distribution gave good fit to data than Rayleigh distribution. Moreover, it was found that all methods gave good fit except GM. Mean WPDs were found to be 169 W m⁻² and 416.7 W m⁻² at 30 and 50 m heights respectively. Economic analysis of energy generation showed that energy with \$ 0.02189/kWh can be produced at Nooriabad at a hub height of 50 m.

Hong Kong, an island in China was investigated to assess the wind potential and to determine the suitability of certain wind turbine models, presented in Lu et al. (2002). A potential site in Brazil i.e. Paraiba was investigated and presented in Lima and Filho (2012). Similarly, Firouzkooh county of Iran (Pishgar-Komleh et al., 2015), Arizona (Acker et al., 2007), Tehran, Iran (Keyhani et al., 2010) and many others have been studied. In Pakistan, Gharo, Sindh (Khahro et al., 2014b), Baburband, Sindh (Shoaib et al., 2017), Jiwani, Balochistan (Shami et al., 2016) and other potential sites have been investigated so far. As no single method can always be accurate for the estimation of Weibull parameters, therefore, there is always a thirst for developing better methods for the estimation of Weibull parameters.

The novelty of this work lies in the fact that it is dual objective in nature. Firstly, it introduces a new method, Modified Method of Moment (MMOM), which is a modification of previously used method called Method of Moment (MOM). To the best of authors' knowledge, this modified method has not been used throughout the literature to estimate the Weibull parameters. To verify whether this new method has a better accuracy than original MOM, it must be compared with MOM. Moreover, MMOM should also be compared with Energy Pattern Factor Method (EPFM) because EPFM has also been found significantly accurate in many studies and moreover, it is much easy to use EPFM which requires no numerical iteration, therefore, EPFM can be an attractive selection for anyone to estimate Weibull parameters. So overall, work compares MMOM with MOM and EPFM in order to evaluate whether it is better fit than the other two methods or not. Secondly, wind potential estimation in South Punjab, which has not been accessed so far, needs to be accessed for future power projects expected to be launched in this area by Government of Pakistan (GOP).

2. Materials and methods

2.1. Wind Data Modeling

Although there are many continuous probability density functions available to model various phenomenon (Pobočíková et al., 2017; Carta et al., 2009), two-parameter Weibull distribution has been the most widely used to estimate wind power potential throughout the literature (Bagiorgas et al., 2012; Kitaneh et al., 2012). Two-parameter Weibull model is given as follows (Khahro et al., 2014a; Aized et al., 2019; Costa Rocha et al., 2012).

$$f(V) = \frac{K}{C} \left(\frac{V}{C}\right)^{K-1} e^{-\left(\frac{V}{C}\right)^{K}}$$
(1)

$$F(V) = 1 - e^{-\left(\frac{V}{C}\right)^K} \tag{2}$$

where

f(V) = Probability Density Function

F(V) = Cumulative Density Function

K = Dimensionless Shape Parameter

 $C = Scale Parameter (m s^{-1})$

2.2. Methods for estimating Weibull parameters

There are a number of methods available to estimate Weibull distribution parameters. This study focused on three methods i.e. Method of Moment (MOM), Energy Pattern Factor Method (EPFM) and a newly proposed method in this study called Modified Method of Moment (MMOM). As the name suggests, MMOM is a new method developed through the modification of previously used method MOM, therefore, it must be compared with MOM in order to evaluate whether MMOM gives better results than original MOM or not (This is a proven and validated technique as whenever Modified Maximum Likelihood Method is used, it is necessarily compared with Maximum Likelihood Method (Shoaib et al., 2019; Hulio et al., 2017; Khahro et al., 2014a; Hulio et al., 2019b)). Moreover, MMOM was compared with EPFM as EPFM is also significantly accurate method and it is much easy to apply this method as it requires no numerical iterative procedure for the estimation of Weibull parameters but only simple formulation is applied (Hulio et al., 2019a; Shoaib et al., 2019; Hulio et al., 2017; Khahro et al., 2014a). Therefore, present study compared MMOM with MOM and EPFM.

i. Method of Moment (MOM)

Mean wind speed can be calculated using integral definition, as given by Eq. (3)

$$\overline{V} = \int_0^\infty V f(V) dV \tag{3}$$

Putting Weibull probability density function in Eq. (3), we get Eq. (4)

$$\overline{V} = \int_0^\infty V \frac{K}{C} \left[\left(\frac{V}{C} \right)^{K-1} \times e^{-\left(\frac{V}{C} \right)^K} \right] dV \tag{4}$$

Incorporating the definition of gamma function $\Gamma(y) = \int_0^\infty e^{-t} t^{y-1}$, and simplifying the results, average wind speed assumes the following form:

$$\overline{V} = C\Gamma\left(1 + \frac{1}{K}\right) \to C = \frac{\overline{V}}{\Gamma\left(1 + \frac{1}{V}\right)}$$
 (5)

From basic definition of standard deviation, we have following mathematical relationship

$$\sigma = \sqrt{\int_0^\infty \left(V - \overline{V}\right)^2 f(V)} dV \tag{6}$$

Integrating Eq. (6)

$$\int_0^\infty V^2 f(V) dV = \int_0^\infty V^2 \left(\frac{K}{C}\right) \left(\frac{V}{C}\right)^{K-1} dV$$
$$= \int_0^\infty C^2 y^{\frac{2}{K}} e^{-y} dV = C^2 \Gamma(1 + \frac{2}{K})$$
(7)

Simplifying the results, we have following form of standard devi-

$$\sigma = C \left\{ \Gamma \left(1 + \frac{2}{K} \right) - \Gamma^2 \left(1 + \frac{2}{K} \right) \right\}^{0.5} \tag{8}$$

Simultaneous numerical iterative solution of Eqs. (5) and (8) estimates Weibull parameters.

ii. Modified Method of Moment (MMOM)

This is a new method proposed in this study called modified method of moment (MMOM). This method is based on the fact that "Weibull scale parameter is proportional to mean wind speed".

Let us suppose that mean wind speed and Weibull scale are equal i.e. $C = \overline{V}$. If this assumption is true, following relationship must hold good as well:

$$C = \left(\overline{V}^k\right)^{\frac{1}{K}} \tag{9}$$

However, the results of various studies show that Weibull scale parameter is not exactly equal to mean wind speed, however, it is closely related to mean wind speed. Thus establishing a best fit between Weibull scale parameter (calculated from other methods in literature) and mean wind speed gives a similar form (but not same) of relationship as Eq. (9) the following relationship as given in Eq. (10)

$$C = \left(\overline{V^K}\right)^{1/K} \tag{10}$$

Taking natural logarithm of Eqs. (8) and (10), we have Eqs. (11) and (12) respectively.

$$\ln\left(\sigma^2 + \overline{V}^2\right) = 2\ln C + \ln \Gamma\left(1 + \frac{2}{K}\right) \tag{11}$$

$$lnC = \frac{1}{\kappa} ln\left(\overline{V^K}\right) \tag{12}$$

Eliminating C from Eqs. (11) and (12), we get following Eq. (13)

$$\ln \Gamma \left(1 + \frac{2}{K} \right) + 2 \left(\frac{1}{K} \right) \ln \left(\overline{V^K} \right) - \ln \left(\sigma^2 + \overline{V}^2 \right) = 0 \tag{13}$$

Numerical solution of Eq. (13) yields K and C is then estimated using Eq. (10). This Eq. (13) is a new equation which has not previously been used in literature.

iii. Energy Pattern Factor Method (EPFM)

This method relies on the fact that "Average power of wind is higher than power of the average wind". A parameter to quantify this difference is known as Wind Energy Pattern Factor (WEPF), given below:

WEPF =
$$\frac{Average \ power \ of \ the \ wind}{power \ of \ average \ wind} = \frac{\frac{1}{N} \sum_{i=1}^{N} (\frac{1}{2} \rho V_i^3)}{\frac{1}{2} \rho \left(\frac{1}{N} \sum_{i=1}^{N} V_i\right)^3} = \frac{\overline{V^3}}{\overline{V}^3}$$
(14)

Once WEPF is estimated, Weibull parameters can be calculated using Eq. (15) (Akdağ and Dinler, 2009; Akdağ and Güler, 2015) and Eq. (5) respectively

$$K = 1 + \frac{3.69}{WEPF^2} \tag{15}$$

2.3. Measure of goodness of fit

How good is the Weibull distribution to model the actual wind data? This question is answered by using different statistical measures given below:

i. Coefficient of Determination (R^2)

Coefficient of determination is used to measure the accuracy of the wind model relative to the actual wind data. It can be evaluated using Eq. (16)

$$R^{2} = \frac{\sum_{i=1}^{N} (Y_{i} - Z)^{2} - \sum_{i=1}^{N} (X_{i} - Z)^{2}}{\sum_{i=1}^{N} (Y_{i} - Z)^{2}}$$
(16)

 Y_i is actual wind speed probability X_i is predicted wind speed probability And Z is the mean of actual data

ii. Root Mean Square Error (RMSE)

Another measure to check the accuracy of wind model relative to the actual distribution is root mean square error. RMSE is calculated using Eq. (17)

$$RMSE = \left[\frac{1}{N} \sum_{i=1}^{N} (Y_i - X_i)^2\right]^{0.5}$$
 (17)

It quantifies the deviation of predicted probability values from actual probability values. Therefore, the smaller is RMSE, the more accurate is the given model.

iii. Power Error (P.E)

Power error quantifies the relative difference between actual wind power density and predicted wind power density

$$P.E = \left| \frac{WPD_W - WPD_{act}}{WPD_{act}} \right| \tag{18}$$

2.4. Wind potential

Wind potential is described by not only the mean wind speeds but also by wind power density (WPD) and wind energy density (WED) because average wind speeds can be identical for different locations irrespective of whether they possess same or different wind power or wind energy densities. WPD and WED can be estimated using following mathematical relationships (Pishgar-Komleh et al., 2015; Azad et al., 2014):

$$WPD_{W} = \int_{0}^{\infty} \frac{1}{2} \rho V^{3} f(V) dV = \frac{1}{2} \rho C^{3} \Gamma\left(1 + \frac{3}{K}\right)$$
 (19)

$$WED = \frac{1}{2}\rho C^3 \Gamma \left(1 + \frac{3}{K}\right) T \tag{20}$$

T = Required time period

Two important speeds in the estimation of wind resource are most probable wind speed (V_{mp}) and the optimum wind speed (V_{opt}). Once the Weibull parameters are calculated, these speeds can be calculated using following mathematical relationships (Khahro et al., 2014b; Keyhani et al., 2010):

$$V_{mp} = C \left(\frac{K-1}{K}\right)^{1/K} \tag{21}$$

$$V_{opt} = V_{\text{max}E} = C \left(\frac{K+2}{K}\right)^{1/K} \tag{22}$$

2.5. Energy production through turbines

Amount of power or energy produced over a period of time is an important consideration (Khahro et al., 2014a). Wind power extracted using a wind turbine does not depend only on wind characteristics of a site but also on turbine characteristics such as rated speed, cut-in speed, cut-out speed, rotor area and hub height (Liu and Yocke, 1980). Moreover, a turbine is normally rated to its maximum power (P_R) it can produce but practically, it would be able to produce a fraction of rated power. This relative difference is described in terms of capacity factor (CF).CF and power generated can be calculated using Eqs. (23) and (24) respectively:

$$C_F = \frac{Actual\ Power\ from\ Wind\ Turbine\ (P)}{Rated\ Power\ from\ Wind\ Turbine\ (P_R)} \tag{23}$$

$$\overline{P_{WT}} = \begin{cases}
\sum_{j=1}^{N_B} \left\{ exp \left[-\left(\frac{v_{j-1}}{c}\right)^k \right] - exp \\
\times \left[-\left(\frac{v_j}{c}\right)^k \right] \right\} P_{WT} \left(\frac{v_{j-1} + v_j}{2}\right) & for(v_{cutin} \le v \le v_r) \\
\sum_{j=1}^{N_B} \left\{ exp \left[-\left(\frac{v_{j-1}}{c}\right)^k \right] - exp \\
\times \left[-\left(\frac{v_j}{c}\right)^k \right] \right\} P_{WT} (v_r) & for (v_r \le v \le v_{cutout}) \\
0 & for v < v_{cutin} \text{ and } v > v_{cutout}
\end{cases}$$

3. Methodology

Wind potential estimation and energy generation in South Punjab, an expectedly high potential area in Punjab, was investigated using two-parameter Weibull Distribution function. Five years hourly recorded wind data at 50 m height was collected at eleven stations in South Punjab. Three methods to estimate Weibull parameters namely EPFM, MOM and MMOM were used and their comparative analysis was carried out based on \mathbb{R}^2 , RMSE and P.E. monthly, seasonal and annual variations in wind speed, WPD and WED were observed. V_{mp} and V_{opt} were calculated using the method found the most accurate of three methods. Polar diagrams were drawn to demonstrate optimum wind direction at each of the investigated location. Finally, actual power produced from six turbine models from different manufacturers along with energy generation per year was also determined.

4. Results and discussions

4.1. Measure of goodness of fit

Three methods i.e. EPFM, MOM and MMOM were compared based upon three statistical measures i.e. R², RMSE and P.E. Table 1 lists the values of Weibull Shape (K) and Scale (C) parameters calculated from all three methods for all locations. These values have been listed upto 5 decimal points with a view to making an in-depth comparison. Comparative analysis between MOM and MMOM shows that MMOM is superior in performance to MOM against all statistical tests of performance checking i.e. R², RMSE and P.E. Similarly, comparison between MMOM and EPFM shows that MMOM is better than EPFM when compared w.r.t P.E for all locations. However, MMOM has been found better than EPFM upto 63% and 55% against R² RMSE respectively. Comparison between MOM and EPFM shows that MOM is superior to EPFM w.r.t P.E. for all locations; superior to EPFM for 63% locations against R² and inferior to EPFM for about 72% locations.

4.2. Weibull distribution


Weibull distribution estimates the actual wind data with significant accuracy. Table 1 shows that Weibull distribution estimates the actual data accurately with a minimum accuracy of more than 90% and for many locations more than 95%. Thus Weibull distribution has been found to give an accurate fit for all locations. The Weibull diagrams for all locations showing a comparison between three methods and actual data have been shown in Fig. 1.

4.3. Monthly, seasonal and annual variation in wind speeds

Monthly and average wind speed values have been listed in Tables 3 and 4 respectively. Graphically, monthly, seasonal and yearly mean wind speeds have been shown in Figs. 2–4 respectively. Analysis shows that at each of the investigated location, maximum mean wind speed occurs during summer season (Layyah shows exceptional behavior where maximum wind speed occurs during spring season) while minimum wind speed is observed during winter season (D.G. Khan and Muzaffargarh show exceptional behaviors with minimum wind speed occurring in autumn season). Comparison among investigated sites shows that Rahim Yar Khan (RYK) has the highest wind speed with 3.58, 4.28, 5.76 and 3.89 m s⁻¹ winter, spring, summer and autumn respectively with annual mean value of 4.38 m s⁻¹.

4.4. Monthly, seasonal and annual variation wind power and energy density

Monthly and annual WPD values are listed in Tables 3 and 4. Furthermore, monthly, seasonal and annual variation in WPD have been graphically represented in Figs. 5-7 respectively. Analysis shows that at each of the investigated location, highest WPD has been observed in summer season while lowest has been observed in winter (D.G. Khan and Layyah show exceptional behavior where lowest WPD has been observed in autumn). Moreover, RYK has the highest mean WPD of 42.84 W m^{-2} , 63.79 W m^{-2} , 149.42 W m^{-2} and 52.36 W m^{-2} in winter, spring, summer and autumn respectively with yearly average value of 77.10 W m⁻². Similarly, monthly, seasonal and annual variation in WED has been shown in Figs. 8-10 respectively. Analysis shows that the trend of variation in wind energy density is exactly same as wind power density. Moreover, RYK possesses highest WED with 91.50, 140.96, 329.21 and 113.95 kWh m^{-2} season⁻¹ in winter, spring, summer and autumn respectively with yearly value of 675.62 $kWh m^{-2} year^{-1}$.



 $\textbf{Fig. 1.} \ \ \textbf{Comparison of actual probability distribution with Weibull distribution.}$




Fig. 2. Monthly variation in wind speed at 11 locations in South Punjab.

Table 1
Comparison of three methods for estimating Weibull parameters.

Location	EPFM					MOM					MMOM				
	K	C (m s ⁻¹)	R ²	RMSE	P.E	K	C (m s ⁻¹)	R ²	RMSE	P.E	K	C (m s ⁻¹)	\mathbb{R}^2	RMSE	P.E
Bahawalnagar	3.06936	3.95905	0.97861	0.00240	0.12607	2.86558	4.06203	0.97444	0.01813	0.02741	2.68751	4.04015	0.97743	0.00461	0.01106
Bahawalpur	3.02400	4.53800	0.95594	0.00182	0.19589	2.61076	4.65206	0.96656	0.00989	0.06782	2.51076	4.66064	0.96918	0.00492	0.03972
D.G. Khan	3.51600	4.28400	0.95229	0.00123	0.06823	3.86208	4.37971	0.93128	0.01019	0.02664	3.49482	4.36980	0.94251	0.01012	0.00945
Multan	3.01265	4.09420	0.95185	0.00305	0.15143	2.65256	4.17722	0.95924	0.00248	0.04059	2.53260	4.15631	0.96395	0.00244	0.02825
Muzaffargarh	3.01911	4.24947	0.95374	0.00235	0.12947	2.76818	4.33428	0.95399	0.00618	0.03832	2.63155	4.31320	0.95871	0.00282	0.02565
Rahim Yar Khan	3.14164	4.79035	0.95776	0.00113	0.15305	2.74358	4.92905	0.97114	0.00515	0.01962	2.67566	4.90755	0.97437	0.01855	0.01915
Khanewal	3.01265	4.09420	0.95183	0.00305	0.15143	2.65528	4.17712	0.95904	0.02110	0.04123	2.53636	4.15747	0.96366	0.00239	0.02835
Layyah	3.68866	4.05509	0.95928	0.00680	0.06045	4.39488	4.15238	0.94233	0.00844	0.02304	3.90353	4.14870	0.94932	0.00109	0.00632
Lodhran	3.02109	4.37696	0.96510	0.01229	0.15153	2.64118	4.46988	0.97228	0.00232	0.05590	2.58763	4.41882	0.97694	0.00174	0.03453
Rajanpur	3.41524	4.71628	0.95836	0.00785	0.07952	3.52568	4.83132	0.94458	0.00489	0.01949	3.38730	4.82333	0.95018	0.00101	0.01295
Vehari	3.07559	4.08576	0.95864	0.02101	0.13533	2.75235	4.16182	0.96332	0.00366	0.03852	2.60283	4.14033	0.96793	0.00290	0.02334

4.5. Most probable and optimum wind speed

The analysis of Tables 2 and 4 shows that Rajanpur has the highest value of V_{mp} as 4.34 m s⁻¹ and Bahawalnagar carries the lowest as 3.49 m s⁻¹ The highest V_{opt} is observed for RYK as 6.07 m s⁻¹ and the minimum is for Layyah i.e. 4.59 m s⁻¹ (lower than that of Bahawalnagar i.e. 4.89 m s⁻¹) (see Table 5).

4.6. Wind speed distribution

Cumulative frequency distribution has been shown in Fig. 11. Analysis shows that at the highest wind potential area i.e. RYK, wind blows at a speed greater than 3 m s $^{-1}$ with more than 75% cumulative probability whereas for Bahawalnagar the wind blows at a speed greater than 3 m s $^{-1}$ with approximately 62% cumulative frequency value. Wind speed of greater than 3 m s $^{-1}$ is important as most of the wind turbines have cut-in speed equal to 3 m s $^{-1}$.

4.7. Polar diagrams

Polar diagrams are very important to show the optimum direction in which the wind blows at a certain location. The determination of this direction is important as the amount of energy extraction surely relies on the direction in which the turbine is installed. In Fig. 12, the polar diagrams have been shown for all 11 locations and results show that in South Punjab, the optimum direction for almost all locations is Southwest (SW).

4.8. Energy production from wind turbines

Energy production per year using six turbine models from different manufacturers has been investigated. These turbines were selected for two reasons. Firstly, these are the most preferably used turbines in Pakistan, and secondly, these turbines are available at the same hub height (50 m) at which this potential estimation has been conducted. Turbine models used in this study are listed with their specifications in Table 6. It can be observed that all these models are available at 50 m height. Table 7 enlists power and annual energy production from various models and CF estimation at each of the investigated location in South Punjab.

It can be observed that at RYK, the highest energy output per year is 1743.85 MWh by Bonus 1300/62 and minimum is 777.59 MWh by Vestas V42. Same behavior can be analyzed for other locations also. From this observation, it can be easily concluded that wind energy production does not depend only on the wind potential of the site (as one might expect) but also on turbine characteristics.

5. Conclusion

Wind potential in a region of South Punjab has been investigated using two-parameter Weibull distribution with 5 years hourly average wind data. Three Weibull parameters estimation method i.e. EPFM, MOM and MMOM were used and compared based upon three statistical measures i.e. R², RMSE and P.E. monthly, seasonal and annual variation in wind speed, wind power density and wind energy density were analyzed. The following conclusions have been drawn from the analysis:

i MMOM is better than MOM against all statistical tests of performance evaluation. Similarly, comparison between MMOM and EPFM shows that MMOM is better than EPFM when compared w.r.t P.E for all locations. However, it has been found better than EPFM upto 63% and 55% against R² and RMSE respectively. So overall it can be concluded that MMOM is also better than EPFM.




Fig. 3. Seasonal variation in wind speed at 11 locations in South Punjab.




Fig. 4. Yearly average and 5-years average wind speeds (m s^{-1}).




Fig. 5. Monthly variation in wind power density at 11 locations in South Punjab.




Fig. 6. Seasonal variation in wind power density at 11 locations in South Punjab.




Fig. 7. Yearly average and 5-years average wind power densities (W m⁻²).




Fig. 8. Monthly variation in wind energy density at 11 locations in South Punjab.




Fig. 9. Seasonal variation in wind energy density at 11 locations in South Punjab.




Fig. 10. Yearly average and 5-years average wind energy densities (kWh m⁻² year⁻¹).

Table 2 Monthly average values of Weibull shape and scale (m s⁻¹) parameters.

		Jan	Feb	March	April	May	June	July	August	Sep	Oct	Nov	Dec
Bahawalnagar	K	2.90	2.85	3.40	3.47	3.28	2.54	2.95	2.92	3.32	3.18	2.94	3.07
_	C	3.28	3.76	3.75	4.37	4.17	4.84	4.64	4.80	4.25	3.24	3.29	3.13
Bahawalpur	K	2.81	2.95	3.28	3.34	3.19	2.62	2.90	3.40	3.31	2.87	2.78	2.83
	C	3.67	4.10	4.33	4.40	4.71	5.45	5.77	5.96	5.45	3.74	3.47	3.42
D.G. Khan	K	3.62	3.53	3.60	3.46	3.03	3.70	3.30	3.51	3.46	3.65	3.59	3.71
	C	3.83	4.41	4.37	4.48	4.34	4.53	4.80	4.87	3.98	3.79	4.05	3.94
Khanewal	K	2.91	3.05	3.47	3.25	3.01	2.66	2.81	3.24	2.99	3.16	2.66	2.94
	C	3.33	3.88	4.04	4.27	3.93	4.99	5.13	5.56	4.44	3.07	3.31	3.17
Layyah	K	3.73	3.77	3.70	3.75	3.42	3.74	3.41	3.65	3.65	3.87	3.85	3.69
	C	3.77	4.27	4.26	4.27	4.25	4.15	4.31	4.10	3.61	3.71	4.01	3.94
Lodhran	K	2.86	3.04	3.37	3.31	3.08	2.60	2.81	3.31	3.28	3.07	2.69	2.83
	C	3.53	4.01	4.23	4.34	4.26	5.53	5.52	5.83	5.04	3.44	3.43	3.35
Multan	K	2.91	3.05	3.47	3.25	3.01	2.66	2.81	3.24	2.99	3.16	2.66	2.94
	C	3.33	3.88	4.04	4.27	3.93	4.99	5.13	5.56	4.44	3.07	3.31	3.17
Muzaffargarh	K	2.95	3.09	3.44	3.20	2.82	2.99	2.99	3.34	2.72	2.90	2.75	3.03
	C	3.53	4.18	4.25	4.36	4.09	4.99	5.33	5.67	4.22	3.20	3.70	3.47
RYK	K	2.61	2.76	3.05	3.28	3.31	3.13	3.43	3.78	3.56	3.10	2.93	2.75
	C	3.89	4.44	4.45	4.61	5.01	6.51	6.23	5.95	5.40	3.85	3.49	3.66
Rajanpur	K	3.42	3.27	3.48	3.54	3.20	3.01	3.30	3.53	3.51	3.52	3.65	3.53
	C	4.06	4.65	4.52	4.83	4.95	5.48	5.48	5.49	4.91	4.08	4.06	4.09
Vehari	K	2.91	2.98	3.47	3.39	3.14	2.71	2.77	3.18	3.20	3.29	2.85	3.02
	C	3.28	3.83	4.04	4.35	3.96	5.12	4.93	5.35	4.51	3.22	3.30	3.13

Table 3 Monthly average wind speed (m $\rm s^{-1}$) and wind power densities (W $\rm m^{-2}$).

Wind speed	Jan	Feb	March	April	May	June	July	August	Sep	Oct	Nov	Dec
Bahawalnagar	2.96	3.40	3.42	4.04	3.81	4.34	4.18	4.33	3.89	2.95	2.97	2.84
Bahawalpur	3.30	3.70	3.97	4.04	4.29	5.33	5.21	5.49	5.01	3.37	3.12	3.08
D.G. Khan	3.56	4.08	4.06	4.13	3.94	4.23	4.42	4.52	3.67	3.53	3.75	3.67
Khanewal	3.00	3.51	3.74	3.91	3.56	4.48	4.62	5.08	4.03	2.80	2.97	2.86
Layyah	3.56	3.98	3.96	3.98	3.89	3.89	3.99	3.85	3.38	3.50	3.76	3.67
Lodhran	3.17	3.63	3.90	3.99	3.87	4.96	4.96	5.35	4.63	3.13	3.07	3.01
Multan	3.10	3.61	3.84	4.01	3.66	4.58	4.72	5.18	4.13	2.90	3.07	2.96
Muzaffargarh	3.19	3.79	3.92	3.97	3.68	4.52	4.84	5.21	3.79	2.89	3.32	3.18
RYK	3.48	3.98	4.03	4.22	4.59	5.92	5.76	5.60	5.02	3.49	3.17	3.28
Rajanpur	3.73	4.25	4.16	4.47	4.51	4.95	5.04	5.10	4.55	3.77	3.78	3.78
Vehari	2.96	3.47	3.74	4.00	3.62	4.61	4.43	4.87	4.12	2.97	2.97	2.83
WPD	Jan	Feb	March	April	May	June	July	August	Sep	Oct	Nov	Dec
Bahawalnagar	22.32	34.37	32.59	49.59	44.15	80.61	62.07	72.30	47.21	20.72	23.02	18.85
Bahawalpur	31.65	43.12	48.69	51.48	65.97	132.34	122.42	130.30	98.80	33.50	27.13	25.52
D.G. Khan	32.59	50.94	48.12	53.38	50.88	56.22	70.50	72.32	38.39	31.64	39.15	35.28
Khanewal	23.37	36.17	39.00	47.35	37.69	86.48	90.54	109.41	56.72	17.93	24.15	20.03
Layyah	30.73	45.00	44.45	45.23	46.47	43.37	50.75	42.90	27.94	29.36	37.85	35.48
Lodhran	27.94	39.92	45.15	49.80	47.80	119.11	109.51	124.20	79.53	25.19	26.63	24.06
Multan	30.37	42.17	45.00	53.35	43.69	92.48	96.54	116.41	63.72	24.93	31.15	27.03
Muzaffargarh	27.84	45.40	45.29	50.42	43.85	81.39	100.22	115.09	51.75	20.84	32.63	26.47
RYK	39.71	57.11	54.22	58.85	78.29	178.69	144.89	124.67	93.18	36.12	27.77	31.69
Rajanpur	39.90	60.94	54.07	67.23	74.27	107.54	100.01	100.68	70.52	39.64	39.10	39.80
Vehari	22.63	35.20	38.90	49.47	38.13	93.45	79.59	97.76	57.17	20.24	23.29	18.93

Table 4 Annual average wind speeds (m s^{-1}), Shape (K), Scale, C (m s^{-1}) parameters and wind power density, WPD (W m^{-2}) for South Punjab.

Location	2014			2015	2015			2016	2016			2017			2018					
	V _{avg}	K	С	WPD	$\overline{V_{avg}}$	K	С	WPD	$\overline{V_{avg}}$	K	С	WPD	V _{avg}	K	С	WPD	V _{avg}	K	С	WPD
Bahawalnagar	3.68	2.72	4.14	45.55	3.51	2.82	3.98	39.75	3.38	2.98	3.87	35.71	3.50	2.74	3.95	39.51	3.90	3.07	4.36	50.36
Bahawalpur	4.35	3.15	4.77	65.20	4.12	2.99	4.53	57.02	3.94	2.97	4.16	44.28	3.96	2.89	4.38	52.33	4.42	3.12	4.85	68.78
D.G Khan	3.80	3.46	4.13	41.03	3.82	2.77	4.06	42.64	3.81	2.81	3.85	36.01	3.96	2.57	4.06	44.46	4.42	3.66	4.72	60.16
Multan	3.72	2.44	4.20	50.65	3.62	2.87	4.02	40.59	3.43	2.93	3.80	33.96	3.60	2.98	3.98	38.73	4.19	3.26	4.57	56.64
Muzaffargarh	3.78	2.36	4.22	52.80	3.75	2.78	4.19	46.79	3.62	2.86	4.03	40.95	3.81	2.57	4.27	51.65	4.33	2.59	4.85	75.40
Rahim Yar Khan	4.54	2.48	5.09	89.55	4.45	3.10	4.97	74.23	4.19	2.74	4.70	66.32	4.15	2.59	4.66	66.82	4.55	2.47	5.12	91.18
Khanewal	3.72	3.02	4.10	42.21	3.62	3.94	4.02	36.73	3.43	4.11	4.12	39.26	3.60	4.11	4.12	39.26	4.19	4.15	4.63	55.59
Layyah	3.66	3.87	4.01	36.57	3.60	3.44	3.95	36.09	3.67	3.67	3.93	34.88	3.77	3.71	4.03	37.32	4.23	3.80	4.50	51.79
Lodhran	4.08	2.38	4.58	67.16	3.92	2.69	4.39	54.59	3.69	2.62	4.12	45.94	3.81	2.58	4.30	52.74	4.36	2.57	4.89	77.54
Rajanpur	4.38	3.00	4.86	70.29	4.33	3.72	4.81	63.75	4.10	3.53	4.58	55.67	4.23	3.30	4.69	60.96	4.67	3.39	5.17	81.12
Vehari	3.75	2.43	4.20	50.94	3.60	2.70	4.03	42.06	3.45	2.72	3.85	36.51	3.57	2.97	3.99	39.09	4.22	2.70	4.64	64.31

ii Comparison between MOM and EPFM shows that MOM is better than EPFM upto 100% and 63% w.r.t P.E. and R² respectively. However, EPFM has been found better than

MOM for about 72% locations w.r.t RMSE. Overall, MMOM can be declared as the best method followed by MOM and EPFM respectively.

Table 5Yearly $(m s^{-1}).$	mo	st pi	obable,	$V_{mp}(\mathbf{m}$	s ⁻¹)	and	optimum	wind	speed,	V_{opt}
Location	2014		201	5	20	16	2017		2018	
	$\overline{V_{mp}}$	Vopt	$\overline{V_{mp}}$	V _{opt}	$\overline{V_{m_i}}$, V _{op}	V_{mp}	V _{opt}	$\overline{V_{mp}}$	V _{opt}
Bahawalnagar	3.50	5.07	3.41	4.81	3.3	8 4.6	0 3.35	4.83	3.83	5.14
Bahawalpur	4.23	5.58	3.95	5.38	3.6	2 4.9	5 3.78	5.25	4.29	5.68
D.G Khan	3.74	4.71	3.46	4.94	3.2	9 4.6	6 3.35	5.08	4.32	5.31
Multan	3.38	5.36	3.46	4.83	3.3	0 4.5	4 3.47	4.73	4.08	5.29
Muzaffargarh	3.34	5.47	3.57	5.10	3.4	6 4.8	5 3.52	5.34	4.02	6.05
Rahim Yar Khan	4.13	6.47	4.38	5.84	3.9	8 5.7	4 3.86	5.81	4.15	6.51
Khanewal	3.59	4.86	3.73	4.46	3.8	5 4.5	4 3.85	4.54	4.34	5.09
Layyah	3.71	4.47	3.58	4.52	3.6	1 4.4	3 3.70	4.52	4.15	5.03
Lodhran	3.65	5.92	3.70	5.39	3.4	3 5.1	2 3.56	5.38	4.04	6.12
Rajanpur	4.25	5.76	4.43	5.40	4.1	7 5.2	0 4.20	5.41	4.67	5.93
Vehari	3.38	5.38	3.39	4.94	3.2	5 4.7	1 3.48	4.75	3.91	5.69




Fig. 11. Cumulative probability distribution for South Punjab.




Fig. 12. Polar diagrams - showing the optimum wind direction - for South Punjab.

- iii Monthly and seasonal analysis shows that entire region has highest wind speed, WPD and WED in summer season followed by spring, autumn and winter respectively.
- iv RYK is the highly windy area with maximum wind speed, WPD and WED as 4.38 m s⁻¹, 77.10 W m⁻² and 675.60 kWh m⁻² year⁻¹ respectively.
- v On the other hand, Bahawalnagar is the poorest area as far as wind speed is concerned. But the minimum WPD and WED has been observed for Layyah rather than Bahawalnagar. The difference is associated with the difference in V_{opt} values.
- vi At same location, different turbine models produce different power and energy output per year with different

Table 6Different turbine models with their specifications.

Turbine model	P _R (kW)	$A_T \ (m^2)$	V _{cin} (m s ⁻¹)	V_R (m s ⁻¹)	V _{cout} (m s ⁻¹)	Hub height (m)
Bonus 1300/62	1300	3018	3	14	24	50, 60, 68, 80
Bonus 1 MW/54	1000	2300	3	15	25	50, 60
Bonus 600/44	600	1520	3	13	25	40, 45, 50, 60
Vestas V42	600	1385	4	17	25	35, 40, 50, 55
GE600a	600	1662	3	14	20	50
Enercon E-40/600	600	1520	2.5	12	28	46, 50, 58, 65

capacity factor. Therefore, choice of turbine at particular location is also important.

Table 7Power production, P_n (kW), annual energy production (MWh) and capacity factors, C.F (%) for various locations in South Punjab.

C.F. 8.36 8.33 9.20 6.60 10.07 9.67 Bahawalpur Pp 170.05 130.87 86.89 70.68 95.00 88.09 Bahawalpur Energy 1489.64 1146.42 750.18 610.15 815.24 761.99 C.F. 13.08 13.09 14.48 11.78 15.83 14.68 D.G. Khan Energy 1187.94 909.38 605.67 460.78 664.01 616.70 C.F. 10.43 10.38 11.52 8.77 12.63 11.73 Multan Energy 1081.42 824.75 54.51 416.54 603.56 573.78 C.F. 9.50 9.42 10.55 7.93 11.48 10.92 Muzaffargarh Energy 1218.17 932.68 622.57 482.76 678.99 641.58 C.F. 10.70 10.65 11.85 9.19 12.92 12.21 Muzaffargarh Energy 1343.5	Location	Turbine model	Bonus 1300/62	Bonus 1 MW/54	Bonus 600/44	Vestas V42	GE600a	Enercon E-40/600
C.F. 8.36 8.33 9.20 6.60 10.07 9.67		Pp	108.15	83.25	55.15	39.58	60.45	58.01
Pp	Bahawalnagar	Energy	947.34	729.27	483.11	346.72	529.54	508.17
Bahawalpur Energy CF 1489.64 1146.42 13.09 750.18 11.78 610.15 15.24 761.99 761.99 CF 13.08 13.09 14.48 11.78 15.83 14.68 D.G. Khan Energy 1187.94 909.38 605.67 460.78 664.01 616.70 C.F 10.43 10.38 11.52 8.77 12.63 11.73 Multan Energy 1081.42 824.75 554.51 416.54 603.56 573.78 Muzaffargarh Energy 139.06 106.47 71.07 55.11 77.51 73.24 Muzaffargarh Energy 1218.17 932.68 622.57 482.76 678.99 641.58 C.F 10.70 10.65 11.85 9.19 12.92 12.21 RYK Energy 1743.85 1333.36 887.30 737.59 968.51 901.49 C.F 15.31 15.22 16.88 14.03 18.43 17.15 Ryman 1743.85 1333.36 <td></td> <td>C.F</td> <td>8.36</td> <td>8.33</td> <td>9.20</td> <td>6.60</td> <td>10.07</td> <td>9.67</td>		C.F	8.36	8.33	9.20	6.60	10.07	9.67
CF 13.08 13.09 14.48 11.78 15.83 14.68 Pp 135.61 103.81 69.14 52.60 75.80 70.40 D.G. Khan Energy 1187.94 999.38 605.67 460.78 664.01 616.70 C.F 10.43 10.38 11.52 8.77 12.63 11.73 Multan Pp 123.45 94.15 63.30 47.55 68.90 655.0 Multan Energy 1081.42 824.75 554.51 416.54 603.56 573.78 C.F 9.50 9.42 10.55 7.93 11.48 10.92 Muzaffargarh Pp 139.06 106.47 71.07 55.11 77.51 73.24 Muzaffargarh Energy 1218.17 932.68 622.57 482.76 678.99 641.58 RYK Energy 1743.85 1333.36 887.30 737.59 968.51 901.49 RYK Energy 182.		Рр	170.05	130.87	86.89	70.68	95.00	88.09
Pp	Bahawalpur	Energy	1489.64	1146.42	750.18	610.15	815.24	
D.G. Khan Energy C.F 1187.94 10.43 909.38 11.52 8.77 460.78 12.63 11.73 664.01 616.70 11.73 Multan Pp 123.45 94.15 94.15 53.30 47.55 68.90 65.50 65.50 10.647 71.07 55.45 416.54 603.56 573.78 10.62 73.78 11.48 10.92 Multan Energy 10814.2 824.75 554.51 416.54 603.56 573.78 11.48 10.92 10.55 7.93 11.48 10.92 10.55 7.93 11.48 10.92 10.55 79.31 11.48 10.92 10.55 79.31 11.48 10.92 10.55 79.31 11.48 10.92 10.50 79.31 11.48 10.92 10.50 79.31 11.49 10.92 10.50 79.31 11.49 10.92 10.50 79.31 11.49 10.92 10.50 79.31 11.49 10.92 10.50 79.31 10.50 79.31 11.49 10.92 10.50 79.31 10.50 79.31 10.50 79.31 10.50 79.31 79.59 641.58 10.29 10.50 79.31 79		C.F	13.08	13.09	14.48	11.78	15.83	14.68
C.F 10.43 10.38 11.52 8.77 12.63 11.73 Multan Pp 123.45 94.15 63.30 47.55 68.90 65.50 Multan Energy 1081.42 824.75 554.51 416.54 603.56 573.78 C.F 9.50 9.42 10.55 7.93 11.48 10.92 Muzaffargarh Energy 1218.17 932.68 622.57 482.76 678.99 641.58 C.F 10.70 10.65 11.85 9.19 12.92 12.21 RYK Energy 1743.85 1333.36 887.30 737.59 968.51 901.49 RYK Energy 1743.85 1333.36 887.30 737.59 968.51 901.49 RYK Energy 1743.85 1333.36 887.30 737.59 968.51 901.49 Khanewal Energy 1082.65 829.40 554.25 416.80 604.35 574.92 Khanewal		Pp	135.61		69.14		75.80	
Pp	D.G. Khan		1187.94	909.38	605.67		664.01	616.70
Multan Energy C.F 1081.42 9.50 824.75 9.50 554.51 9.42 416.54 16.54 16.54 10.92 603.56 573.78 10.92 Muzaffargarh Pp 139.06 106.47 7.107 7.107 7.51.1 77.51 73.24 77.51 77.51 73.24 77.51 77.51 73.24 Muzaffargarh Energy 1218.17 932.68 622.57 482.76 678.99 641.58 67.89 641.58 7.50 10.70 10.65 11.85 9.19 12.92 12.21 67.89 641.58 7.50 10.70 10.65 11.85 9.19 12.92 12.21 101.29 84.20 110.56 102.91 10.56 102.91 10.56 102.91 10.56 102.91 10.56 102.91 10.56 102.91 10.56 10.91 10.56 10.91 10.56 10.91		C.F	10.43	10.38	11.52	8.77	12.63	11.73
CF 9.50 9.42 10.55 7.93 11.48 10.92 Muzaffargarh Pp 139.06 106.47 71.07 55.11 77.51 73.24 Muzaffargarh Energy 1218.17 932.68 622.57 482.76 678.99 641.58 CF 10.70 10.65 11.85 9.19 12.92 12.21 RYK Pp 199.07 152.21 101.29 84.20 110.56 102.91 RYK Energy 1743.85 1333.36 887.30 737.59 968.51 901.49 Energy 1743.85 1333.36 887.30 737.59 968.51 901.49 Energy 162.51 15.22 16.88 14.03 18.43 17.15 Khanewal Energy 1082.65 829.40 554.25 416.80 604.35 574.92 C.F 9.51 9.47 10.55 7.93 11.50 10.94 Layyah Energy 112.55		Pp						
Pp	Multan							
Muzaffargarh Energy C.F 1218.17 10.70 932.68 11.85 622.57 11.85 482.76 9.19 678.99 641.58 12.21 RYK Pp 199.07 152.21 101.29 84.20 110.56 102.91 102.91 RYK Energy 1743.85 1333.36 887.30 737.59 968.51 901.49 968.51 901.49 C.F 15.31 15.22 16.88 14.03 18.43 17.15 Pp 123.59 94.68 63.27 47.58 68.99 65.63 Khanewal Energy 1082.65 829.40 554.25 416.80 604.35 574.92 C.F 9.51 9.47 10.55 7.93 11.50 10.94 Layyah Pp 112.55 86.27 57.71 40.65 62.91 60.15 Layyah Energy 985.94 755.73 505.54 356.09 551.09 526.91 C.F 8.66 8.63 9.62 6.78 10.49 10.03 Lodhran Pp 152.63 116.81 77.90 61.72 84.98 79.93 Lodhran Energy 1337.04 1023.26 682.40 540.67 744.42 700.19 C.F 11.74 11.68 12.98 10.29 14.16 13.32 Rajanpur Pp 184.79 141.32 94.10 77.11 102.60 95.72 Rajanpur Energy 1618.76 1237.96 824.32 675.48 898.78 838.51 C.F 14.21 14.13 15.68 12.85 17.10 15.95 Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95		C.F	9.50	9.42	10.55	7.93	11.48	10.92
C.F 10.70 10.65 11.85 9.19 12.92 12.21 RYK Pp 199.07 152.21 101.29 84.20 110.56 102.91 RYK Energy 1743.85 1333.36 887.30 737.59 968.51 901.49 C.F 15.31 15.22 16.88 14.03 18.43 17.15 Khanewal Pp 123.59 94.68 63.27 47.58 68.99 65.63 Khanewal Energy 1082.65 829.40 554.25 416.80 604.35 574.92 C.F 9.51 9.47 10.55 7.93 11.50 10.94 Layyah Energy 985.94 755.73 505.54 356.09 551.09 526.91 Layyah Energy 985.94 755.73 505.54 356.09 551.09 526.91 Lodhran Energy 1337.04 1023.26 682.40 540.67 744.42 700.19 C.F 11.74		Pp	139.06	106.47	71.07			
RYK Pp 199,07 152,21 101,29 84,20 110,56 102,91 RYK Energy 1743,85 1333,36 887,30 737,59 968,51 901,49 C.F 15,31 15,22 16,88 14,03 18,43 17,15 Khanewal Pp 123,59 94,68 63,27 47,58 68,99 65,63 Khanewal Energy 1082,65 829,40 554,25 416,80 604,35 574,92 C.F 9,51 9,47 10,55 7,93 11,50 10,94 Layyah Pp 112,55 86,27 57,71 40,65 62,91 60,15 Layyah Energy 985,94 755,73 505,54 356,09 551,09 526,91 Lodhran Pp 152,63 116,81 77,90 61,72 84,98 79,93 Lodhran Energy 1337,04 1023,26 682,40 540,67 744,42 700,19	Muzaffargarh	Energy	1218.17	932.68	622.57	482.76	678.99	641.58
RYK Energy C.F 1743.85 1333.36 15.22 16.88 14.03 18.43 17.15 Pp 123.59 94.68 63.27 47.58 68.99 65.63 65.63 60.435 60.		C.F	10.70	10.65	11.85	9.19	12.92	12.21
C.F 15.31 15.22 16.88 14.03 18.43 17.15 Pp 123.59 94.68 63.27 47.58 68.99 65.63 Khanewal Energy 1082.65 829.40 554.25 416.80 604.35 574.92 C.F 9.51 9.47 10.55 7.93 11.50 10.94 Layyah Pp 112.55 86.27 57.71 40.65 62.91 60.15 Layyah Energy 985.94 755.73 505.54 356.09 551.09 526.91 Lowyah Energy 8.66 8.63 9.62 6.78 10.49 10.03 Lodhran Pp 152.63 116.81 77.90 61.72 84.98 79.93 Lodhran Energy 1337.04 1023.26 682.40 540.67 744.42 700.19 C.F 11.74 11.68 12.98 10.29 14.16 13.32 Rajanpur Energy 1618.76		Pp	199.07					
Pp	RYK		1743.85				968.51	
Khanewal Energy C.F 1082.65 829.40 554.25 416.80 604.35 574.92 Layyah Pp 112.55 86.27 57.71 40.65 62.91 60.15 Layyah Energy 985.94 755.73 505.54 356.09 551.09 526.91 C.F 8.66 8.63 9.62 6.78 10.49 10.03 Lodhran Pp 152.63 116.81 77.90 61.72 84.98 79.93 Lodhran Energy 1337.04 1023.26 682.40 540.67 744.42 700.19 C.F 11.74 11.68 12.98 10.29 14.16 13.32 Rajanpur Energy 1618.76 1237.96 824.32 675.48 898.78 838.51 C.F 14.21 14.13 15.68 12.85 17.10 15.95 Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95		C.F	15.31	15.22	16.88	14.03	18.43	17.15
C.F 9.51 9.47 10.55 7.93 11.50 10.94 Layyah Pp 112.55 86.27 57.71 40.65 62.91 60.15 Layyah Energy 985.94 755.73 505.54 356.09 551.09 526.91 C.F 8.66 8.63 9.62 6.78 10.49 10.03 Lodhran Pp 152.63 116.81 77.90 61.72 84.98 79.93 Lodhran Energy 1337.04 1023.26 682.40 540.67 744.42 700.19 C.F 11.74 11.68 12.98 10.29 14.16 13.32 Rajanpur Energy 1618.76 1237.96 824.32 675.48 898.78 838.51 C.F 14.21 14.13 15.68 12.85 17.10 15.95 Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95		Рр	123.59	94.68	63.27	47.58	68.99	65.63
Pp	Khanewal							
Layyah Energy C.F 985.94 8.66 755.73 8.63 505.54 9.62 356.09 6.78 551.09 10.03 526.91 10.03 Lodhran Pp 152.63 116.81 1023.26 77.90 682.40 61.72 540.67 84.98 79.93 79.93 700.19 Lodhran Energy C.F 117.4 116.81 11.68 12.98 12.98 10.29 10.29 14.16 14.16 13.32 Pp 184.79 141.32 1237.96 94.10 824.32 77.11 675.48 102.60 898.78 95.72 838.51 17.10 Energy C.F 14.21 14.13 15.68 12.85 12.85 17.10 17.10 15.95 Pp 121.76 12.76 93.28 17.13 62.35 17.10 407.69 17.69 595.50 566.95		C.F	9.51	9.47	10.55	7.93	11.50	10.94
C.F. 8.66 8.63 9.62 6.78 10.49 10.03 Lodhran Pp 152.63 116.81 77.90 61.72 84.98 79.93 Lodhran Energy 1337.04 1023.26 682.40 540.67 744.42 700.19 C.F 11.74 11.68 12.98 10.29 14.16 13.32 Rajanpur Pp 184.79 141.32 94.10 77.11 102.60 95.72 Rajanpur Energy 1618.76 1237.96 824.32 675.48 898.78 838.51 C.F 14.21 14.13 15.68 12.85 17.10 15.95 Pp 121.76 93.28 62.35 46.54 67.98 64.72 Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95		Рр						
Pp	Layyah	Energy	985.94			356.09	551.09	526.91
Lodhran Energy C.F 1337.04 11.74 1023.26 11.68 682.40 12.98 540.67 10.29 744.42 14.16 700.19 13.32 Pp 184.79 141.32 94.10 77.11 102.60 95.72 Rajanpur Energy Energy C.F 1618.76 1237.96 824.32 675.48 898.78 838.51 C.F 14.21 14.13 15.68 12.85 17.10 15.95 Pp 121.76 93.28 62.35 46.54 67.98 64.72 Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95		C.F	8.66	8.63	9.62	6.78	10.49	10.03
C.F 11.74 11.68 12.98 10.29 14.16 13.32 Pp 184.79 141.32 94.10 77.11 102.60 95.72 Rajanpur Energy 1618.76 1237.96 824.32 675.48 898.78 838.51 C.F 14.21 14.13 15.68 12.85 17.10 15.95 Pp 121.76 93.28 62.35 46.54 67.98 64.72 Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95		Рр						
Pp 184.79 141.32 94.10 77.11 102.60 95.72 Rajanpur Energy 1618.76 1237.96 824.32 675.48 898.78 838.51 C.F 14.21 14.13 15.68 12.85 17.10 15.95 Pp 121.76 93.28 62.35 46.54 67.98 64.72 Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95	Lodhran							
Rajanpur Energy C.F 1618.76 1237.96 14.13 824.32 15.68 12.85 17.10 15.95 898.78 838.51 15.95 Pp 121.76 93.28 62.35 46.54 67.98 64.72 675.48 67.98 64.72 675.48 67.98 64.72 Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95		C.F	11.74	11.68	12.98	10.29	14.16	13.32
C.F 14.21 14.13 15.68 12.85 17.10 15.95 Pp 121.76 93.28 62.35 46.54 67.98 64.72 Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95		Pp						
Pp 121.76 93.28 62.35 46.54 67.98 64.72 Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95	Rajanpur							
Vehari Energy 1066.62 817.13 546.19 407.69 595.50 566.95		C.F	14.21	14.13	15.68	12.85	17.10	15.95
	·							
C.F 9.37 9.33 10.39 7.76 11.33 10.79	Vehari							
		C.F	9.37	9.33	10.39	7.76	11.33	10.79

CRediT authorship contribution statement

Muhammad Sumair: Conceptualization, Methodology, Software, Writing - review & editing. **Tauseef Aized:** Supervision, Data curation, Writing - original draft. **Syed Asad Raza Gardezi:** Writing - review & editing. **Syed Ubaid ur Rehman:** Software, Validation, Writing - review & editing. **Syed Muhammad Sohail Rehman:** Visualization, Investigation, Writing - review & editing.

Declaration of competing interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Data availability statement

Data generated at a central, large scale facility. Raw data were generated at the Pakistan Meteorological Department, large scale facility. Derived data supporting the findings of this study are available from the corresponding author upon reasonable request

References

Acker, T.L., et al., 2007. Wind resource assessment in the state of Arizona: Inventory, capacity factor, and cost. Renew. Energy 32 (9), 1453–1466.

Aized, T., et al., 2019. Design and analysis of wind pump for wind conditions in Pakistan. Adv. Mech. Eng. 11 (9), 1687814019880405.

Akdağ, S.A., Dinler, A., 2009. A new method to estimate Weibull parameters for wind energy applications. Energy Convers. Manage. 50 (7), 1761–1766.

Akdağ, S.A., Güler, Ö., 2015. A novel energy pattern factor method for wind speed distribution parameter estimation. Energy Convers. Manage. 106, 1124–1133.

Akpinar, E.K., Akpinar, S., 2005. An assessment on seasonal analysis of wind energy characteristics and wind turbine characteristics. Energy Convers. Manage. 46 (11), 1848–1867.

Andrade, C.F.d., et al., 2014. An efficiency comparison of numerical methods for determining Weibull parameters for wind energy applications: A new approach applied to the northeast region of Brazil. Energy Convers. Manage. 86, 801–808.

Azad, A.K., et al., 2014. Analysis of wind energy conversion system using Weibull distribution. Procedia Eng. 90, 725–732.

Bagiorgas, H.S., et al., 2012. Wind power potential assessment for seven buoys data collection stations in Aegean Sea using Weibull distribution function. J. Renew. Sustain. Energy 4 (1), 013119.

Baloch, M.H., Kaloi, G.S., Memon, Z.A., 2016. Current scenario of the wind energy in Pakistan challenges and future perspectives: A case study. Energy Rep. 2, 201–210.

Bilir, L., et al., 2015. Seasonal and yearly wind speed distribution and wind power density analysis based on Weibull distribution function. Int. J. Hydrogen Energy 40 (44), 15301–15310.

Carta, J.A., Ramirez, P., Velazquez, S., 2009. A review of wind speed probability distributions used in wind energy analysis: Case studies in the Canary Islands. Renew. Sustain. Energy Rev. 13 (5), 933–955.

Chang, T.P., 2011. Performance comparison of six numerical methods in estimating Weibull parameters for wind energy application. Appl. Energy 88 (1), 272–282.

Chaurasiya, P.K., Ahmed, S., Warudkar, V., 2017. Study of different parameters estimation methods of Weibull distribution to determine wind power density using ground based Doppler SODAR instrument. Alexandria Eng. J..

Chaurasiya, P.K., Ahmed, S., Warudkar, V., 2018. Study of different parameters estimation methods of Weibull distribution to determine wind power density using ground based Doppler SODAR instrument. Alexandria Eng. J. 57 (4), 2299–2311.

Costa Rocha, P.A., et al., 2012. Comparison of seven numerical methods for determining Weibull parameters for wind energy generation in the northeast region of Brazil. Appl. Energy 89 (1), 395–400.

Dorvlo, A.S.S., 2002. Estimating wind speed distribution. Energy Convers. Manage. 43 (17), 2311–2318.

ETEnergyWorld, 2019. World's top 10 countries in wind energy capacity. 12-02-2020]; Available from: https://energy.economictimes.indiatimes.com/news/renewable/worlds-top-10-countries-in-wind-energy-capacity/68465090.

- Hulio, Z.H., Jiang, W., Rehman, S., 2017. Technical and economic assessment of wind power potential of Nooriabad, Pakistan. Energy Sustain. Soc. 7 (1), 35.
- Hulio, Z.H., Jiang, W., Rehman, S., 2019a. Techno Economic assessment of wind power potential of Hawke's Bay using Weibull parameter: A review. Energy Strategy Rev. 26, 100375
- Hulio, Z.H., Jiang, W., Rehman, S., 2019b. Techno-economic assessment of wind power potential of Hawke's Bay using Weibull parameter: A review. Energy Strategy Rev. 26, 100375.
- IRENA, 2019. Renewable energy statistics 2019.
- Keyhani, A., et al., 2010. An assessment of wind energy potential as a power generation source in the capital of Iran, Tehran. Energy 35 (1), 188–201.
- Khahro, S.F., et al., 2014a. Evaluation of wind power production prospective and Weibull parameter estimation methods for Babaurband, Sindh Pakistan. Energy Convers. Manage. 78, 956–967.
- Khahro, S.F., et al., 2014b. Techno-economical evaluation of wind energy potential and analysis of power generation from wind at Gharo, Sindh Pakistan. Renew. Sustain. Energy Rev. 35, 460–474.
- Kitaneh, R., Alsamamra, H., Aljunaidi, A., 2012. Modeling of wind energy in some areas of Palestine. Energy Convers. Manage. 62, 64–69.
- Lima, L.d.A., Filho, C.R.B., 2012. Wind resource evaluation in São João do Cariri (SJC) Paraiba, Brazil. Renew. Sustain. Energy Rev. 16 (1), 474–480.
- Liu, M.-K., Yocke, M.A., 1980. Siting of wind turbine generators in complex terrain. J. Energy 4 (1), 10–16.
- Lu, L., Yang, H., Burnett, J., 2002. Investigation on wind power potential on Hong Kong islands—an analysis of wind power and wind turbine characteristics. Renew. Energy 27 (1), 1–12.
- Milanese, M., et al., 2017. Numerical method for wind energy analysis applied to Apulia Region, Italy. Energy 128, 1–10.

- Milanese, M., et al., 2019. Numerical method for wind energy analysis in WTG siting. Renew. Energy 136, 202–210.
- Pishgar-Komleh, S., Keyhani, A., Sefeedpari, P., 2015. Wind speed and power density analysis based on Weibull and Rayleigh distributions (a case study: Firouzkooh county of Iran). Renew. Sustain. Energy Rev. 42, 313–322.
- Pobočíková, I., Sedliačková, Z., Michalková, M., 2017. Application of four probability distributions for wind speed modeling. Procedia Eng. 192, 713–718.
- Rehman, S., et al., 2020. Assessment of wind energy potential across varying topographical features of Tamil Nadu, India. Energy Explor. Exploit. 38 (1), 175–200.
- Saleh, H., Abou El-Azm Aly, A., Abdel-Hady, S., 2012. Assessment of different methods used to estimate Weibull distribution parameters for wind speed in Zafarana wind farm, Suez Gulf, Egypt. Energy 44 (1), 710–719.
- Sarim, M., 2019. Pakistan's energy mix. 15-01-2020]; Available from: https://tribune.com.pk/story/1879268/6-pakistans-energy-mix/.
- Shami, S.H., et al., 2016. Evaluating wind energy potential in Pakistan's three provinces, with proposal for integration into national power grid. Renew. Sustain. Energy Rev. 53, 408–421.
- Shoaib, M., et al., 2017. Evaluation of wind power potential in Baburband (Pakistan) using Weibull distribution function. Renew. Sustain. Energy Rev. 70, 1343–1351.
- Shoaib, M., et al., 2019. Assessment of wind energy potential using wind energy conversion system. J. Cleaner Prod. 216, 346–360.
- World Wind Energy Association, 2019. Wind power capacity worldwide reaches 597 GW, 50.1 GW added in 2018. 15-02-2020]; Available from: https://wwindea.org/information-2/information/.