

Schill, Wolf-Peter

**Article — Accepted Manuscript (Postprint)**

## Electricity Storage and the Renewable Energy Transition

Joule

**Provided in Cooperation with:**

German Institute for Economic Research (DIW Berlin)

*Suggested Citation:* Schill, Wolf-Peter (2020) : Electricity Storage and the Renewable Energy Transition, Joule, ISSN 2542-4351, Elsevier BV, Amsterdam, Vol. 4, Iss. 10, pp. 2059-2064, <https://doi.org/10.1016/j.joule.2020.07.022> , <https://www.sciencedirect.com/science/article/pii/S2542435120303408?via%3Dihub>

This Version is available at:

<https://hdl.handle.net/10419/266427>

**Standard-Nutzungsbedingungen:**

Die Dokumente auf EconStor dürfen zu eigenen wissenschaftlichen Zwecken und zum Privatgebrauch gespeichert und kopiert werden.

Sie dürfen die Dokumente nicht für öffentliche oder kommerzielle Zwecke vervielfältigen, öffentlich ausstellen, öffentlich zugänglich machen, vertreiben oder anderweitig nutzen.

Sofern die Verfasser die Dokumente unter Open-Content-Lizenzen (insbesondere CC-Lizenzen) zur Verfügung gestellt haben sollten, gelten abweichend von diesen Nutzungsbedingungen die in der dort genannten Lizenz gewährten Nutzungsrechte.

**Terms of use:**

*Documents in EconStor may be saved and copied for your personal and scholarly purposes.*

*You are not to copy documents for public or commercial purposes, to exhibit the documents publicly, to make them publicly available on the internet, or to distribute or otherwise use the documents in public.*

*If the documents have been made available under an Open Content Licence (especially Creative Commons Licences), you may exercise further usage rights as specified in the indicated licence.*



<https://creativecommons.org/licenses/by-nc-nd/4.0/deed.de>

# Electricity storage and the renewable energy transition

Wolf-Peter Schill<sup>a,b</sup>

<sup>a</sup>*German Institute for Economic Research (DIW Berlin), Mohrenstraße 58, 10117 Berlin, Germany*

<sup>b</sup>*Energy Transition Hub, University of Melbourne, Australia*

---

---

## Introduction

The transition to renewable energy sources is a main strategy for deep decarbonization. In many countries, the potentials of dispatchable renewables — such as hydro power, geothermal, or bioenergy — are limited. The renewable energy transition is thus often driven by wind power and solar photovoltaics (PV). Wind and PV have characteristic features which become increasingly relevant with growing penetration. In particular, their generation patterns are temporally variable, and the spatial distribution of good wind and solar resources does not necessarily coincide with the historical grid layout. Different technological options are available for integrating increasing shares of variable renewable energy sources, often referred to as flexibility options. These include, but are not limited to, various electricity storage technologies.

So what is the role of electricity storage in the renewable energy transition? In this Commentary, I discuss how three different strands of the literature address this question, summarize a few well-established findings, and provide some intuition on how the role of electricity storage changes with increasing shares of renewables and sector coupling. Using residual load duration curves (RLDCs), which are generated with a stylized open-source model, I illustrate that the main driver for electricity storage deployment shifts when the renewable penetration increases toward 100%, from taking up renewable surplus generation to meet-

---

\*Corresponding author  
Email address: [schill@diw.de](mailto:schill@diw.de) (Wolf-Peter Schill)

ing positive residual load. Flexible sector coupling interacts with the former, but hardly with the latter. Based on this, I suggest promising fields for future research and draw a few high-level policy conclusions.

## **Electricity storage: technologies, applications, and competing flexibility options**

Many different electricity storage technologies are available [1]. Electricity storage is broadly defined as any technology that allows taking up electrical energy at one point in time and releasing electrical energy again at a later point in time (*Power-to-Power*). Technologies are available at various scales and can widely differ in round-trip efficiency as well as energy- and power-related costs. This leads to varying energy-to-power (E/P) ratios. These typically do not exceed a few hours for short-term storage, e.g., lithium-ion batteries or pumped hydro storage, but may range from days to weeks for long-term storage, e.g., hydrogen-based electricity storage.

There are many different applications for electricity storage. A major grid-scale application is bulk electricity storage, also referred to as energy arbitrage. It allows increasing the use of generators with low variable costs by shifting their production from periods with low electricity demand (and low prices) to such with higher demand (and higher prices), which becomes increasingly relevant with growing renewable penetration levels.

Aside from energy arbitrage, there are many other uses of electricity storage, which storage facilities may also be able to combine to some extent [2]. These include, but are not limited to, reduced ramping of other generators; the provision of different types of ancillary services, in particular balancing power; the provision of firm capacity; the deferral of transmission or distribution infrastructure investments; and various end-user applications, including power quality and PV self-consumption. Many of these storage applications also become increasingly relevant in the context of renewable energy integration.

Electricity storage, especially short-term storage, competes with many other

50 flexibility options on both the supply and demand side that can also contribute  
to renewable integration [3]:

- *Power-to-Power*: Demand-side management, in particular temporal shifting of conventional electric load, which has a similar function in the power sector as electricity storage;
- 55 • *X-to-Power*: Flexible operation of dispatchable generators, including flexible combined heat and power generation;
- *Power-to-X*: Additional flexible loads (without reconversion to electricity), which arise from coupling the power sector with other sectors, and making use of other forms of energy storage. This includes the mobility sector via  
60 smart charging of battery-electric vehicles, the heating sector via heat pumps or direct resistive heating plus heat storage, and green hydrogen production via electrolysis plus hydrogen storage;
- Expansion of transmission and distribution grids, which facilitates geographical balancing of renewable supply and electricity demand, and may  
65 also address aspects of temporal variability.

Importantly, the mentioned flexibility options do not perfectly substitute each other. For example, demand-side management often offers only short-term flexibility compared to some electricity storage technologies. New flexible loads can take up renewable surplus energy, but usually do not provide electricity back  
70 to the grid. And geographical balancing may only provide limited temporal flexibility, depending on the size of the balancing area.

### **Three strands of research on electricity storage and the renewable energy transition**

There is a rich literature of model-based studies on the role of electricity  
75 storage in the renewable energy transition, considering different renewable penetration levels, geographical contexts, and storage applications. There are three

broad, yet not always distinct, strands of research. The first one focuses on grid-scale electricity storage in traditional power sectors without sector coupling. The second strand builds on the first one, but also includes other types of energy storage related to additional sector coupling. The third strand of research focuses on decentralized PV-batteries for solar prosumage.

#### *Grid-scale electricity storage in traditional power sectors*

One strand of the literature focuses on grid-scale electricity storage (*Power-to-Power*) in traditional power sectors. Many studies find that electricity storage needs remain relatively low up to a share of around 80% renewables, but increase substantially toward 100% renewables, with a growing importance of long-term storage for seasonal balancing. This has been illustrated, for example, for future scenarios of Germany [4], overall Europe [5], and different U.S. regions [6].

Figure 1 illustrates the increasing need for electricity storage and its changing use for stylized settings with 60% or 90% shares of variable renewables in Germany, using residual load duration curves. The residual load of a given time period, e.g., an hour, is the total electric load during this hour, minus the potential generation of variable renewables in the same hour. A residual load duration curve sorts all hourly residual load values of a full year in descending order. With increasing shares of variable renewables, the RLDC does not equally shift downwards, but the right-hand side decreases much faster than the left-hand side because of simultaneity in wind and PV generation. Note that all following illustrations refer to system-wide renewable surpluses, and abstract from local surpluses which may arise due to network constraints. The Figures are generated with a stylized version of the open-source model DIETER, which minimizes total system costs and is available under a permissive license (SI.2).

In the case with 60% renewables, storage is mainly used for taking up renewable surplus generation on the right-hand side of the RLDC and shifting it to hours on the left-hand side where residual load is positive, but low (Figure 1, left panel). Electricity storage accordingly helps to make more efficient use of the installed renewable generation capacity. The optimal electricity storage power

and energy capacity as well as the E/P ratio are relatively low in the 60% case. Note that electricity storage does not completely take up the renewable surplus in a least-cost solution; a sizeable fraction is also curtailed, as investments in  
110 both storage energy and power incur costs. The optimal shares of renewable electricity that are curtailed or stored, and thus the shapes of the RLDCs, depend, amongst other factors, on the costs and availability of different renewable generation and storage technologies (SI.1). Electricity storage also makes a minor contribution to peak residual load coverage on the very left-hand side of the  
115 RLDC, for which also some non-renewable generation may be used. Electricity storage shifts renewable surplus energy largely to periods with low residual load, and not to peak residual load hours, because the latter would require a substantially higher storage energy capacity, which would be more costly than supplying peak load with dispatchable generation.

120 If the renewable share increases to 90%, much more electricity storage is used. This is driven by larger renewable surpluses, but also by an increasing contribution of storage to supplying peak residual load on the very left-hand side of the RLDC (Figure 1, right panel). The optimal storage power capacity substantially increases compared to the 60% case, and the storage energy capacity increases even more, such that the E/P ratio more than doubles. This is  
125 because the renewable surplus not only increases overall, but individual renewable surplus events also become much larger. As a consequence, the number of yearly full storage cycles decreases with increasing renewable penetration.

The literature shows that the optimal deployment of electricity storage further  
130 depends on the availability of other sources of power sector flexibility. For example, the option of curtailing renewable surpluses plays a major role. If renewable curtailment was neglected, vast amounts of electricity storage would be needed even at relatively low renewable penetration rates. Yet storage needs substantially decrease if some temporary renewable curtailment is tolerated [7].  
135 Figure 1 also illustrates this point: without renewable curtailment, a much larger area under the abscissa would have to be integrated by electricity storage. That is, renewable curtailment is a substitute for electricity storage use on




Figure 1: Residual load and electricity storage use in a setting without sector coupling. Stylized illustration for Germany.

the right-hand side of the RLDC.

Increased geographical balancing, facilitated by transmission expansion, is  
 140 another major source of flexibility which can substantially decrease electricity  
 storage needs. This has been numerically demonstrated, for example, in future  
 scenarios of the U.S. [8] and Europe [9]. The larger the balancing area, the lower  
 the optimal storage capacity, as the time series of both electric load and renew-  
 able availability generally differ between locations. Geographical balancing may  
 145 thus flatten the RLDC on both the left- and the right-hand side.

#### *Other types of energy storage related to sector coupling*

A second strand of research not only includes electricity storage technolo-  
 gies, but also other types of energy storage, such as heat or chemical storage,  
 or battery-electric vehicles. These storage options, which are often relatively  
 150 cheap compared to stationary electricity storage, are linked to the electrifica-  
 tion of other sectors such as heat and mobility, a strategy often referred to as  
 sector coupling or *Power-to-X* [10]. Importantly, such other types of energy  
 storage usually do not feed back electricity to the grid, in contrast to *Power-to-*  
*Power* storage, but they can increase the demand-side flexibility of the power  
 155 sector. Sector coupling with chemical storage, such as hydrogen or synthetic hy-

drowcarbons, which can be transported, may further allow not only for temporal, but also for spatial balancing of energy demand and renewable supply.

A major project of the German national science academies has shown that massive sector coupling can substantially contribute to buffering renewable energy variability and mitigate electricity storage needs, if it is carried out in a system-oriented way with sufficient heat and hydrogen storage capacities [11]. In particular, electric vehicle batteries can help to balance daily PV variability, while Power-to-Gas and thermal energy storage may balance longer-term wind power fluctuations, as shown in another study for Europe [12]. The use of electricity for heating, in combination with thermal energy storage, emerges as a particularly interesting seasonal balancing option because of relatively low specific investment costs.

Figure 2 illustrates the effects of flexible sector coupling for the stylized German setting discussed before, assuming a generic sector coupling technology with an additional, exogenous yearly electricity demand of 8% of the traditional electric load. This level was selected as it roughly equals the renewable surplus generation of the case without sector coupling. The renewable share now applies to the sum of traditional load and sector coupling, so the yearly generation from variable renewables increases. Sector coupling is assumed to be very flexible here as it comes with a relatively high power rating (50% of peak load) and low full load hours (1020), which may be most plausible for Power-to-Heat technologies in connection with heat storage. In a setting with 60% renewables, such flexible sector coupling would almost completely substitute both electricity storage and renewable curtailment as it allows taking up most of the renewable surplus generation (Figure 2, left panel).

This mitigating effect on electricity storage vanishes if the renewable share increases to 90% and sector coupling remains on the same level (Figure 2, right panel). Here, electricity storage is largely used as in the case without sector coupling, with similar storage power and only slightly smaller storage energy capacity. The E/P ratio and yearly full cycles also do not change much. This is because sector coupling demand is relatively small compared to renewable






Figure 2: Residual load and electricity storage use in a setting with flexible sector coupling (electricity demand 8% of traditional yearly load, power rating 50% of peak load, 1020 full load hours). Stylized illustration for Germany.

surpluses in this setting, and it also does not contribute to peak residual load coverage on the very left-hand side.

If the sector coupling electricity demand increases, electricity storage needs  
 190 may also decrease to some extent in the 90% renewables case (SI.1.2). Yet  
 in 100% renewable scenarios, even large-scale flexible sector coupling hardly  
 changes the optimal electricity storage dimensioning (Figure 3). This is be-  
 cause electricity storage is no longer driven by making use of renewable sur-  
 pluses anymore; instead, it is needed for supplying positive residual load on the  
 195 left-hand side of the RLDC. It should be noted that the optimal storage power  
 substantially increases when the renewable share grows from 90% to 100%, and  
 the storage energy capacity grows even more strongly. In turn, the E/P ratio  
 increases, and yearly storage cycles decrease. Note that most of the renewable  
 200 generation potential would actually be used in this setting (right panel of Fig-  
 ure 3), and hardly anything would be curtailed. This puts into perspective an  
 argument made in a previous commentary in this journal, where the economics  
 of power systems with very high shares of variable renewables were questioned,  
 as these would suffer from an inefficient utilization of variable renewable gener-  
 ation assets [13]. In turn, the market value of renewable electricity should also




Figure 3: Residual load and electricity storage use in a setting with 100% renewables, in the right panel with large-scale flexible sector coupling (electricity demand 100% of traditional yearly load, power rating 250% of peak load, 2549 full load hours). Stylized illustration for Germany.

205 improve, an aspect which deserves further investigation.

Complementary RLDCs are provided in SI.1. The general finding that storage deployment is increasingly driven by the left-hand side of the RLDC when the renewable share approaches 100% also holds for alternative assumptions on technologies and costs as well as alternative base years. Yet it should be noted  
 210 that sector coupling may lead to increasing electricity storage needs if it is less flexible than assumed above, i.e., if flexibly taking up renewable surpluses is less feasible (SI.1.2).

#### *PV-batteries for solar prosumage*

A third strand of research deals with small-scale batteries that are coupled  
 215 with decentralized, and often residential, PV installations (*Power-to-Power*). Such PV-batteries are usually operated to optimize solar self-consumption. This concept is also referred to as prosumage, combining the terms *production*, *consumption*, and *storage* [14]. It extends the established prosumer concept by explicitly including storage. In recent years, investments in PV-batteries have  
 220 substantially increased in many markets, in particular in some U.S. regions and

in Australia, and their further growth bears the potential for substantial power market disruptions. While PV-batteries may contribute to renewable energy integration, neither investments nor operations are usually guided by energy system considerations, but driven by end-user preferences for self-generation, and by the regulatory environment.

The profitability and optimal dimensioning of PV-batteries used for self-consumption is relatively well-researched. Yet their overall power sector effects are so far less understood. A recent study for Western Australia indicates that PV-batteries may lead to residual load smoothing comparable to grid-scale stationary batteries, even though in a less cost-efficient way [15]. Yet their contribution to integrating very high shares of variable renewables is likely to be limited, as PV-batteries provide only short-term storage, for which there are also many competing flexibility options. Further, they can neither take up wind power surpluses, nor provide electricity to the grid in times of peak residual demand, if they are operated only to optimize PV self-consumption.

Importantly, the use of PV-batteries for self-consumption could be combined with other storage applications [2]. This may not only include energy arbitrage by a fleet of aggregated PV-battery systems, but also the provision of ancillary services. PV batteries could thus provide substantially more flexibility to the overall power sector than usually is the case today, facilitated by aggregators and service providers.

## Conclusions

With growing shares of variable renewable energy sources, electricity storage plays an increasing role in the renewable energy transition. But there is no definite answer to the question how much electricity storage will be required at which renewable penetration. Optimal capacity choices depend on the cost and availability of various electricity storage technologies, and on those of many other potential sources of power sector flexibility. Yet there is a broad consensus in the literature that system-wide storage needs remain moderate up to

250 fairly high shares of variable renewables. Accordingly, concerns that a possible  
shortage of electricity storage may hinder the further deployment of renewable  
generators are currently not justified in most electricity markets. While this con-  
clusion applies to the overall system level, the need for flexibility and electricity  
storage may be larger in specific distribution grid settings.

255 When the penetration of variable renewable energy sources approaches very  
high levels, the main driver for electricity storage deployment shifts from re-  
newable surplus integration (right-hand side of the RLDC) to peak residual  
load supply (left-hand side of the RLDC). Flexible sector coupling hardly con-  
tributes to the latter. Therefore, sector coupling can mitigate electricity storage  
260 needs in settings with moderate to high renewable penetrations, but not in fully  
renewable scenarios. Long-term electricity storage technologies thus remain a  
key element of decarbonized power sectors with very high shares of variable  
renewables, absent other firm low-carbon resources such as fossil generators  
with carbon capture and storage (CCS), advanced geothermal technologies, or  
265 battery-electric vehicles that feed electricity back to the grid.

R&D support for electricity storage technologies should thus focus on long-  
term storage options. Working toward low energy-related storage costs would  
be particularly desirable. Cheap long-term storage would address the seasonal  
mismatch of variable renewable supply and electricity demand, and could reduce  
270 renewable capacity needs and renewable surplus generation (SI.1.3). Long-term  
electricity storage technologies are likely to involve green hydrogen, e.g., electro-  
lysis and hydrogen storage with later reconversion to electricity in gas turbines  
or fuel cells, or the use of synthetic hydrocarbon fuels based on green hydrogen  
(Power-to-Gas or Power-to-Liquid). Yet pure R&D may not suffice. Previ-  
275 ous experience with renewable technologies, in particular solar PV, showed that  
incentives for actual market uptake can be required to scale up, foster technolog-  
ical learning, and develop supply chains needed at later stages of the renewable  
energy transition [16]. Importantly, such supportive measures should minimize  
unintended path dependencies. For example, support of hydrogen-based sector  
280 coupling should not lead to excessive hydrogen use in applications where much

more energy-efficient direct electrification options or energy-saving measures are available, such as heat pumps or building retrofits in the low-temperature heating sector.

For shorter-term electricity storage technologies, further R&D support is less  
285 urgent, as various technologies are already commercially available, and there are many other competing options for short-term flexibility. Instead, the market and regulatory conditions for electricity storage technologies have to be designed to enable a level playing field for storage technologies and other flexibility options across different applications. This claim is not new [17], but there still seems to  
290 be much room for improvement in many markets.

At the same time, future sector coupling should be enabled to become as temporally flexible as possible. This requires, for example, sufficient investments in heat or hydrogen storage capacity, as well as non-distortive charges and tariffs across sector boundaries that allow making use of such flexibility. Similarly, the  
295 regulatory framework should enable the realization of the full flexibility potential of PV-batteries in energy and ancillary service markets.

Regarding future energy system research, the first-mentioned research strand appears to be largely completed, but more detailed numerical research is necessary in the other two strands. In particular, we need a better understanding  
300 of the system effects of different centralized or decentralized sector coupling options and their interactions with electricity storage and other sources of power sector flexibility. Respective analyses should consider the flexibility constraints of sector coupling as well as regional specifics in more detail. This also includes more detailed analyses of battery-electric vehicles that feed electricity back to  
305 the grid, as this would change their character from a pure *Power-to-X* option to a technology that also contains *Power-to-Power* elements, such that they could also contribute to residual load coverage on the left-hand side of the RLDC. Likewise, the overall system effects of PV-batteries and the preconditions for realizing potential power sector benefits deserve more detailed analyses. Com-  
310 bining both research strands also appears to be promising, i.e., analyzing the system effects of decentralized self-consumption facilitated not only by batteries,

but also by electric vehicles or electric heating and/or cooling. To ensure the highest degree of transparency and reproducibility of respective numerical analyses, using open-source and open-data approaches, as promoted by the Open Energy Modelling Initiative, would be particularly desirable.

### Acknowledgments

I thank three anonymous reviewers for detailed and insightful comments on an earlier draft. I further thank the members of my research group “Transformation of the Energy Economy” at DIW Berlin for many insightful comments and joint previous work on the economics of electricity storage. I have written parts of this article during a research stay at the Energy Transition Hub at the Climate and Energy College of the University of Melbourne. I gratefully acknowledge research funding by the German Federal Ministry of Education and Research via the project Future of Fossil Fuels in the wake of greenhouse gas neutrality (FFF), research grant 01LA1810B.

### Data availability

The reduced version of the DIETER model that was used for generating the data for the graphs is available at <https://doi.org/10.5281/zenodo.3935702>.

### References

- [1] Xing Luo, Jihong Wang, Mark Dooner, and Jonathan Clarke. Overview of current development in electrical energy storage technologies and the application potential in power system operation. *Applied Energy*, 137:511–536, 2015. doi:10.1016/j.apenergy.2014.09.081.
- [2] A. Stephan, B. Battke, M.D. Beuse, J.H. Clausdeinken, and T.S. Schmidt. Limiting the public cost of stationary battery deployment by combining applications. *Nature Energy*, 1(7):16079–, 2016. doi:10.1038/nenergy.2016.79.

- [3] Peter D. Lund, Juuso Lindgren, Jani Mikkola, and Jyri Salpakari. Review of energy system flexibility measures to enable high levels of variable renewable electricity. *Renewable and Sustainable Energy Reviews*, 45:785 – 807, 2015. doi:10.1016/j.rser.2015.01.057.
- [4] W.-P. Schill and A. Zerrahn. Long-run power storage requirements for high shares of renewables: Results and sensitivities. *Renewable and Sustainable Energy Reviews*, 83:156–171, 2018. doi:10.1016/j.rser.2017.05.205.
- [5] Michael Child, Claudia Kemfert, Dmitrii Bogdanov, and Christian Breyer. Flexible electricity generation, grid exchange and storage for the transition to a 100% renewable energy system in Europe. *Renewable Energy*, 139:80 – 101, 2019. doi:10.1016/j.renene.2019.02.077.
- [6] Micah S. Ziegler, Joshua M. Mueller, Gonçalo D. Pereira, Juhyun Song, Marco Ferrara, Yet-Ming Chiang, and Jessika E. Trancik. Storage requirements and costs of shaping renewable energy toward grid decarbonization. *Joule*, 3(9):2134 – 2153, 2019. doi:10.1016/j.joule.2019.06.012.
- [7] Alexander Zerrahn, Wolf-Peter Schill, and Claudia Kemfert. On the economics of electrical storage for variable renewable energy sources. *European Economic Review*, 108:259 – 279, 2018. doi:10.1016/j.euroecorev.2018.07.004.
- [8] Alexander E. MacDonald, Christopher T. M. Clack, Anneliese Alexander, Adam Dunbar, James Wilczak, and Yuanfu Xie. Future cost-competitive electricity systems and their impact on US CO<sub>2</sub> emissions. *Nature Climate Change*, 6(5):526–531, 2016. doi:10.1038/nclimate2921.
- [9] D.P. Schlachtberger, T. Brown, S. Schramm, and M. Greiner. The benefits of cooperation in a highly renewable European electricity network. *Energy*, 134:469 – 481, 2017. doi:10.1016/j.energy.2017.06.004.
- [10] B.V. Mathiesen, H. Lund, D. Connolly, H. Wenzel, P.A. Østergaard, B. Möller, S. Nielsen, I. Ridjan, P. Karnøe, K. Sperling, and F.K.

Hvelplund. Smart energy systems for coherent 100% renewable energy and transport solutions. *Applied Energy*, 145:139 – 154, 2015. doi: 10.1016/j.apenergy.2015.01.075.

- [11] acatech/Leopoldina/Akademiunion. Coupling the different energy sectors – options for the next phase of the energy transition, August 2018. ISBN: 978-3-8047-3673-3. URL: [https://energiesysteme-zukunft.de/fileadmin/user\\_upload/Publikationen/PDFs/ESYS\\_Position\\_Paper\\_Coupling\\_the\\_different\\_energy\\_sectors.pdf](https://energiesysteme-zukunft.de/fileadmin/user_upload/Publikationen/PDFs/ESYS_Position_Paper_Coupling_the_different_energy_sectors.pdf).
- [12] T. Brown, D. Schlachtberger, A. Kies, S. Schramm, and M. Greiner. Synergies of sector coupling and transmission reinforcement in a cost-optimised, highly renewable European energy system. *Energy*, 160:720 – 739, 2018. doi:10.1016/j.energy.2018.06.222.
- [13] Jesse D. Jenkins, Max Luke, and Samuel Thernstrom. Getting to zero carbon emissions in the electric power sector. *Joule*, 2(12):2498–2510, 2018. doi:10.1016/j.joule.2018.11.013.
- [14] W.-P. Schill, A. Zerrahn, and F. Kunz. Prosumage of solar electricity: Pros, cons, and the system perspective. *Economics of Energy & Environmental Policy*, 6(1):7–31, 2017. doi:10.5547/2160-5890.6.1.wsch.
- [15] Kelvin Say, Wolf-Peter Schill, and Michele John. Degrees of displacement: The impact of household PV battery prosumage on utility generation and storage. *Applied Energy*, 2020. in press, arXiv preprint 2003.06987.
- [16] Gregory F Nemet. *How solar energy became cheap: A model for low-carbon innovation*. Routledge, London, 2019. doi:10.4324/9780367136604.
- [17] Ramteen Sioshansi, Paul Denholm, and Thomas Jenkin. Market and policy barriers to deployment of energy storage. *Economics of Energy & Environmental Policy*, 1(2):47–64, 2012.



## SI. Supplemental information

### SI.1. Supplemental data items

This section contains complementary residual load duration curve illustrations. All Figures are generated with a stylized open-source model that is described in section SI.2. For background on the use and the interpretation of RLDCs, see also [1, 2].

Compared to Figures 1-3 in the main text, the following SI Figures show results for additional renewable shares, alternative assumptions on the level and the flexibility of sector coupling, alternative storage and generation technologies, different cost assumptions, different assumptions on renewable availability, as well as alternative base years. Information on storage power, energy, E/P ratio and cycles for all SI Figures is provided in Table SI.1.

#### SI.1.1. Alternative renewable shares under baseline assumptions




Figure SI.1: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal), one storage technology (pumped hydro storage), and without sector coupling.

Figure SI.1 shows RLDCs for baseline assumptions. It is complementary to Figure 1 in the main text, but also includes other shares of variable renewables

up to 100%. For simplicity, only one stylized dispatchable generation technology (hard coal) and one stylized storage technology (pumped hydro) are used here, and there is no additional sector coupling.

If the share of variable renewables increases from 60% to 90%, the installed storage power nearly quadruples from 17% to 64% of peak load, and the storage energy capacity increases by the factor eight from 0.03% to 0.24% of yearly load. If the renewable share further grows to 100%, the need for electricity storage increases disproportionately, as the left-hand side of the RLDC has to be completely covered: storage power further increases to 92% of peak load, and the storage energy capacity grows even more to 1.20% of yearly load. The E/P ratio accordingly increases to 83.5. At the same time, yearly full storage cycles decrease from 56 in the 90% case to only 13 in the 100% case. Electricity storage accordingly has a more seasonal usage pattern in a fully renewable setting.




Figure SI.2: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal), one storage technology (pumped hydro storage), and flexible sector coupling (electricity demand 8% of traditional yearly load, power rating 50% of peak load, equivalent to 1020 full load hours).

Figure SI.2 shows RLDCs for a similar setting, but with additional sector coupling, complementary to in Figure 2 in the main text. It can be seen that

the storage-mitigating effect largely vanishes already when the renewable share increases from 60% to 70%. This is because sector coupling electricity demand is small compared to renewable surplus energy. In a 100% renewable setting, electricity storage investments and usage are similar to the case without sector coupling, as they are driven by positive residual load coverage on the left-hand side of the RLDC.

*SI.1.2. Alternative assumptions on the level and flexibility of sector coupling*




Figure SI.3: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal), one storage technology (pumped hydro storage), and flexible sector coupling (electricity demand 50% of traditional yearly load, power rating 200% of peak load, equivalent to 1593 full load hours).

Figure SI.3 shows RLDCs for a similar setting as above, but with higher sector coupling electricity demand corresponding to 50% of the traditional yearly load, and a power rating of 200% of the yearly peak load. Compared to the previous setting with only 8% additional demand, the electricity needed for sector coupling is now substantially larger than the renewable surplus for renewable shares below 80%. Accordingly, the right-hand side of the RLDC is largely covered by flexible sector coupling, and hardly any electricity storage is used. If

renewable shares increase to 90% or 95%, electricity storage energy and power capacity (as well as E/P ratios) are still lower than in the setting with 8% sector coupling demand, as sizeable parts of the renewable surplus energy are used by flexible sector coupling. Yet in a fully renewable setting, storage deployment and use are again similar as before, driven by the left-hand side of the RLDC.




Figure SI.4: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal), one storage technology (pumped hydro storage), and inflexible sector coupling (electricity demand 50% of traditional yearly load, power rating 50% of peak load, equivalent to 6372 full load hours).

Figure SI.4 indicates that results change when sector coupling is substantially less flexible, e.g., if sufficient heat or chemical storage capacities are missing. Here, an additional electricity demand corresponding to 50% of the traditional yearly load comes with a power rating of only 50% of the yearly peak load, so sector coupling full-load hours quadruple compared to the setting shown in Figure SI.3. Such inflexible sector coupling substantially increases the need for electricity storage, particularly if renewable shares are below 100%. This is because demand increases also during hours in which the residual load is positive, and electricity storage is needed to shift renewable surplus energy to these hours. Accordingly, both storage energy and power capacity grow by

around the factor four in the 90% renewables case compared to the setting with more flexible sector coupling shown above, and partly even more so in cases with lower renewable shares. In a fully renewable setting, the optimal electricity storage capacity is again similar to the situation without sector coupling (storage power even increases), but electricity storage is cycled more often to also supply sector coupling demand during hours with positive residual demand.

*SI.1.3. Alternative assumptions on electricity storage technologies and costs*

Figures SI.5 and SI.6 show RLDCs for two different storage technologies, under more conservative or more optimistic storage cost assumptions. Instead of the stylized pumped hydro technology used in most other Figures in this Commentary, two complementary electricity storage technologies are available here: lithium-ion batteries and hydrogen-based storage. Given their cost and roundtrip efficiency parameters, which are summarized in Table SI.2, lithium-ion batteries are more suitable for short-term storage, and hydrogen storage lends itself to long-term storage. While using only a single (pumped hydro) storage technology is an appropriate choice for high-level RLDC illustrations, the use of these two alternative technologies may provide a slightly more realistic picture.

Figure SI.5 shows results for conservative electricity storage cost assumptions. Up to 80% renewables, only lithium-ion batteries are deployed, with lower storage energy and power capacity compared to the setting with (cheaper) pumped hydro storage. For higher renewable penetrations, hydrogen storage is also used, which leads to a change in the shape of the orange storage loading area in the Figure. As the combination of the two storage technologies is more costly than the single pumped hydro technology, renewable generation deployment and curtailment also increase compared to the standard setting provided in Figure SI.1.

Figure SI.6 shows corresponding results for more optimistic electricity storage cost assumptions. Here, both electricity storage technologies are deployed already at a 60% renewable share, and this combination also leads to lower costs than pumped hydro storage. Accordingly, overall storage energy and power




Figure SI.5: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal) and two storage technologies (lithium-ion batteries and hydrogen storage, conservative cost assumptions).




Figure SI.6: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal) and two storage technologies (lithium-ion batteries and hydrogen storage, optimistic cost assumptions).

capacity increase. Renewable generation deployment and curtailment in turn decrease compared to the baseline setting shown in Figure SI.1.






Figure SI.7: Residual load and electricity storage use in a setting with 100% renewables, one dispatchable generation technology (hard coal) and long-term storage. The left (middle, right) panel shows results for energy-related storage investments of 1 (5, 10) euros/kWh.

Figure SI.7 further highlights the effects of alternative assumptions on energy-related storage costs in a 100% renewable setting. For simplicity, only hydrogen storage is included here. The left panel shows the RLDC for optimistic cost assumptions as shown in Table SI.2, with energy-related investment costs of 1 euro/kWh. Note that this is a truly optimistic assumption which reflects very low-cost cavern storage options [3]. If energy-related investment costs increase to 5 euros/kWh, the storage energy capacity decreases by 37%. At the same time, optimal renewable capacity deployment and overall system costs increase by 14% and 24%, respectively. If energy-related storage costs further increase to 10 euros/kWh, optimal storage energy capacity investments decrease further. In turn, renewable capacities (+24% compared to the 1 euro/kWh case) and system costs (+36%) increase even more. Very low energy-related storage costs would thus be extremely beneficial in scenarios with very high shares of variable renewables.

#### SI.1.4. More differentiated dispatchable technology portfolio

While all other Figures in this Commentary use only one stylized dispatchable technology for simplicity (hard coal), Figure SI.8 illustrates the effects of including additional dispatchable generation technologies, i.e., open and closed cycle gas turbines. These differ from hard coal with respect to fixed and variable




Figure SI.8: Residual load and electricity storage use in a setting with three dispatchable generation technologies (hard coal, open-cycle gas turbines, closed-cycle gas turbines) and one storage technology (pumped hydro storage).

costs. Note that the intention, again, is not to derive quantitative conclusions on the optimal mix of generation technologies. Rather, Figure SI.8 illustrates that electricity storage is used slightly differently in this setting. Renewable surplus energy is now shifted further to the left-hand side of the RLDC, in order to optimize the capacity investments and dispatch of the three dispatchable technologies.

#### SI.1.5. Alternative assumptions on the shares of wind and solar PV

Under baseline assumptions, the capacity shares of wind and solar PV are fixed to 50% each. Figures SI.9 and SI.10 show results for alternative settings with wind/solar capacity shares of 25/75%, or 75/25%, respectively. If the solar share increases to 75%, renewable surplus generation increases because of simultaneous daytime feed-in of solar PV plants. Accordingly, optimal electricity storage energy and power capacity generally increase. If, conversely, wind power has a capacity share of 75%, the optimal storage power capacity tends to decrease, following the changing shape of the renewable surplus curve. Yet



overall, qualitative findings are robust for different wind and solar PV shares.




Figure SI.9: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal) and one storage technology (pumped hydro storage), wind/solar PV capacity shares 25/75%.




Figure SI.10: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal) and one storage technology (pumped hydro storage), wind/solar PV capacity shares 75/25%.

### SI.1.6. Effects of different base years

All previous Figures are based on the year 2014. The following Figures show results for different base years between 2012 and 2018, i.e., for different time series of electricity demand and renewable availability factors, as provided by the Open Power System Data platform [4]. Historic years differ not only with respect to average full load hours of wind and solar generation, but also with respect to low-wind events, which can influence optimal electricity storage deployment. Yet while the shapes of residual load curves vary between the years to some degrees, the qualitative effects are similar.




Figure SI.11: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal) and one storage technology (pumped hydro storage), base year 2012.




Figure SI.12: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal) and one storage technology (pumped hydro storage), base year 2013.




Figure SI.13: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal) and one storage technology (pumped hydro storage), base year 2015.




Figure SI.14: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal) and one storage technology (pumped hydro storage), base year 2016.




Figure SI.15: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal) and one storage technology (pumped hydro storage), base year 2017.




Figure SI.16: Residual load and electricity storage use in a setting with one dispatchable generation technology (hard coal) and one storage technology (pumped hydro storage), base year 2018.

Table SI.1: Storage power, energy, E/P ratio and cycles for all SI Figures.

		Share of variable renewables					
		60%	70%	80%	90%	95%	100%
Figure SI.1							
Storage power	% of peak load	17%	29%	47%	64%	72%	92%
Storage energy	% of yearly load	0.03%	0.05%	0.10%	0.24%	0.41%	1.20%
E/P	hours	11.3	11.3	13.9	24.2	36.5	83.5
Full cycles		77.0	96.0	86.9	55.9	37.0	12.5
Figure SI.2							
Storage power	% of peak load	9%	24%	44%	64%	72%	92%
Storage energy	% of yearly load	0.01%	0.05%	0.09%	0.22%	0.36%	1.20%
E/P	hours	6.5	12.8	12.7	21.8	32.1	83.5
Full cycles		25.2	84.6	92.5	60.1	41.0	12.5
Figure SI.3							
Storage power	% of peak load	7%	8%	8%	22%	51%	92%
Storage energy	% of yearly load	0.00%	0.00%	0.00%	0.04%	0.17%	1.20%
E/P	hours	3.4	3.5	3.4	12.6	21.2	83.5
Full cycles		4.0	5.3	12.6	131.4	68.3	12.5
Figure SI.4							
Storage power	% of peak load	16%	30%	55%	87%	100%	104%
Storage energy	% of yearly load	0.03%	0.06%	0.08%	0.18%	0.27%	1.19%
E/P	hours	9.9	13.6	9.1	13.4	17.0	73.0
Full cycles		72.6	76.6	118.8	88.1	74.4	24.4
Figure SI.5							
Storage power Li-ion	% of peak load	7%	24%	45%	56%	55%	18%
Storage power H2	% of peak load				14%	28%	74%
Storage energy Li-ion	% of yearly load	0.00%	0.02%	0.04%	0.05%	0.05%	0.01%
Storage energy H2	% of yearly load				0.25%	0.57%	2.61%
E/P Li-ion	hours	3.8	5.3	5.9	6.1	5.7	5.1
E/P H2	hours				113.7	131.6	226.3
Full cycles Li-ion		186.7	187.3	177.4	177.5	171.0	186.6
Full cycles H2					12.9	9.5	4.3
Figure SI.6							
Storage power Li-ion	% of peak load	17%	30%	41%	56%	61%	57%
Storage power H2	% of peak load	11%	17%	28%	37%	46%	68%
Storage energy Li-ion	% of yearly load	0.01%	0.03%	0.04%	0.05%	0.06%	0.06%
Storage energy H2	% of yearly load	0.16%	0.57%	1.34%	2.12%	3.00%	8.17%
E/P Li-ion	hours	5.7	5.6	5.8	6.2	6.2	6.2
E/P H2	hours	92.8	219.7	306.6	361.7	416.8	765.9
Full cycles Li-ion		141.7	169.9	194.2	195.1	197.9	198.4
Full cycles H2		5.5	3.2	2.9	3.1	2.9	1.5
Figure SI.7, 1 euro/kWh							
Storage power	% of peak load						92%
Storage energy	% of yearly load						7.85%
E/P	hours						542.8
Full cycles							2.4
Figure SI.7, 5 euros/kWh							
Storage power	% of peak load						92%
Storage energy	% of yearly load						4.93%
E/P	hours						341.8
Full cycles							3.3
Figure SI.7, 10 euros/kWh							
Storage power	% of peak load						92%
Storage energy	% of yearly load						3.10%
E/P	hours						215.4
Full cycles							4.7

Continued on next page

Continued from previous page

		Share of variable renewables					
		60%	70%	80%	90%	95%	100%
Figure SI.8							
Storage power	% of peak load	16%	29%	47%	64%	75%	92%
Storage energy	% of yearly load	0.03%	0.05%	0.10%	0.23%	0.33%	1.20%
E/P	hours	10.5	11.2	13.7	23.2	28.3	83.5
Full cycles		101.1	106.3	92.1	57.6	43.6	12.5
Figure SI.9							
Storage power	% of peak load	38%	61%	81%	103%	99%	119%
Storage energy	% of yearly load	0.05%	0.08%	0.11%	0.25%	0.35%	1.21%
E/P	hours	7.6	8.1	8.9	15.3	22.4	65.0
Full cycles		160.2	157.7	149.4	80.9	55.2	13.8
Figure SI.10							
Storage power	% of peak load	17%	23%	31%	48%	61%	92%
Storage energy	% of yearly load	0.03%	0.06%	0.14%	0.30%	0.51%	1.17%
E/P	hours	12.9	18.1	28.7	40.3	53.7	81.3
Full cycles		44.1	44.7	40.2	33.1	25.4	13.8
Figure SI.11							
Storage power	% of peak load	21%	29%	46%	62%	68%	95%
Storage energy	% of yearly load	0.03%	0.06%	0.13%	0.26%	0.31%	1.29%
E/P	hours	8.1	13.7	18.1	26.8	28.6	85.3
Full cycles		105.6	90.4	74.9	53.6	43.7	11.1
Figure SI.12							
Storage power	% of peak load	15%	32%	53%	58%	61%	97%
Storage energy	% of yearly load	0.02%	0.07%	0.13%	0.30%	0.55%	1.30%
E/P	hours	9.8	13.0	15.0	31.6	54.6	82.3
Full cycles		101.7	89.1	79.1	46.2	25.3	9.5
Figure SI.13							
Storage power	% of peak load	18%	21%	39%	56%	63%	93%
Storage energy	% of yearly load	0.03%	0.04%	0.08%	0.22%	0.34%	1.30%
E/P	hours	11.0	12.2	13.6	25.9	34.7	91.1
Full cycles		66.5	89.9	87.1	54.1	36.4	8.5
Figure SI.14							
Storage power	% of peak load	21%	27%	43%	61%	59%	87%
Storage energy	% of yearly load	0.03%	0.05%	0.10%	0.20%	0.38%	1.27%
E/P	hours	10.2	12.0	15.0	20.7	41.0	92.4
Full cycles		73.3	91.8	82.5	61.8	36.5	12.1
Figure SI.15							
Storage power	% of peak load	15%	22%	40%	57%	60%	91%
Storage energy	% of yearly load	0.03%	0.05%	0.12%	0.27%	0.38%	1.94%
E/P	hours	11.7	13.2	18.7	30.4	41.0	138.0
Full cycles		75.0	88.5	68.0	45.3	31.3	6.7
Figure SI.16							
Storage power	% of peak load	18%	22%	36%	55%	64%	88%
Storage energy	% of yearly load	0.02%	0.04%	0.10%	0.22%	0.34%	1.21%
E/P	hours	8.9	11.7	17.7	25.3	33.8	87.9
Full cycles		74.0	99.2	81.9	57.9	42.8	12.7

## *SI.2. Supplemental experimental procedures*

The residual load duration curves presented in this article are generated with a stylized open-source power sector model, which is a much-reduced version of the more detailed *Dispatch and Investment Evaluation Tool with Endogenous Renewables* (DIETER). A description of the general setup of the full model [5] as well as various applications [6, 7, 8, 9, 10] can be found in the literature. Here, a stylized model version is used that builds on [2]. It features only a very limited set of generation and storage technologies, does not have a spatial resolution, and abstracts from various other sources of power sector flexibility, such as geographical balancing or demand-side measures. Its main purpose is not to determine optimal real-world technology portfolios, but to generate high-level insights on the development of residual load and electricity storage in settings with increasing shares of variable renewables.

The model minimizes overall power sector costs, which consist of investment costs and variable costs. Its results can be interpreted as the outcome of a frictionless market in a long-run equilibrium. It is a linear program that is solved for all consecutive hours of a full year, using GAMS / CPLEX. The optimization is subject to a number of constraints, such as generation capacity and storage restrictions as well as an energy balance. Sector coupling is modeled in a stylized way with only two restrictions, a first one that constrains hourly electricity use of sector coupling, and a second one that ensures that an exogenous yearly sector coupling electricity demand is met. Another restriction forces the model to cover a predefined share of overall yearly electricity demand (including sector coupling) by variable renewable energy sources.

Endogenous model outputs comprise overall system costs, capacity deployment and dispatch of all generation and electricity storage technologies, and the dispatch of the generic sector coupling technology.

Exogenous model inputs include time series of electricity demand and renewable availability, which are taken from the Open Power System Data platform [4], as well as fixed and variable costs and efficiencies of generation and storage technologies. Further, yearly electricity demand as well as the capacity of a



generic sector coupling technology are exogenously defined. The model is calibrated to German market data, using a greenfield approach. All input data is freely available together with the open-source code in the Zenodo repository <https://doi.org/10.5281/zenodo.3935702>.

For convenience, Table SI.2 summarizes key input data assumptions for electricity storage technologies. These are based on [3, 11, 12, 13]. For lithium-ion batteries and hydrogen storage, two different cost assumptions are used. The conservative one is guided by the 2030 perspective proposed by [13], and the optimistic one by the 2050 perspective.

Table SI.2: Key input data for electricity storage technologies, based on [3, 11, 12, 13].

	Roundtrip efficiency	Overnight investment costs energy [EUR/kWh]	Overnight investment costs power [EUR/kW]	Technical lifetime [years]
Li-ion, conservative	0.9	200	150	13
Li-ion, optimistic	0.9	100	100	13
Pumped hydro	0.8	80	1100	60
Hydrogen, conservative	0.4	15	3000	20
Hydrogen, optimistic	0.4	1	1500	20

### SI.3. Supplemental references

- [1] Falko Ueckerdt, Robert Brecha, Gunnar Luderer, Patrick Sullivan, Eva Schmid, Nico Bauer, Diana Böttger, and Robert Pietzcker. Representing power sector variability and the integration of variable renewables in long-term energy-economy models using residual load duration curves. *Energy*, 90:1799–1814, 2015. doi:10.1016/j.energy.2015.07.006.
- [2] Alexander Zerrahn, Wolf-Peter Schill, and Claudia Kemfert. On the economics of electrical storage for variable renewable energy sources. *European Economic Review*, 108:259 – 279, 2018. doi:10.1016/j.euroecorev.2018.07.004.
- [3] Georg Fuchs, Benedikt Lunz, Matthias Leuthold, and Dirk Uwe Sauer. Technology overview on electricity storage. Technical report, ISEA RWTH Aachen, June 2012. URL: [https://www.sefep.eu/activities/projects-studies/120628\\_Technology\\_Overview\\_Electricity\\_Storage\\_SEFEP\\_ISEA.pdf](https://www.sefep.eu/activities/projects-studies/120628_Technology_Overview_Electricity_Storage_SEFEP_ISEA.pdf).
- [4] Frauke Wiese, Ingmar Schlecht, Wolf-Dieter Bunke, Clemens Gerbaulet, Lion Hirth, Martin Jahn, Friedrich Kunz, Casimir Lorenz, Jonathan Mühlenpfordt, Juliane Reimann, and Wolf-Peter Schill. Open Power System Data - Frictionless data for electricity system modelling. *Applied Energy*, 236:401 – 409, 2019. doi:10.1016/j.apenergy.2018.11.097.
- [5] Alexander Zerrahn and Wolf-Peter Schill. Long-run power storage requirements for high shares of renewables: review and a new model. *Renewable and Sustainable Energy Reviews*, 79:1518 – 1534, 2017. doi:10.1016/j.rser.2016.11.098.
- [6] W.-P. Schill, A. Zerrahn, and F. Kunz. Prosumage of solar electricity: Pros, cons, and the system perspective. *Economics of Energy & Environmental Policy*, 6(1):7–31, 2017. doi:10.5547/2160-5890.6.1.wsch.

- [7] W.-P. Schill and A. Zerrahn. Long-run power storage requirements for high shares of renewables: Results and sensitivities. *Renewable and Sustainable Energy Reviews*, 83:156–171, 2018. doi:10.1016/j.rser.2017.05.205.
- [8] Claudia Günther, Wolf-Peter Schill, and Alexander Zerrahn. Prosumage of solar electricity: Tariff design, capacity investments, and power system effects, 2019. arXiv:1907.09855.
- [9] Wolf-Peter Schill and Alexander Zerrahn. Flexible electricity use for heating in markets with renewable energy. *Applied Energy*, 266:114571, 2020. doi:10.1016/j.apenergy.2020.114571.
- [10] Kelvin Say, Wolf-Peter Schill, and Michele John. Degrees of displacement: The impact of household PV battery prosumage on utility generation and storage. *Applied Energy*, 2020. in press, arXiv preprint 2003.06987.
- [11] JRC. Energy technology reference indicator projections for 2010-2050. Technical report, 2014. URL: <https://setis.ec.europa.eu/publications/jrc-setis-reports/etri-2014>.
- [12] Oliver Schmidt, Sylvain Melchior, Adam Hawkes, and Iain Staffell. Update 2018 - The future cost of electrical energy storage based on experience rates. 8 2018. doi:10.6084/m9.figshare.7012202.v1.
- [13] Oliver Schmidt, Sylvain Melchior, Adam Hawkes, and Iain Staffell. Projecting the future levelized cost of electricity storage technologies. *Joule*, 3(1):81 – 100, 2019. doi:10.1016/j.joule.2018.12.008.